

```
*****
*
*      STAAD.Pro
*      Version  2007    Build 04
*      Proprietary Program of
*      Research Engineers, Intl.
*      Date=    JAN 18, 2013
*      Time=    15:14:25
*
*      USER ID:
*****

1. STAAD SPACE
INPUT FILE: 20121220 T-Goal Post 032-034 R2.STD
2. START JOB INFORMATION
3. ENGINEER DATE 12-MAY-12
4. END JOB INFORMATION
5. INPUT WIDTH 79
6. UNIT METER KN
7. JOINT COORDINATES
8. 2 5 0.3 -6.255; 4 5 3.648 -6.255; 6 5 3.648 -7.405; 11 5 0.3 -7.405
9. 12 6.019 0.3 -6.255; 13 6.019 3.648 -6.255; 14 6.019 3.648 -7.405
10. 15 6.019 0.3 -7.405
11. MEMBER INCIDENCES
12. 3 2 4; 5 6 4; 10 11 6; 11 12 13; 12 14 13; 13 15 14; 14 6 14; 15 4 13
13. DEFINE MATERIAL START
14. ISOTROPIC STEEL
15. E 2.05E+008
16. POISSON 0.3
17. DENSITY 76.8195
18. ALPHA 1.2E-005
19. DAMP 0.03
20. END DEFINE MATERIAL
21. MEMBER PROPERTY JAPANESE
22. 3 10 11 13 TABLE ST H394X398X11
23. 5 12 14 15 TABLE ST H394X398X11
24. CONSTANTS
25. MATERIAL STEEL ALL
26. SUPPORTS
27. 2 11 12 15 FIXED
28. MEMBER RELEASE
29. 5 12 START MY MZ
30. 5 12 END MY MZ
31. ***** DEAD LOAD *****
32. LOAD 1 LOADTYPE NONE TITLE DL
33. SELFWEIGHT Y -1 LIST 3 5 10 TO 15
34. MEMBER LOAD
35. 14 15 UNI GY -85.4
36. *5 12 CON GY -174 0.575
37. *5 12 UNI GY -1.4
38. 14 15 UNI GY -1.52
39. ***** FRICTIONAL LOAD *****
40. LOAD 2 LOADTYPE NONE TITLE FL
41. MEMBER LOAD
42. 14 15 UNI GZ -0.5
43. **5 12 CON GZ -1 0.575
44. ***** WIND LOAD X-DIRECTION*****
45. LOAD 3 LOADTYPE NONE TITLE WLX
46. MEMBER LOAD
47. 3 10 11 13 UNI GX -0.34
48. 5 12 UNI GX -0.34
49. ***** WIND LOAD Z-DIRECTION*****
50. LOAD 4 LOADTYPE NONE TITLE WLZ
51. MEMBER LOAD
52. 3 10 11 13 UNI GZ -0.34
53. 14 15 UNI GZ -0.34
```

```
54. ***** NOTIONAL LOAD X-DIRECTION*****
55. LOAD 5 LOADTYPE NONE TITLE NLX
56. SELFWEIGHT X -0.015 LIST 3 5 10 TO 15
57. MEMBER LOAD
58. 14 15 UNI GX -1.281
59. *5 12 CON GX -2.61 0.575
60. *5 12 UNI GX -0.021
61. 14 15 UNI GX -0.023
62. *****NOTIONAL LOAD Z-DIRECTION*****
63. LOAD 6 LOADTYPE NONE TITLE NLZ
64. SELFWEIGHT Z -0.015 LIST 3 5 10 TO 15
65. MEMBER LOAD
66. 14 15 UNI GZ -1.281
67. *5 12 CON GZ -2.61 0.575
68. *5 12 UNI GZ -0.021
69. 14 15 UNI GZ -0.023
70. ***** LOAD COMBINATION - SERVICE *****
71. LOAD COMB 7 1.0DL+1.0FL
72. 1 1.0 2 1.0
73. LOAD COMB 8 1.0DL+1.0FL+1.0WLX
74. 1 1.0 2 1.0 3 1.0
75. LOAD COMB 9 1.0DL+1.0FL+1.0WLZ
76. 1 1.0 2 1.0 4 1.0
77. LOAD COMB 10 1.0DL+1.0FL+1.0NLX
78. 1 1.0 2 1.0 5 1.0
79. LOAD COMB 11 1.0DL+1.0FL+1.0NLZ
80. 1 1.0 2 1.0 6 1.0
81. ***** LOAD COMBINATION - ULTIMATE *****
82. LOAD COMB 12 1.0DL+1.4FL
83. 1 1.0 2 1.4
84. LOAD COMB 13 1.4DL+1.4FL
85. 1 1.4 2 1.4
86. LOAD COMB 14 1.0DL+1.4FL+1.4WLX
87. 1 1.0 2 1.4 3 1.4
88. LOAD COMB 15 1.0DL+1.4FL+1.4WLZ
89. 1 1.0 2 1.4 4 1.4
90. LOAD COMB 16 1.0DL+1.4FL+1.4NLX
91. 1 1.0 2 1.4 5 1.4
92. LOAD COMB 17 1.0DL+1.4FL+1.4NLZ
93. 1 1.0 2 1.4 6 1.4
94. PERFORM ANALYSIS
```

P R O B L E M S T A T I S T I C S

NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS = 8/ 8/ 4

SOLVER USED IS THE IN-CORE ADVANCED SOLVER

TOTAL PRIMARY LOAD CASES = 6, TOTAL DEGREES OF FREEDOM = 24

95. LOAD LIST 7 TO 11
96. PRINT JOINT DISPLACEMENTS ALL

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
2	7	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	8	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	9	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
2	7	1.03	50.65	0.25	0.85	0.00	-0.94
	8	2.36	52.03	0.25	0.85	0.00	-2.79
	9	1.03	50.65	1.57	3.34	0.00	-0.94
	10	1.79	52.36	0.25	0.85	0.00	-2.49
	11	1.03	50.65	1.01	3.28	0.00	-0.94
11	7	1.03	50.65	0.25	0.85	0.00	-0.94
	8	2.36	52.03	0.25	0.85	0.00	-2.79
	9	1.03	50.65	1.57	3.34	0.00	-0.94
	10	1.79	52.36	0.25	0.85	0.00	-2.49
	11	1.03	50.65	1.01	3.28	0.00	-0.94
12	7	-1.03	50.65	0.25	0.85	0.00	0.94
	8	0.31	49.26	0.25	0.85	0.00	-0.92
	9	-1.03	50.65	1.57	3.34	0.00	0.94
	10	-0.27	48.93	0.25	0.85	0.00	-0.61
	11	-1.03	50.65	1.01	3.28	0.00	0.94
15	7	-1.03	50.65	0.25	0.85	0.00	0.94
	8	0.31	49.26	0.25	0.85	0.00	-0.92
	9	-1.03	50.65	1.57	3.34	0.00	0.94

11	-1.03	50.65	1.01	3.28	0.00	0.94		
***** END OF LATEST ANALYSIS RESULT *****								
98. LOAD LIST 12 TO 17								
99. PRINT MEMBER FORCES ALL								
MEMBER END FORCES STRUCTURE TYPE = SPACE								

ALL UNITS ARE -- KN METE (LOCAL)								
MEMBER	LOAD	JT	AXIAL	SHEAR-Y	SHEAR-Z	TORSION	MOM-Y	MOM-Z
3	12	2	50.65	-1.03	0.36	0.00	-1.19	-0.94
		4	-45.84	1.03	-0.36	0.00	0.00	-2.50
	13	2	70.90	-1.44	0.36	0.00	-1.19	-1.31
		4	-64.18	1.44	-0.36	0.00	0.00	-3.50
	14	2	52.59	-2.89	0.36	0.00	-1.19	-3.53
		4	-47.78	1.30	-0.36	0.00	0.00	-3.49
	15	2	50.65	-1.03	2.19	0.00	-4.67	-0.94
		4	-45.84	1.03	-0.60	0.00	0.00	-2.50
	16	2	53.05	-2.09	0.36	0.00	-1.19	-3.11
		4	-48.24	1.99	-0.36	0.00	0.00	-3.73
	17	2	50.65	-1.03	1.42	0.00	-4.59	-0.94
		4	-45.84	1.03	-1.32	0.00	0.00	-2.50
5	12	6	0.00	0.83	0.00	0.00	0.00	0.00
		4	0.00	0.83	0.00	0.00	0.00	0.00
	13	6	0.00	1.16	0.00	0.00	0.00	0.00
		4	0.00	1.16	0.00	0.00	0.00	0.00
	14	6	0.00	0.83	-0.27	0.00	0.00	0.00
		4	0.00	0.83	-0.27	0.00	0.00	0.00
	15	6	0.00	0.83	0.00	0.00	0.00	0.00
		4	0.00	0.83	0.00	0.00	0.00	0.00
	16	6	0.00	0.83	-0.02	0.00	0.00	0.00
		4	0.00	0.83	-0.02	0.00	0.00	0.00
	17	6	0.02	0.83	0.00	0.00	0.00	0.00
		4	0.02	0.83	0.00	0.00	0.00	0.00
10	12	11	50.65	-1.03	0.36	0.00	-1.19	-0.94
		6	-45.84	1.03	-0.36	0.00	0.00	-2.50
	13	11	70.90	-1.44	0.36	0.00	-1.19	-1.31
		6	-64.18	1.44	-0.36	0.00	0.00	-3.50
	14	11	52.59	-2.89	0.36	0.00	-1.19	-3.53
		6	-47.78	1.30	-0.36	0.00	0.00	-3.49
	15	11	50.65	-1.03	2.19	0.00	-4.67	-0.94
		6	-45.84	1.03	-0.60	0.00	0.00	-2.50
	16	11	53.05	-2.09	0.36	0.00	-1.19	-3.11
		6	-48.24	1.99	-0.36	0.00	0.00	-3.73
	17	11	50.65	-1.03	1.42	0.00	-4.59	-0.94
		6	-45.84	1.03	-1.32	0.00	0.00	-2.50
11	12	12	50.65	1.03	0.36	0.00	-1.19	0.94
		13	-45.84	-1.03	-0.36	0.00	0.00	2.50
	13	12	70.90	1.44	0.36	0.00	-1.19	1.31
		13	-64.18	-1.44	-0.36	0.00	0.00	3.50
	14	12	48.71	-0.84	0.36	0.00	-1.19	-1.66
		13	-43.90	-0.75	-0.36	0.00	0.00	1.51

MEMBER END FORCES STRUCTURE TYPE = SPACE

Friday, January 18, 2013, 03:14 PM

MEMBER	LOAD	JT	AXIAL	SHEAR-Y	SHEAR-Z	TORSION	MOM-Y	MOM-Z
15	12	12	50.65	1.03	2.19	0.00	-4.67	0.94
	13	13	-45.84	-1.03	-0.60	0.00	0.00	2.50
16	12	12	48.25	-0.04	0.36	0.00	-1.19	-1.23
	13	13	-43.44	-0.06	-0.36	0.00	0.00	1.28
17	12	12	50.65	1.03	1.42	0.00	-4.59	0.94
	13	13	-45.84	-1.03	-1.32	0.00	0.00	2.50
12	12	14	0.00	0.83	0.00	0.00	0.00	0.00
	13	13	0.00	0.83	0.00	0.00	0.00	0.00
	13	14	0.00	1.16	0.00	0.00	0.00	0.00
	13	13	0.00	1.16	0.00	0.00	0.00	0.00
14	14	14	0.00	0.83	-0.27	0.00	0.00	0.00
	13	13	0.00	0.83	-0.27	0.00	0.00	0.00
15	14	14	0.00	0.83	0.00	0.00	0.00	0.00
	13	13	0.00	0.83	0.00	0.00	0.00	0.00
16	14	14	0.00	0.83	-0.02	0.00	0.00	0.00
	13	13	0.00	0.83	-0.02	0.00	0.00	0.00
17	14	14	0.02	0.83	0.00	0.00	0.00	0.00
	13	13	0.02	0.83	0.00	0.00	0.00	0.00
13	12	15	50.65	1.03	0.36	0.00	-1.19	0.94
	14	14	-45.84	-1.03	-0.36	0.00	0.00	2.50
13	15	15	70.90	1.44	0.36	0.00	-1.19	1.31
	14	14	-64.18	-1.44	-0.36	0.00	0.00	3.50
14	15	15	48.71	-0.84	0.36	0.00	-1.19	-1.66
	14	14	-43.90	-0.75	-0.36	0.00	0.00	1.51
15	15	15	50.65	1.03	2.19	0.00	-4.67	0.94
	14	14	-45.84	-1.03	-0.60	0.00	0.00	2.50
16	15	15	48.25	-0.04	0.36	0.00	-1.19	-1.23
	14	14	-43.44	-0.06	-0.36	0.00	0.00	1.28
17	15	15	50.65	1.03	1.42	0.00	-4.59	0.94
	14	14	-45.84	-1.03	-1.32	0.00	0.00	2.50
14	12	6	1.03	45.02	0.36	0.00	0.00	2.50
	14	14	-1.03	45.02	0.36	0.00	0.00	-2.50
13	6	6	1.44	63.02	0.36	0.00	0.00	3.50
	14	14	-1.44	63.02	0.36	0.00	0.00	-3.50
14	6	6	1.03	46.96	0.36	0.00	0.00	3.49
	14	14	-1.03	43.08	0.36	0.00	0.00	-1.51
15	6	6	1.03	45.02	0.60	0.00	0.00	2.50
	14	14	-1.03	45.02	0.60	0.00	0.00	-2.50
16	6	6	1.97	47.42	0.36	0.00	0.00	3.73
	14	14	-0.08	42.62	0.36	0.00	0.00	-1.28
17	6	6	1.03	45.02	1.30	0.00	0.00	2.50
	14	14	-1.03	45.02	1.30	0.00	0.00	-2.50
15	12	4	1.03	45.02	0.36	0.00	0.00	2.50
	13	13	-1.03	45.02	0.36	0.00	0.00	-2.50

MEMBER END FORCES STRUCTURE TYPE = SPACE

ALL UNITS ARE -- KN METE (LOCAL)

MEMBER	LOAD	JT	AXIAL	SHEAR-Y	SHEAR-Z	TORSION	MOM-Y	MOM-Z
13	4	4	1.44	63.02	0.36	0.00	0.00	3.50
	13	13	-1.44	63.02	0.36	0.00	0.00	-3.50
14	4	4	1.03	46.96	0.36	0.00	0.00	3.49
	13	13	-1.03	43.08	0.36	0.00	0.00	-1.51
15	4	4	1.03	45.02	0.60	0.00	0.00	2.50
	13	13	-1.03	45.02	0.60	0.00	0.00	-2.50
16	4	4	1.97	47.42	0.36	0.00	0.00	3.73
	13	13	-0.08	42.62	0.36	0.00	0.00	-1.28

Friday, January 18, 2013, 03:14 PM

17	4	1.03	45.02	1.30	0.00	0.00	2.50
	13	-1.03	45.02	1.30	0.00	0.00	-2.50

***** END OF LATEST ANALYSIS RESULT *****

100. LOAD LIST ALL
 101. PARAMETER 1
 102. CODE BS5950
 103. BEAM 2 ALL
 104. CHECK CODE ALL

STAAD.Pro CODE CHECKING - (BSI)

PROGRAM CODE REVISION V2.12_5950-1_2000

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
3 ST	H394X398X11	PASS	BS-4.8.3.3.2	0.028	15
		50.65 C	4.67	2.50	-
5 ST	H394X398X11	PASS	BS-4.2.3-(Y)	0.002	13
		0.00	0.00	0.00	0.00
10 ST	H394X398X11	PASS	BS-4.8.3.3.2	0.028	15
		50.65 C	4.67	2.50	-
11 ST	H394X398X11	PASS	BS-4.8.3.3.2	0.028	15
		50.65 C	4.67	2.50	-
12 ST	H394X398X11	PASS	BS-4.2.3-(Y)	0.002	13
		0.00	0.00	0.00	0.00
13 ST	H394X398X11	PASS	BS-4.8.3.3.2	0.028	15
		50.65 C	4.67	2.50	-
14 ST	H394X398X11	PASS	BS-4.2.3-(Y)	0.091	13
		1.44 C	0.00	3.50	0.00
15 ST	H394X398X11	PASS	BS-4.2.3-(Y)	0.091	13
		1.44 C	0.00	3.50	0.00

***** END OF TABULATED RESULT OF DESIGN *****

105. FINISH

***** END OF THE STAAD.Pro RUN *****

**** DATE= JAN 18,2013 TIME= 15:14:26 ****

 * For questions on STAAD.Pro, please contact *
 * Research Engineers Offices at the following locations *
 * * *
 * Telephone Email *
 * USA: +1 (714)974-2500 support@bentley.com *
 * CANADA +1 (905)632-4771 detech@odandetech.com *
 * UK +44(1454)207-000 support@bentley.com *
 * NORWAY +47 67 57 21 30 staad@edr.no *
 * SINGAPORE +65 6225-6158 support@bentley.com *
 * INDIA +91(833)4006-2021 support@bentley.com *
 * JAPAN +81(03)5952-6500 eng-eye@crc.co.jp *
 * CHINA +86(411)8479-1166 support@bentley.com *