
* STAAD.Pro Bld 1001.US
* Version 2003
* Proprietary Program of
* Research Engineers, Intl.
* Date= JUN 15, 2009
* Time= 16:44: 8
*
* USER ID:

1. STAAD PLANE DXF IMPORT OF 1F-6K.DXF

2. START JOB INFORMATION
3. JOB NAME 1F 6K X 16K
4. JOB CLIENT ACI
5. ENGINEER NAME RCZ
6. APPROVED NAME ICK
7. ENGINEER DATE 15-JUN-09
8. END JOB INFORMATION
9. INPUT WIDTH 79
10. UNIT MMS KN
11. JOINT COORDINATES
12. 1 31.5215 34.4362 0; 2 31.5215 2884.44 0; 3 10951.5 34.4362 0
13. 4 10951.5 2884.44 0; 5 941.521 3094.53 0; 6 1851.52 3304.62 0
14. 7 2761.52 3514.71 0; 8 3671.52 3724.8 0; 9 4581.52 3934.89 0
15. 10 5491.52 4144.98 0; 11 6401.52 3934.89 0; 12 7311.52 3724.8 0
16. 13 8221.52 3514.71 0; 14 9131.52 3304.62 0; 15 10041.5 3094.53 0
17. 16 941.521 2884.44 0; 17 1851.52 2884.44 0; 18 2761.52 2884.44 0
18. 19 3671.52 2884.44 0; 20 4581.52 2884.44 0; 21 5491.52 2884.44 0
19. 22 6401.52 2884.44 0; 23 7311.52 2884.44 0; 24 8221.52 2884.44 0
20. 25 9131.52 2884.44 0; 26 10041.5 2884.44 0; 27 31.5215 2534.44 0
21. 28 -1368.48 2534.44 0; 29 -668.479 2534.44 0; 30 -668.478 2709.44 0
22. 31 -318.479 2534.44 0; 32 -318.478 2796.94 0
23. MEMBER INCIDENCES
24. 1 1 27; 2 3 4; 3 2 5; 4 5 6; 5 6 7; 6 7 8; 7 8 9; 8 9 10; 9 10 11; 10 11 12
25. 11 12 13; 12 13 14; 13 14 15; 14 15 4; 15 2 16; 16 16 17; 17 17 18; 18 18 19
26. 19 19 20; 20 20 21; 21 21 22; 22 22 23; 23 23 24; 24 24 25; 25 25 26; 26 26 4
27. 27 10 21; 28 16 5; 29 5 17; 30 17 6; 31 6 18; 32 18 7; 33 7 19; 34 19 8
28. 35 8 20; 36 20 9; 37 9 21; 38 21 11; 39 11 22; 40 22 12; 41 12 23; 42 23 13
29. 43 13 24; 44 24 14; 45 14 25; 46 25 15; 47 15 26; 48 27 2; 49 27 31; 50 28 30
30. 51 29 28; 52 30 32; 53 31 29; 54 32 2; 55 29 30; 56 30 31; 57 31 32; 58 32 27
31. 59 27 16
32. DEFINE MATERIAL START
33. ISOTROPIC STEEL
34. E 205
35. POISSON 0.3
36. DENSITY 7.68195E-008
37. ALPHA 6.5E-006
38. DAMP 0.03
39. END DEFINE MATERIAL
40. CONSTANTS
41. MATERIAL STEEL ALL

DXF IMPORT OF 1F-6K.DXF

42. START USER TABLE
43. TABLE 1
44. UNIT MMS KN
45. GENERAL
46. C38X38
47. 252 38 2.3 38 2.3 38072 62913 100000 1557 3311 87 175 1557 3311 100000 38
48. TABLE 2
49. UNIT MMS KN
50. GENERAL
51. 2C75X45
52. 1098 75 6 90 3 938192 638334 100000 26218 14185 450 270 26218 14185 100000 75
53. TABLE 3
54. UNIT MMS KN
55. GENERAL
56. C100X50
57. 653 50 3 100 3 229000 990000 1E+006 7270 19800 300 343 11600 23600 1E+006 48
58. TABLE 4
59. UNIT MMS KN
60. GENERAL
61. C75X45
62. 518 45 3 75 3 138000 449000 100000 4940 12000 270 315 4940 12000 100000 40
63. TABLE 5
64. UNIT MMS KN
65. TUBE
66. SHS100X3-CF
67. 1140 100 100 3 1.77E+006 1.77E+006 2.79E+006 600 400
68. TABLE 6
69. UNIT MMS KN
70. TUBE
71. SHS100X4-CF
72. 1490 100 100 4 2.26E+006 2.26E+006 3.62E+006 800 533
73. TABLE 7
74. UNIT MMS KN
75. TUBE
76. SHS100X6-CF
77. 2160 100 100 6 3.11E+006 3.11E+006 5.14E+006 1200 800
78. TABLE 8
79. UNIT MMS KN
80. TUBE
81. SHS150X4.5CF
82. 2570 150 150 4.5 8.96E+006 8.96E+006 1.41E+007 1350 900
83. TABLE 9
84. UNIT MMS KN
85. TUBE
86. SHS75X3-CF
87. 841 75 75 3 716000 716000 1.15E+006 450 300
88. TABLE 10
89. UNIT MMS KN
90. TUBE
91. SHS50X3-CF
92. 541 50 50 3 195000 195000 321000 300 200
93. TABLE 11
94. UNIT MMS KN
95. TUBE
96. SHS38X3-CF
97. 397 38 38 3 78500 78500 133000 228 152

DXF IMPORT OF 1F-6K.DXF

98. TABLE 12
99. UNIT MMS KN
100. ANGLE
101. UA38X38X3
102. 38 38 3 14.5 114 1
103. END
104. MEMBER PROPERTY AMERICAN
105. 1 2 48 UPTABLE 2 2C75X45
106. 3 TO 27 UPTABLE 3 C100X50
107. 28 TO 47 59 UPTABLE 10 SHS50X3-CF
108. 49 TO 58 UPTABLE 12 UA38X38X3
109. MEMBER TRUSS
110. 27 TO 47 55 TO 58
111. MEMBER RELEASE
112. 3 15 49 START MX MY MZ
113. 14 26 54 END MX MY MZ
114. SUPPORTS
115. 1 3 PINNED
116. UNIT METER KN
117. LOAD 1 S/W
118. SELFWEIGHT Y -1
119. LOAD 2 DL
120. MEMBER LOAD
121. 3 TO 14 UNI GY -1.27
122. 50 52 54 UNI GY -0.64
123. LOAD 3 LL
124. MEMBER LOAD
125. 3 TO 14 UNI GY -1.82
126. 50 52 54 UNI GY -0.9
127. LOAD 4 WL
128. MEMBER LOAD
129. 3 TO 14 UNI GY 1
130. 50 52 54 UNI GY 0.5
131. LOAD COMB 6 ULTIMATE S/W+DL+LL
132. 1 1.4 2 1.4 3 1.6
133. LOAD COMB 7 ULTIMATE DL+WL
134. 1 1.0 2 1.0 4 1.4
135. LOAD COMB 9 SERVICE DL+LL FOR DEFLECTION
136. 2 1.0 3 1.0
137. LOAD COMB 10 SERVICE S/W+DL+LL FOR FOUNDATION DESIGN
138. 1 1.0 2 1.0 3 1.0
139. PERFORM ANALYSIS

PROBLEM STATISTICS

NUMBER OF JOINTS/MEMBER-ELEMENTS/SUPPORTS = 32/ 59/ 2
ORIGINAL/FINAL BAND-WIDTH= 30/ 3/
TOTAL PRIMARY LOAD CASES = 4, TOTAL DEGREES OF FREEDOM = 92
SIZE OF STIFFNESS MATRIX = 2 DOUBLE KILLO-WORDS
REQD/AVAIL. DISK SPACE = 12.1/ 32851.2 MB, EXMEM = 308.2 MB

DXF IMPORT OF 1F-6K.DXF

140. PARAMETER
141. CODE BS5950
142. CHECK CODE ALL

STAAD.Pro CODE CHECKING - (BSI)

PROGRAM CODE REVISION V2.4_5950-1_2000