

PAGE NO.
1

STAAD.Pro
Version 2006 Bld 1005.US
Proprietary Program of
Research Engineers, Intl.
Date= MAR 27, 2008
Time= 18:12:47

USER ID: M1PL

1. STAAD PLANE RAS B16 CONTROL OFFICE FRAME 1
INPUT FILE: Ras B16 Control Office Frame-1.STD

2. START JOB INFORMATION

3. ENGINEER DATE MAR-08

4. END JOB INFORMATION

5. INPUT WIDTH 79

6. UNIT METER KN

7. JOINT COORDINATES

8. 101 0 0

9. 201 0 5.23 0

10. 203 -1.805 5.23 0

11. 102 1.65 0 0

12. 202 1.65 5.23 0

13. 204 3.195 5.23 0

14. MEMBER INCIDENCES

15. 101 101 201

16. 102 102 202

17. 201 201 202

18. 202 203 201

19. 203 202 204

20. MEMBER PROPERTY

21. 101 PRI YD 0.4

22. 102 PRI YD 0.4

23. 201 PRI 2D 0.4 YD 0.6

24. 202 203 PRI 2D 0.4 YD 0.45

25. CONSTANTS

26. E 2.5E+007 MEMB 101 102 2001 2002 2003

27. POISSON 0.2 MEMB 101 102 2001 2002 2003

28. DENSITY 24 MEMB 101 102 2001 2002 2003

29. SUPPORTS

30. 101 102 FIX

31. LOAD 1 SELFWEIGHT

32. SELFWEIGHT Y -1

33. LOAD 2 SUL

34. JOINT LOAD

35. 201 202 FY -208.91

36. LOAD 3 LL

37. JOINT LOAD

38. 201 202 FY -92.39

40. LOAD 21 EQ (EARTHQUAKE LOAD)

41. MEMBER LOAD

RAS B16 CONTROL OFFICE FRAME 1

42. 101 UNI Y 18.6

43. 102 UNI Y 18.5

45. LOAD COMB 1001 1.4DL + 1.6LL

46. 1 1.4 2 1.4 3 1.6

47. LOAD COMB 1021 1.2DL + 0.5LL + 1.0EQ

1

48. 1 1.2 2 1.2 3 0.5 21 1.0
49. LOAD COMB 1121 1.2DL + 0.5LL - 1.0EQ
50. 1 1.2 2 1.2 3 0.5 21 -1.0
51. LOAD COMB 1221 0.9DL + 1.0EQ
52. 1 0.9 2 0.9 21 1.0
53. LOAD COMB 1321 0.9DL - 1.0EQ
54. 1 0.9 2 0.9 21 -1.0
56. LOAD COMB 2001 1.0DL + 1.0LL
57. 1 1.0 2 1.0 3 1.0
58. LOAD COMB 2002 1.0DL + 0.5LL
59. 1 1.0 2 1.0 3 0.5
61. PERFORM ANALYSIS

1

PROBLEM STATISTICS

NUMBER OF JOINTS/MEMBER/ELEMENTS/SUPPORTS = 6/ 5/ 2
ORIGINAL/FINAL BAND-WIDTH= 3/ 3/
TOTAL PRIMARY LOAD CASES = 4, TOTAL DEGREES OF FREEDOM = 12
SIZE OF STIFFNESS MATRIX = 1 DOUBLE KILO-WORDS
RECORD/AVAIL. DISK SPACE = 12.0/ 134460.3 MB

62. PRINT MAXFORCE ENV

RAS B16 CONTROL OFFICE FRAME 1

3

-- PAGE NO.

MEMBER FORCE ENVELOPE

ALL UNITS ARE KN METE

MAX AND MIN FORCE VALUES AMONGST ALL SECTION LOCATIONS

MEMB	FY/ FZ LD	DIST DIST LD	M2/ MY LD	DIST DIST LD	FX FY FZ	DIST DIST LD
101 MAX	97.31	0.00 1121	171.74	0.00 1121		
	0.00	0.00 1	0.00	0.00 1	481.49 C	0.00
	1001					
MIN	-97.15	0.00 21	-171.50	0.00 21		
	0.00	5.23 2002	0.00	5.23 2002	13.65 C	5.23
	1					
102 MAX	96.76	0.00 1321	171.02	0.00 1321		
	0.00	0.00 1	0.00	0.00 1	476.83 C	0.00
	1001					
MIN	-97.04	0.00 1021	-171.58	0.00 1021		
	0.00	5.23 2002	0.00	5.23 2002	99.78 T	5.23
	21					
2001 MAX	106.81	0.00 1021	90.06	0.00 1021		
	0.00	0.00 1	0.00	0.00 1	0.01 C	0.00
	1321					
MIN	-104.16	1.65 1121	-82.42	1.65 21		
	0.00	1.65 2002	0.00	1.65 2002	0.29 T	1.65
	1021					
2002 MAX	0.00	0.00 1	9.85	1.81 1001		

2