

Performed by Jonathan Campbell
Began on Jun 12, 2026 at 09:31 AM
Submitted on Jun 12, 2026 at 01:02 PM
At Greiner Brothers Inc.

Pass	34
Fail	4
N/A	41
Missing	1
Pass/Fail Percent	89% / 10%

Checklist Notes

This inspection report is proposed to serve as a compliance aid for the client to decrease the risk of detectible hazards. The primary function of this report serves to identify hazardous risks and insufficient protection which require corrective action or modified procedures. This report does not suggest that all other hazard(s) and provisions are unflawed at the time of this inspection. Adhering to any observation presented in this report does not guarantee the completion and success of the clients' obligations as may be required by any local, state or federal laws. No other liability is assumed by reason of this inspection report.

Title

Purdue Academic Building

Location Details

Indianapolis, IN

General

Competent Person On-Site? **PASS**

Yes

JHA Completed and available? **PASS**

Yes

First-Aid kit Available, stocked, and in date? **PASS**

Yes

Do employees know where to find proper SDS information? **PASS**

Yes

Working areas have properly lighting needed? **PASS**

Yes

Housekeeping

Clear paths of travel or egress? **PASS**

Yes

Immediate workspace clean and orderly? **PASS**

Yes

Is work area clear of trash and debris? **PASS**

Yes

Personal Protective Equipment

Is adequate PPE provided for the job? **PASS**

Yes

Are all employees wearing all required PPE for the task? PASS

Yes

Are all employees dress appropriately for the job and the weather? PASS

Yes

Power Tools

All hand and power tools are in good serviceable condition? PASS

Yes

All Guards are in place and have not been bypassed? PASS

Yes



All tools are being used for their designated purpose? PASS

Yes

Fire Protection


Only proper NFPA fuel storage cans in use? PASS

Yes

Fire Extinguishers are properly stored and are in serviceable condition? FAIL

No

Failed Finding Resolution Status - Unresolved



Missing inspection tag (FL11)



Need monthly inspection (FL 9)

Fire extinguishers are in the immediate area while any hot work is being completed? PASS

Yes

Electrical

GFCI in use on all Temporary power sources? PASS

Yes

Extension Cords in good serviceable condition? (including ground prongs)? PASS

Yes

Cords out of walkways and off of egress paths? PASS

Yes

Outer coating of electrical/extension cords free from any damage? PASS

Yes


Strain relief at the plug or cord in good condition? PASS

Yes

Material Stacking & Cribbing

Cribbing base is sturdy and in serviceable condition (not damaged, rotten, molding)? PASS

Yes



Ground under cribbing is stable for storage? PASS

Yes


Material that is supposed to be stored in cribbing is stored properly and contained. PASS

Missing

Hot Work

Oxygen / Acetylene - Cylinders properly secured and in upright position, barrier between cylinders, hoses, gauges, and flashback arrestors observed good condition? PASS

Yes



Cylinders not in use valve caps in place. Tanks properly secured and upright position? **PASS**

Yes

Fire watch is being used while completing hot work and being maintained 30 minutes after completion of hot work? **PASS**

Yes

Powered Industrial Truck (PIT)

Have pre-use inspections been completed? **FAIL**

No

Failed Finding Resolution Status - Unresolved



Either wrong month or hasn't been inspected in a month (FL11)



Missing inspection (FL9)

Is the operator been properly trained to use PIT **PASS**

Yes

Is machinery in serviceable condition? **PASS**

Yes

Are users properly tied off if required? **PASS**

Yes

Are operators and others in the immediate work area keeping proper communication with each other? **PASS**

Yes

Entry door closed for chain installed prior to operation? **PASS**

Yes

Ladders

Have ladders been inspected and are in good serviceable condition? **PASS**

Yes

Employees maintaining 3 points of contact? **PASS**

Yes

Employees using ladders for intended purpose? **PASS**

Yes

Has all required labels (warnings, load limits, etc...) **FAIL**

No

Failed Finding Resolution Status - Unresolved



FL 15 ladders missing labels

Hole Openings

Are holes greater than 2 inches in their least dimension protected by covers

FAIL

No

Failed Finding Resolution Status - Unresolved



FL 15 missing covers



FL14 covers missing