



Circuit Reliability Review

San Gabriel

January 2017

Providing Safe, Reliable, and Affordable Power

Southern California Edison is modernizing the power grid to meet the changing needs and expectations of our customers and to help California achieve its clean energy goals.

We are investing more than \$12 billion into our power grid between 2015 – 2017 with the goal of increasing power reliability through significant upgrades. These investments include:

- Updating thousands of transmission and distribution poles
- Replacing hundreds of miles of underground cables
- Replacing hundreds of underground structures such as vaults and manholes
- Upgrading critical distribution equipment; capacitor banks, switches, and circuit breakers
- Building new distribution circuits to serve electrical demands in our communities
- Inspecting and replacing overhead conductor and equipment to improve public safety

Our investments in local communities will help ensure that customers receive safe, reliable, and affordable electricity now and in the future.

Understanding Your Reliability Report

As your electric utility, we want you to always have power when you need it. To get there, we constantly track and monitor electric outages across our service territory, and we measure our “system reliability” from this data.

The two metrics we rely on are common in the electric utility industry: the System Average Interruption Duration Index (SAIDI) and the System Average Interruption Frequency Index (SAIFI). Both are described in more detail on the next page.

Replacing and upgrading our infrastructure will help SCE maintain or improve SAIDI and SAIFI measurements.

This report provides historical reliability data for the circuits that serve your jurisdiction and our proposed infrastructure upgrades for the current year.

To view other reliability reports, visit [sce.com>Outage Center>Maintaining Reliable Service](https://www.sce.com/Outage-Center/Maintaining-Reliable-Service)

Reliability Metrics

MOMENTARY OUTAGES:

OUTAGES LASTING 5 MINUTES OR LESS

MAIFI:

- The number of times the average customer is interrupted by Momentary outages each year.

SUSTAINED OUTAGES:


OUTAGES LASTING LONGER THAN 5 MINUTES

SAIFI:

- The number of times the average customer is interrupted by Sustained outages each year.

SAIDI:

- The cumulative amount of time the average customer is interrupted by Sustained outages each year.





Cities in the Monrovia District

Altadena

Arcadia

Azusa

Baldwin Park

Bradbury

Duarte

East Pasadena

East San Gabriel

Glendale

Irwindale

La Canada Flintridge

La Crescenta-Montrose

Los Angeles

Mayflower Village

Monrovia

Pasadena

San Gabriel

San Marino

Sierra Madre

South Pasadena

Temple City

Vincent

West Puente Valley

Reliability by SCE District (No Exclusions)

District Name	2012				2013				2014				2015				2016			
	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking
ANTELOPE VALLEY	78.60	28	0.56	31	94.42	22	0.62	31	51.05	35	0.59	34	104.34	22	0.68	30	107.67	24	0.87	29
ARROWHEAD	129.58	13	1.31	7	180.59	7	1.39	8	193.25	5	1.59	5	362.61	4	3.97	1	659.46	3	2.85	5
BARSTOW	184.80	7	1.15	12	204.33	6	1.40	7	201.53	4	1.34	10	187.11	8	1.17	12	134.83	18	1.35	9
BIG CREEK	1184.25	1	4.52	1	176.51	8	3.08	1	920.25	1	1.34	11	422.77	2	3.42	2	1062.01	2	4.99	1
BISHOP	463.09	2	1.25	9	104.44	17	0.51	35	118.79	17	0.59	35	298.11	6	2.22	4	168.59	8	1.22	14
BLYTHE	225.88	6	1.53	3	483.13	1	1.38	9	707.54	2	2.42	2	427.00	1	1.52	7	396.38	5	2.71	6
CATALINA	78.46	30	0.72	29	105.94	16	2.97	2	97.02	24	4.17	1	42.56	35	2.25	3	65.01	35	3.66	3
COVINA	108.73	19	0.92	19	100.51	19	0.86	20	91.60	27	0.87	22	100.08	23	0.81	25	112.13	22	0.97	24
DOMINGUEZ HILLS	117.22	18	0.82	24	89.17	26	0.80	21	82.30	29	0.71	28	130.63	15	0.97	17	146.38	12	1.11	17
FOOTHILL	91.69	25	0.90	20	85.80	27	0.79	24	93.35	25	0.93	21	109.64	20	0.95	20	142.81	14	1.03	21
FULLERTON	68.99	33	0.42	35	90.57	25	0.79	22	82.23	30	0.72	27	76.59	29	0.67	31	92.72	30	0.76	34
HUNTINGTON BEACH	95.78	23	0.89	21	66.51	32	0.68	29	79.61	31	0.78	25	98.32	25	0.95	19	128.02	20	1.26	12
KERNVILLE	226.76	5	1.31	6	232.18	4	1.96	3	178.69	8	1.99	3	286.38	7	0.96	18	2421.32	1	3.67	2
LONG BEACH	75.83	31	0.55	33	75.11	30	0.70	28	66.33	34	0.61	32	164.46	9	0.89	23	135.16	17	0.86	31
MENIFEE	99.32	22	0.84	23	107.39	15	1.26	10	156.68	11	1.32	12	111.46	19	0.98	16	156.75	9	1.31	10
MONROVIA	108.11	20	1.13	15	99.12	20	1.02	16	133.32	14	1.16	16	96.68	26	0.88	24	116.57	21	0.84	32
MONTEBELLO	131.06	12	1.13	14	118.08	13	1.17	12	158.34	10	1.16	15	150.28	12	1.18	11	133.52	19	1.17	15
ONTARIO	93.09	24	0.87	22	77.39	29	0.79	23	97.91	23	1.00	19	94.04	27	0.74	27	105.07	27	0.93	27
PALM SPRINGS	175.92	8	1.27	8	112.80	14	0.77	25	107.04	20	0.71	29	99.54	24	0.80	26	107.58	25	1.07	19
REDLANDS	120.13	16	1.11	16	96.48	21	1.04	15	154.25	12	1.04	18	124.52	17	1.01	14	137.11	16	0.98	23
RIDGECREST	229.65	4	1.44	4	161.95	9	1.12	13	176.84	9	1.57	6	148.90	13	1.01	15	254.31	6	1.05	20
SADDLEBACK	83.01	27	0.73	27	70.69	31	0.53	34	99.07	22	0.74	26	46.03	34	0.39	35	65.99	34	0.65	35
SAN JOAQUIN	135.90	10	1.04	18	244.44	2	1.45	6	138.25	13	1.17	14	127.50	16	1.05	13	108.44	23	1.09	18
SANTA ANA	78.60	29	0.55	32	93.35	24	0.74	26	91.68	26	0.84	23	67.46	32	0.71	29	97.27	29	1.00	22
SANTA BARBARA	153.81	9	1.15	13	82.00	28	0.70	27	183.78	7	1.38	9	152.37	11	1.52	6	156.66	10	1.41	8
SANTA MONICA	101.69	21	0.79	25	122.78	12	1.00	17	110.76	19	0.99	20	75.41	30	0.62	32	91.08	31	0.95	26
SOUTH BAY	122.68	15	1.17	10	142.15	10	1.49	5	125.28	16	1.39	8	164.07	10	1.31	8	183.90	7	1.88	7
TEHACHAPI	117.96	17	1.43	5	232.67	3	1.12	14	130.70	15	1.29	13	298.96	5	1.21	9	97.29	28	1.13	16
THOUSAND OAKS	127.73	14	1.05	17	93.86	23	0.91	18	104.37	21	1.10	17	106.59	21	0.92	21	143.78	13	1.31	11
VALENCIA	62.01	35	0.46	34	51.04	34	0.53	33	79.23	32	0.61	33	72.27	31	0.61	33	105.09	26	0.97	25
VENTURA	134.81	11	1.15	11	100.52	18	1.21	11	183.79	6	1.65	4	148.85	14	1.19	10	150.41	11	1.24	13
VICTORVILLE	67.70	34	0.66	30	61.33	33	0.63	30	68.85	33	0.63	31	87.03	28	0.91	22	79.35	33	0.92	28
WHITTIER	72.60	32	0.74	26	135.04	11	0.86	19	87.60	28	0.70	30	114.52	18	0.73	28	137.34	15	0.81	33
WILDOMAR	88.54	26	0.72	28	40.51	35	0.56	32	118.49	18	0.81	24	52.70	33	0.60	34	84.01	32	0.87	30
YUCCA VALLEY	319.82	3	3.41	2	216.97	5	1.50	4	304.25	3	1.49	7	389.08	3	1.80	5	463.68	4	3.39	4
SCE SystemWide	108.13		0.89		102.61		0.91		112.00		0.96		114.83		0.92		134.48		1.10	

Exclusions are days which utilities are allowed to remove from their metrics because the outages on those days were caused by a severe acts of nature.


**In the columns showing "Rank," lower numbers indicate poorer performance.

Overview of San Gabriel

There are 29 circuits that serve San Gabriel


Circuit Type	Sum of Customers	Circuit Type	Sum of Customers	Circuit Type	Sum of Customers	Circuit Type	Sum of Customers
BEAN(4.16KV)	338						
BILTON(16KV)	4,459						
DANES(4.16KV)	460						
DEERFIELD(16KV)	2,668						
DEL MAR(4.16KV)	579						
DOBBINS(4.16KV)	423						
EDMOND(4.16KV)	658						
ELEMENTARY(4.16KV)	175						
ENDICOTT(4.16KV)	427						
GABRIELINO(4.16KV)	363						
GAINSBOROUGH(16KV)	1,990						
GERONA(16KV)	1,679						
HAMPTON(4.16KV)	490						
HIDALGO(4.16KV)	402						
HONOR(16KV)	2,157						
LA PRESA(4.16KV)	729						
LAS TUNAS(4.16KV)	682						
MYDA(4.16KV)	471						
NADINE(4.16KV)	686						
OLNEY(16KV)	1,780						
PALJAY(16KV)	1,869						
PUTNEY(4.16KV)	834						
ROANOKE(4.16KV)	376						
SARAH(4.16KV)	770						
SAXON(4.16KV)	677						
SEGOVIA(16KV)	1,485						
SUNNYSLOPE(4.16KV)	855						
TELSTAR(16KV)	2,846						
WILLARD(16KV)	2,939						
Grand Total	34,267						

Reliability History of Circuits Serving San Gabriel (No Exclusions)



Causes of Repair Outages in San Gabriel Circuits 2016 YTD


Contributions to SAIDI by Outage Cause



SAIDI = the cumulative amount of time the average customer is interrupted by “sustained” outages each year.


Causes of Repair Outages in San Gabriel Circuits 2016 YTD


Contributions to SAIFI by Outage Cause



- **Equipment Failure**
e.g., in-service failure of transformer, switch, or conductors
- **Vegetation/Animal**
e.g., tree branch, rodent, or bird causing a short circuit between conductors
- **Other**
e.g., patrolled but no cause found
- **Operations**
e.g., urgent maintenance w/o 3-day notice
- **3rd Party**
e.g., balloon, car hit pole, dig-in

SAIFI = the number of times the average customer is interrupted by “sustained” outages each year.





Back-up Slides

Reliability Histories of Circuits Serving San Gabriel

Updated through Year-End 2016

Average Reliability of 29 Circuits Serving San Gabriel

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
San Gabriel	95.0	1.0	1.2	157.4	1.4	1.5	119.4	1.0	2.4	21.9	0.2	0.5	34.7	0.2	0.7	8.9	0.1	0.5	80.9	0.5	0.6	146.4	1.0	2.2
3rd Party	0%	0%	5%	15%	23%	25%	19%	21%	11%	0%	0%	2%	1%	3%	2%	0%	0%	48%	36%	34%	9%	20%	17%	14%
Equipment Failure	80%	54%	13%	59%	50%	39%	20%	37%	4%	35%	46%	11%	91%	81%	34%	67%	65%	19%	3%	8%	58%	32%	37%	32%
Operation	1%	5%	0%	4%	6%	2%	6%	4%	6%	2%	2%	0%	0%	0%	0%	29%	30%	0%	57%	35%	5%	34%	19%	1%
Other	2%	0%	40%	20%	16%	20%	5%	9%	41%	18%	3%	70%	6%	2%	3%	3%	5%	33%	2%	6%	0%	5%	4%	24%
Vegetation/Animal	3%	20%	31%	1%	3%	12%	3%	12%	33%	2%	0%	0%	1%	14%	61%	1%	1%	0%	2%	17%	28%	2%	12%	26%
Weather/Fire/Earthquake	14%	21%	11%	0%	1%	1%	48%	16%	4%	43%	49%	17%	0%	0%	0%	0%	0%	0%	0%	0%	0%	6%	10%	4%
SCE Systemwide	102.6	0.9	1.2	112.0	1.0	1.4	114.8	0.9	1.4	40.5	0.3	0.4	34.8	0.3	0.4	29.4	0.2	0.3	29.8	0.3	0.4	134.5	1.1	1.6

Notes:

No outages are excluded from the metrics.

Outage Causes:

Other: e.g., patrolled but no cause could be found

Operations: e.g., urgent maintenance w/o 3-day notice to customers

3rd Party: e.g., balloons, car hit pole, dig-in

Vegetation/Animal: e.g., tree branch, rodent, or bird causing short circuit across conductors

SAIDI (minutes) = the cumulative amount of time the average customer is interrupted by "sustained" (longer than 5 minutes) outages.

SAIFI (interruptions) = the number of times the average customer is interrupted by "sustained" outages.

MAIFI (interruptions) = the number of times the average customer is interrupted by "momentary" (lasting 5 minutes or less) outages.

Reliability Histories for Individual Circuits Serving San Gabriel

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
BEAN(4.16KV) - Customers: 338	256.0	0.6	1.9	0.0	0.0	1.0	0.0	0.0	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	100%	98%	49%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	51%	0%	0%	100%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
BILTON(16KV) - Customers: 4,459	12.5	1.0	2.0	175.6	1.6	3.0	71.3	1.0	5.0	69.5	0.8	0.0	180.5	1.1	1.1	3.0	0.0	1.1	147.5	1.1	0.2	400.6	3.0	2.4
3rd Party	0%	0%	0%	0%	0%	0%	84%	98%	20%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	100%	37%	36%	54%	
Equipment Failure	3%	0%	0%	100%	100%	33%	16%	2%	20%	0%	0%	0%	96%	99%	100%	0%	0%	0%	0%	0%	0%	43%	37%	46%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	1%	0%	0%
Other	0%	0%	0%	0%	0%	33%	0%	0%	20%	0%	0%	0%	4%	1%	0%	0%	0%	0%	0%	0%	0%	2%	1%	0%
Vegetation/Animal	97%	100%	100%	0%	0%	33%	0%	0%	40%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	17%	26%	0%
DANES(4.16KV) - Customers: 460	5.0	0.1	0.0	39.1	1.0	0.0	16.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16.9	0.0	0.0	0.0	0.0	0.0	16.9	0.0	0.0
3rd Party	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	100%	100%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
DEERFIELD(16KV) - Customers: 2,668	15.8	0.0	1.5	112.1	2.1	1.8	31.9	0.1	2.0	6.3	0.0	2.0	81.8	0.6	0.4	0.0	0.0	1.0	19.1	1.0	2.0	107.2	1.6	5.4
3rd Party	0%	0%	0%	0%	0%	55%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	62%	42%	0%	69%	61%	45%	72%	36%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	0%	0%	50%	76%	37%	26%
Operation	0%	0%	0%	1%	1%	0%	6%	12%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	20%	24%	50%	28%	38%	0%	3%	7%	50%	0%	0%	50%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	37%
Vegetation/Animal	0%	0%	0%	2%	1%	0%	16%	41%	50%	100%	100%	0%	0%	0%	0%	0%	0%	0%	100%	100%	50%	24%	63%	18%
Weather/Fire/Earthquake	18%	34%	50%	0%	0%	0%	4%	3%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	18%

Reliability Histories for Individual Circuits Serving San Gabriel

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
DEL MAR(4.16KV) - Customers: 579	0.0	0.0	0.0	19.3	0.0	0.0	0.0	0.0	0.9	5.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	2.0	5.8	0.0	2.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	100%	100%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	50%	96%	63%	50%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	50%	4%	37%	50%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
DOBBINS(4.16KV) - Customers: 423	0.0	0.0	0.0	80.4	1.0	0.0	1.6	0.1	2.0	13.1	0.0	1.0	0.0	0.0	0.0	0.0	0.0	0.0	1.7	0.0	0.0	14.8	0.0	1.0
3rd Party	0%	0%	0%	100%	100%	0%	0%	0%	0%	42%	50%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	38%	27%	100%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	100%	100%	50%	58%	50%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	62%	73%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
EDMOND(4.16KV) - Customers: 658	0.3	0.0	2.0	0.0	0.0	1.0	37.0	1.0	1.1	0.0	0.0	0.0	25.2	0.4	1.6	99.3	0.7	0.0	0.0	0.0	0.0	124.6	1.1	1.6
3rd Party	0%	0%	50%	0%	0%	0%	0%	0%	95%	0%	0%	0%	98%	99%	39%	0%	0%	0%	0%	0%	0%	20%	35%	39%
Equipment Failure	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	0%	0%	0%	0%	0%	0%	5%	0%	0%	0%	2%	1%	0%	100%	100%	0%	0%	0%	0%	80%	65%	0%
Other	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	61%	0%	0%	0%	0%	0%	0%	0%	0%	61%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
ELEMENTARY(4.16KV) - Customers: 175	0.0	0.0	1.9	95.9	3.9	1.0	2.7	0.0	2.0	0.0	0.0	1.0	47.3	1.0	0.0	0.0	0.0	1.0	63.3	2.0	2.0	110.6	3.0	4.0
3rd Party	0%	0%	0%	34%	25%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	56%	50%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	50%	43%	34%	25%
Operation	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	50%	10%	24%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	100%	84%	50%	0%	48%	33%	25%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	16%	50%	50%	9%	33%	25%
Weather/Fire/Earthquake	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	25%

Reliability Histories for Individual Circuits Serving San Gabriel

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
ENDICOTT(4.16KV) - Customers: 427	107.4	2.3	2.0	0.0	0.0	0.0	30.2	0.0	2.0	0.0	0.0	0.0	0.0	0.0	0.0	4.9	0.0	0.0	0.0	0.0	0.0	4.9	0.0	0.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	62%	56%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	100%	100%	0%
Operation	0%	0%	0%	0%	0%	0%	100%	100%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	38%	44%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
GABRIELINO(4.16KV) - Customers: 363	12.0	1.0	1.0	107.5	1.1	3.0	578.0	2.1	4.9	86.3	1.0	0.0	264.7	1.0	1.0	4.4	0.2	1.0	23.9	1.0	1.0	379.3	3.2	3.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	15%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	100%	6%	31%	33%
Equipment Failure	0%	0%	0%	97%	92%	33%	7%	4%	24%	0%	0%	0%	53%	91%	100%	0%	0%	0%	0%	0%	0%	37%	29%	33%
Operation	0%	0%	0%	3%	8%	0%	47%	34%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	1%	6%	0%
Other	0%	0%	0%	0%	0%	33%	47%	62%	24%	0%	0%	0%	47%	9%	0%	0%	0%	100%	0%	0%	0%	33%	3%	33%
Vegetation/Animal	100%	100%	100%	0%	0%	33%	0%	0%	38%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	23%	32%	0%
GAINSBOROUGH(16KV) - Customers: 1,990	10.7	0.1	0.0	15.5	0.3	0.0	11.8	0.6	0.5	1.8	0.1	2.0	0.0	0.0	0.0	13.1	0.0	0.0	6.5	0.5	0.5	21.4	0.6	2.5
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	22%	16%	0%	0%	0%	0%	58%	6%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	100%	100%	100%	92%	90%	19%
Operation	0%	0%	0%	31%	93%	0%	2%	1%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	8%	10%	0%
Other	41%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	81%
Vegetation/Animal	0%	0%	0%	69%	7%	0%	39%	93%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	37%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
GERONA(16KV) - Customers: 1,679	429.3	0.9	0.7	329.9	1.6	0.5	11.1	0.1	3.0	0.0	0.0	1.5	0.0	0.0	0.0	9.4	0.0	0.8	0.0	0.0	0.0	9.4	0.0	2.3
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	100%	100%	100%	96%	81%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	100%	100%	36%
Operation	0%	0%	0%	2%	2%	0%	91%	94%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	50%	0%	0%	67%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	64%
Vegetation/Animal	0%	0%	0%	2%	2%	0%	0%	0%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	1%	15%	50%	9%	6%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving San Gabriel

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
HAMPTON(4.16KV) - Customers: 490	0.0	0.0	0.0	43.1	2.0	1.0	136.9	4.1	2.0	135.3	2.0	1.0	0.0	0.0	0.0	18.7	0.2	0.0	0.0	0.0	0.0	154.0	2.2	1.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	81%	50%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	88%	92%	100%
Operation	0%	0%	0%	0%	0%	0%	13%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	12%	49%	50%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	12%	8%	0%
Vegetation/Animal	0%	0%	0%	19%	50%	100%	6%	24%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	69%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
HIDALGO(4.16KV) - Customers: 402	1.2	0.0	0.0	52.1	2.0	1.0	119.4	4.0	2.0	135.5	2.0	1.0	24.9	0.2	0.0	0.0	0.0	0.0	11.9	0.0	0.0	172.3	2.2	1.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	85%	50%	0%	0%	0%	0%	100%	100%	100%	100%	100%	0%	0%	0%	0%	100%	100%	0%	100%	100%	100%
Operation	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	14%	50%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	15%	50%	100%	7%	25%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	79%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
HONOR(16KV) - Customers: 2,157	85.1	1.0	0.9	0.0	0.0	0.0	64.7	0.7	3.0	1.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0	22.9	0.0	0.0	24.1	0.0	1.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	95%	99%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	3%	1%	0%	0%	0%	0%	2%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	95%	70%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	33%	100%	100%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	5%	30%	100%
Vegetation/Animal	3%	0%	100%	0%	0%	0%	0%	0%	67%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	98%	98%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
LA PRESA(4.16KV) - Customers: 729	0.0	0.0	4.0	0.2	0.0	2.0	0.7	0.0	2.0	6.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	602.9	2.0	0.8	609.4	2.0	3.8
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	89%	50%	100%	88%	49%	22%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%	0%
Operation	0%	0%	0%	100%	100%	0%	100%	100%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%	0%	1%	0%
Other	0%	0%	25%	0%	0%	100%	0%	0%	50%	0%	0%	0%	0%	0%	33%	0%	0%	0%	11%	50%	0%	11%	50%	26%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	67%	0%	0%	0%	0%	0%	0%	0%	0%	52%
Weather/Fire/Earthquake	0%	0%	75%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving San Gabriel

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
LAS TUNAS(4.16KV) - Customers: 682	0.0	0.0	2.0	0.0	0.0	0.0	0.0	0.0	2.0	10.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	0.0	10.2	0.0	1.0
3rd Party	0%	0%	100%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	100%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
MYDA(4.16KV) - Customers: 471	0.0	0.0	1.0	0.0	0.0	0.0	0.7	0.1	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
NADINE(4.16KV) - Customers: 686	0.0	0.0	0.0	50.0	1.0	0.0	59.1	0.6	3.0	0.0	0.0	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	2.0
3rd Party	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	50%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	67%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	50%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
OLNEY(16KV) - Customers: 1,780	159.0	1.1	3.8	273.4	1.6	1.5	227.3	1.6	3.2	0.0	0.0	0.0	10.5	0.0	2.0	0.0	0.0	1.0	0.0	0.0	0.0	10.5	0.0	3.0
3rd Party	0%	0%	0%	66%	29%	100%	76%	35%	14%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	33%
Equipment Failure	89%	9%	25%	0%	0%	0%	24%	65%	0%	0%	0%	0%	100%	100%	50%	0%	0%	0%	0%	0%	0%	100%	100%	33%
Operation	11%	91%	0%	16%	12%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	50%	18%	59%	0%	0%	0%	55%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	25%	0%	0%	0%	0%	0%	31%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	33%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving San Gabriel

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
PALJAY(16KV) - Customers: 1,869	167.3	1.8	1.0	38.5	1.3	0.0	9.7	0.1	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3rd Party	0%	0%	0%	94%	99%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	98%	99%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	2%	1%	0%	6%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
PUTNEY(4.16KV) - Customers: 834	0.0	0.0	1.0	280.3	1.0	0.6	15.7	0.9	2.0	0.3	0.0	2.0	0.0	0.0	0.0	1.5	0.0	0.0	0.0	0.0	1.0	1.8	0.0	3.0
3rd Party	0%	0%	0%	0%	0%	0%	88%	99%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	100%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	100%	84%	67%	33%
Operation	0%	0%	0%	0%	0%	0%	12%	1%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	16%	33%	0%
Other	0%	0%	100%	0%	0%	0%	0%	0%	50%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	67%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
ROANOKE(4.16KV) - Customers: 376	149.4	1.0	0.0	40.0	1.9	0.9	161.2	5.0	2.0	140.6	2.0	1.0	4.4	0.0	0.0	0.0	0.0	0.0	0.0	1.0	145.0	2.1	2.0	
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	81%	50%	0%	0%	0%	0%	100%	100%	100%	92%	44%	0%	0%	0%	0%	0%	0%	100%	99%	51%	
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	8%	56%	0%	0%	0%	0%	0%	100%	0%	1%	49%	
Other	0%	0%	0%	0%	0%	0%	11%	40%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	19%	50%	100%	5%	20%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	100%	100%	0%	0%	0%	0%	85%	40%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
SARAH(4.16KV) - Customers: 770	0.0	0.0	3.0	764.4	1.1	3.0	0.0	0.0	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3rd Party	0%	0%	0%	0%	0%	33%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	10%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	100%	100%	90%	67%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving San Gabriel

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
SAXON(4.16KV) - Customers: 677	0.0	0.0	1.0	90.2	2.6	2.9	78.9	1.1	1.0	118.2	1.0	0.8	0.0	0.0	0.0	10.1	0.0	0.0	0.0	0.0	0.0	128.3	1.0	0.8
3rd Party	0%	0%	0%	44%	38%	100%	95%	94%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	38%	37%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	100%	100%	0%	0%	0%	0%	100%	100%	100%
Operation	0%	0%	0%	17%	25%	0%	5%	6%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	100%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
SEGOVIA(16KV) - Customers: 1,485	160.4	1.8	0.0	190.6	3.0	2.2	44.6	0.1	0.0	0.0	0.0	0.0	1.7	0.0	1.0	100.3	0.8	0.9	39.8	0.1	0.0	141.7	1.0	1.9
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	5%	0%	0%	69%	37%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	100%	100%	100%	0%	99%	98%	47%
Operation	0%	0%	0%	4%	1%	0%	87%	83%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	27%	63%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	1%	2%	0%
Vegetation/Animal	3%	1%	0%	0%	0%	0%	13%	17%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	53%
Weather/Fire/Earthquake	92%	99%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
SUNNYSLOPE(4.16KV) - Customers: 855	0.0	0.0	0.0	122.7	1.8	2.9	7.8	0.1	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	0.0	0.0	0.0	1.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	100%
Equipment Failure	0%	0%	0%	0%	0%	0%	23%	20%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	73%	98%	34%	77%	80%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	27%	2%	66%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
TELSTAR(16KV) - Customers: 2,846	163.0	4.1	1.3	187.8	1.4	4.1	736.7	2.6	1.5	0.0	0.0	0.0	8.8	0.0	2.0	0.6	0.0	0.0	538.6	2.0	1.0	548.0	2.0	3.0
3rd Party	0%	0%	0%	54%	91%	31%	10%	26%	22%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	64%	49%	0%	45%	8%	69%	11%	39%	0%	0%	0%	0%	91%	64%	0%	0%	0%	0%	0%	0%	0%	1%	0%	0%
Operation	0%	0%	0%	2%	1%	0%	1%	8%	0%	0%	0%	0%	9%	36%	0%	0%	0%	0%	100%	100%	0%	98%	99%	0%
Other	7%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	5%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	100%	0%	0%	100%
Weather/Fire/Earthquake	23%	26%	0%	0%	0%	0%	78%	26%	78%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving San Gabriel

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
WILLARD(16KV) - Customers: 2,939	71.4	1.2	0.9	234.6	2.7	0.9	165.6	3.3	4.5	43.9	0.1	0.0	15.3	0.4	1.0	0.4	0.0	0.0	0.2	0.0	2.0	59.7	0.5	3.0
3rd Party	0%	0%	0%	5%	22%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	95%	99%	35%	95%	78%	36%	66%	79%	0%	0%	0%	0%	76%	4%	0%	0%	0%	0%	100%	100%	100%	20%	4%	67%
Operation	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	1%	0%	0%
Other	0%	0%	0%	0%	0%	0%	16%	3%	55%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	73%	14%	0%
Vegetation/Animal	3%	0%	65%	0%	0%	64%	18%	18%	45%	0%	0%	0%	24%	96%	100%	0%	0%	0%	0%	0%	0%	6%	82%	33%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%