



# Circuit Reliability Review

## **Santa Barbara**

---

January 2017

# Providing Safe, Reliable, and Affordable Power

Southern California Edison is modernizing the power grid to meet the changing needs and expectations of our customers and to help California achieve its clean energy goals.

We are investing more than \$12 billion into our power grid between 2015 – 2017 with the goal of increasing power reliability through significant upgrades. These investments include:

- Updating thousands of transmission and distribution poles
- Replacing hundreds of miles of underground cables
- Replacing hundreds of underground structures such as vaults and manholes
- Upgrading critical distribution equipment; capacitor banks, switches, and circuit breakers
- Building new distribution circuits to serve electrical demands in our communities
- Inspecting and replacing overhead conductor and equipment to improve public safety

Our investments in local communities will help ensure that customers receive safe, reliable, and affordable electricity now and in the future.

# Understanding Your Reliability Report

As your electric utility, we want you to always have power when you need it. To get there, we constantly track and monitor electric outages across our service territory, and we measure our “system reliability” from this data.

The two metrics we rely on are common in the electric utility industry: the System Average Interruption Duration Index (SAIDI) and the System Average Interruption Frequency Index (SAIFI). Both are described in more detail on the next page.

Replacing and upgrading our infrastructure will help SCE maintain or improve SAIDI and SAIFI measurements.

This report provides historical reliability data for the circuits that serve your jurisdiction and our proposed infrastructure upgrades for the current year.

To view other reliability reports, visit [sce.com>Outage Center>Maintaining Reliable Service](https://sce.com/Outage-Center/Maintaining-Reliable-Service)

# Reliability Metrics

## MOMENTARY OUTAGES:

OUTAGES LASTING 5 MINUTES OR LESS

### MAIFI:

- The number of times the average customer is interrupted by Momentary outages each year.

## SUSTAINED OUTAGES:

OUTAGES LASTING LONGER THAN 5 MINUTES

### SAIFI:

- The number of times the average customer is interrupted by Sustained outages each year.

### SAIDI:

- The cumulative amount of time the average customer is interrupted by Sustained outages each year.

# Cities in the Santa Barbara District

Carpinteria

Goleta

Isla Vista

Mission Canyon

Montecito

**Santa Barbara**

Summerland

Toro Canyon

# Reliability by SCE District (No Exclusions)

District Name	2012				2013				2014				2015				2016			
	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking
ANTELOPE VALLEY	78.60	28	0.56	31	94.42	22	0.62	31	51.05	35	0.59	34	104.34	22	0.68	30	107.67	24	0.87	29
ARROWHEAD	129.58	13	1.31	7	180.59	7	1.39	8	193.25	5	1.59	5	362.61	4	3.97	1	659.46	3	2.85	5
BARSTOW	184.80	7	1.15	12	204.33	6	1.40	7	201.53	4	1.34	10	187.11	8	1.17	12	134.83	18	1.35	9
BIG CREEK	1184.25	1	4.52	1	176.51	8	3.08	1	920.25	1	1.34	11	422.77	2	3.42	2	1062.01	2	4.99	1
BISHOP	463.09	2	1.25	9	104.44	17	0.51	35	118.79	17	0.59	35	298.11	6	2.22	4	168.59	8	1.22	14
BLYTHE	225.88	6	1.53	3	483.13	1	1.38	9	707.54	2	2.42	2	427.00	1	1.52	7	396.38	5	2.71	6
CATALINA	78.46	30	0.72	29	105.94	16	2.97	2	97.02	24	4.17	1	42.56	35	2.25	3	65.01	35	3.66	3
COVINA	108.73	19	0.92	19	100.51	19	0.86	20	91.60	27	0.87	22	100.08	23	0.81	25	112.13	22	0.97	24
DOMINGUEZ HILLS	117.22	18	0.82	24	89.17	26	0.80	21	82.30	29	0.71	28	130.63	15	0.97	17	146.38	12	1.11	17
FOOTHILL	91.69	25	0.90	20	85.80	27	0.79	24	93.35	25	0.93	21	109.64	20	0.95	20	142.81	14	1.03	21
FULLERTON	68.99	33	0.42	35	90.57	25	0.79	22	82.23	30	0.72	27	76.59	29	0.67	31	92.72	30	0.76	34
HUNTINGTON BEACH	95.78	23	0.89	21	66.51	32	0.68	29	79.61	31	0.78	25	98.32	25	0.95	19	128.02	20	1.26	12
KERNVILLE	226.76	5	1.31	6	232.18	4	1.96	3	178.69	8	1.99	3	286.38	7	0.96	18	2421.32	1	3.67	2
LONG BEACH	75.83	31	0.55	33	75.11	30	0.70	28	66.33	34	0.61	32	164.46	9	0.89	23	135.16	17	0.86	31
MENIFEE	99.32	22	0.84	23	107.39	15	1.26	10	156.68	11	1.32	12	111.46	19	0.98	16	156.75	9	1.31	10
MONROVIA	108.11	20	1.13	15	99.12	20	1.02	16	133.32	14	1.16	16	96.68	26	0.88	24	116.57	21	0.84	32
MONTEBELLO	131.06	12	1.13	14	118.08	13	1.17	12	158.34	10	1.16	15	150.28	12	1.18	11	133.52	19	1.17	15
ONTARIO	93.09	24	0.87	22	77.39	29	0.79	23	97.91	23	1.00	19	94.04	27	0.74	27	105.07	27	0.93	27
PALM SPRINGS	175.92	8	1.27	8	112.80	14	0.77	25	107.04	20	0.71	29	99.54	24	0.80	26	107.58	25	1.07	19
REDLANDS	120.13	16	1.11	16	96.48	21	1.04	15	154.25	12	1.04	18	124.52	17	1.01	14	137.11	16	0.98	23
RIDGECREST	229.65	4	1.44	4	161.95	9	1.12	13	176.84	9	1.57	6	148.90	13	1.01	15	254.31	6	1.05	20
SADDLEBACK	83.01	27	0.73	27	70.69	31	0.53	34	99.07	22	0.74	26	46.03	34	0.39	35	65.99	34	0.65	35
SAN JOAQUIN	135.90	10	1.04	18	244.44	2	1.45	6	138.25	13	1.17	14	127.50	16	1.05	13	108.44	23	1.09	18
SANTA ANA	78.60	29	0.55	32	93.35	24	0.74	26	91.68	26	0.84	23	67.46	32	0.71	29	97.27	29	1.00	22
SANTA BARBARA	153.81	9	1.15	13	82.00	28	0.70	27	183.78	7	1.38	9	152.37	11	1.52	6	156.66	10	1.41	8
SANTA MONICA	101.69	21	0.79	25	122.78	12	1.00	17	110.76	19	0.99	20	75.41	30	0.62	32	91.08	31	0.95	26
SOUTH BAY	122.68	15	1.17	10	142.15	10	1.49	5	125.28	16	1.39	8	164.07	10	1.31	8	183.90	7	1.88	7
TEHACHAPI	117.96	17	1.43	5	232.67	3	1.12	14	130.70	15	1.29	13	298.96	5	1.21	9	97.29	28	1.13	16
THOUSAND OAKS	127.73	14	1.05	17	93.86	23	0.91	18	104.37	21	1.10	17	106.59	21	0.92	21	143.78	13	1.31	11
VALENCIA	62.01	35	0.46	34	51.04	34	0.53	33	79.23	32	0.61	33	72.27	31	0.61	33	105.09	26	0.97	25
VENTURA	134.81	11	1.15	11	100.52	18	1.21	11	183.79	6	1.65	4	148.85	14	1.19	10	150.41	11	1.24	13
VICTORVILLE	67.70	34	0.66	30	61.33	33	0.63	30	68.85	33	0.63	31	87.03	28	0.91	22	79.35	33	0.92	28
WHITTIER	72.60	32	0.74	26	135.04	11	0.86	19	87.60	28	0.70	30	114.52	18	0.73	28	137.34	15	0.81	33
WILDOMAR	88.54	26	0.72	28	40.51	35	0.56	32	118.49	18	0.81	24	52.70	33	0.60	34	84.01	32	0.87	30
YUCCA VALLEY	319.82	3	3.41	2	216.97	5	1.50	4	304.25	3	1.49	7	389.08	3	1.80	5	463.68	4	3.39	4
<b>SCE SystemWide</b>	<b>108.13</b>		<b>0.89</b>		<b>102.61</b>		<b>0.91</b>		<b>112.00</b>		<b>0.96</b>		<b>114.83</b>		<b>0.92</b>		<b>134.48</b>		<b>1.10</b>	

\*\*Exclusions\*\* are days which utilities are allowed to remove from their metrics because the outages on those days were caused by a severe acts of nature.


\*\*In the columns showing "Rank," lower numbers indicate poorer performance.

# Overview of Santa Barbara

## There are 38 circuits that serve Santa Barbara

Circuit Type	Sum of Customers	Circuit Type	Sum of Customers	Circuit Type	Sum of Customers	Circuit Type	Sum of Customers
ALAMAR(4.16KV)	560	PROFESSOR(16KV)	595				
ANACAPA(4.16KV)	61	PUESTA(4.16KV)	1,087				
ANAPAMU(4.16KV)	395	RIVIERA(4.16KV)	476				
ARMOUR(4.16KV)	372	SAN ANDREAS(4.16KV)	1,043				
BATH(4.16KV)	357	SOLA(4.16KV)	627				
BRAEMER(4.16KV)	1,186	STANWOOD(16KV)	1,443				
CASEY(16KV)	783	TURNPIKE(16KV)	3,498				
CASTILLO(4.16KV)	1,123	WESTFALL(4.16KV)	637				
CHAPALA(4.16KV)	101						
CIENIGITAS(16KV)	2,004						
DEL REY(4.16KV)	616						
DRISKILL(16KV)	3,557						
DUFFER(16KV)	3,596						
EMPIRE(16KV)	2,583						
FAIR ACRES(4.16KV)	465						
FELLOWSHIP(4.16KV)	661						
FIGUEROA(4.16KV)	147						
FOX(4.16KV)	979						
GARDEN(4.16KV)	842						
GAUCHO(16KV)	1,587						
GLADIOLA(16KV)	1,829						
GUTIERREZ(4.16KV)	1,059						
HELENA(4.16KV)	998						
HOT SPRINGS(16KV)	3,661						
HURST(16KV)	2,875						
JAMESON(16KV)	2,791						
LA CUMBRE(4.16KV)	241						
LAURO(4.16KV)	608						
MILPAS(16KV)	4,926						
PADRE(16KV)	1,389						
<b>Grand Total</b>	<b>51,758</b>						


# Reliability History of Circuits Serving Santa Barbara (No Exclusions)





# Causes of Repair Outages in Santa Barbara Circuits 2016 YTD


## Contributions to SAIDI by Outage Cause



**SAIDI** = the cumulative amount of time the average customer is interrupted by “sustained” outages each year.


# Causes of Repair Outages in Santa Barbara Circuits 2016 YTD

## Contributions to SAIFI by Outage Cause



- **Equipment Failure**  
e.g., in-service failure of transformer, switch, or conductors
- **Vegetation/Animal**  
e.g., tree branch, rodent, or bird causing a short circuit between conductors
- **Other**  
e.g., patrolled but no cause found
- **Operations**  
e.g., urgent maintenance w/o 3-day notice
- **3rd Party**  
e.g., balloon, car hit pole, dig-in

**SAIFI** = the number of times the average customer is interrupted by “sustained” outages each year.





# Back-up Slides

**Reliability Histories of Circuits Serving Santa Barbara**

**Updated through Year-End 2016**



# Average Reliability of 38 Circuits Serving Santa Barbara

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
<b>Santa Barbara</b>	<b>62.0</b>	<b>0.5</b>	<b>1.1</b>	<b>174.0</b>	<b>1.5</b>	<b>2.4</b>	<b>140.4</b>	<b>1.7</b>	<b>1.8</b>	<b>56.9</b>	<b>0.3</b>	<b>0.4</b>	<b>49.3</b>	<b>0.7</b>	<b>0.3</b>	<b>15.3</b>	<b>0.1</b>	<b>0.5</b>	<b>41.1</b>	<b>0.5</b>	<b>0.4</b>	<b>162.6</b>	<b>1.7</b>	<b>1.6</b>
3rd Party	1%	1%	4%	3%	2%	7%	4%	5%	3%	15%	19%	1%	0%	0%	0%	0%	0%	6%	0%	0%	8%	5%	4%	4%
Equipment Failure	68%	62%	44%	61%	61%	38%	56%	34%	48%	36%	19%	4%	45%	20%	71%	57%	65%	7%	36%	35%	46%	40%	27%	29%
Operation	7%	7%	5%	12%	11%	2%	13%	14%	7%	4%	9%	0%	10%	7%	3%	17%	15%	3%	10%	43%	0%	9%	19%	2%
Other	11%	11%	22%	3%	3%	36%	4%	2%	10%	7%	2%	38%	3%	1%	2%	12%	11%	7%	45%	16%	8%	16%	6%	13%
Vegetation/Animal	5%	4%	6%	1%	1%	11%	6%	24%	5%	0%	0%	0%	19%	54%	0%	13%	8%	76%	0%	0%	0%	7%	24%	26%
Weather/Fire/Earthquake	8%	15%	18%	20%	23%	5%	18%	21%	27%	38%	52%	57%	23%	19%	24%	1%	1%	0%	9%	6%	38%	23%	20%	26%
<b>SCE Systemwide</b>	<b>102.6</b>	<b>0.9</b>	<b>1.2</b>	<b>112.0</b>	<b>1.0</b>	<b>1.4</b>	<b>114.8</b>	<b>0.9</b>	<b>1.4</b>	<b>40.5</b>	<b>0.3</b>	<b>0.4</b>	<b>34.8</b>	<b>0.3</b>	<b>0.4</b>	<b>29.4</b>	<b>0.2</b>	<b>0.3</b>	<b>29.8</b>	<b>0.3</b>	<b>0.4</b>	<b>134.5</b>	<b>1.1</b>	<b>1.6</b>

## Notes:

No outages are excluded from the metrics.

## Outage Causes:

Other: e.g., patrolled but no cause could be found

Operations: e.g., urgent maintenance w/o 3-day notice to customers

3<sup>rd</sup> Party: e.g., balloons, car hit pole, dig-in

Vegetation/Animal: e.g., tree branch, rodent, or bird causing short circuit across conductors

SAIDI (minutes) = the cumulative amount of time the average customer is interrupted by "sustained" (longer than 5 minutes) outages.

SAIFI (interruptions) = the number of times the average customer is interrupted by "sustained" outages.

MAIFI (interruptions) = the number of times the average customer is interrupted by "momentary" (lasting 5 minutes or less) outages.

# Reliability Histories for Individual Circuits Serving Santa Barbara

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
<b>ALAMAR(4.16KV) - Customers: 560</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>60.8</b>	<b>0.2</b>	<b>1.0</b>	<b>34.3</b>	<b>2.9</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>10.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>10.0</b>	<b>1.0</b>	<b>1.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	100%	100%	100%	32%	34%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	39%	33%	0%	0%	0%	0%	100%	100%	0%	0%	0%	100%	0%	0%	0%	100%	100%	100%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	29%	34%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>ANACAPA(4.16KV) - Customers: 61</b>	<b>0.0</b>	<b>0.0</b>	<b>2.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>398.0</b>	<b>2.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
3rd Party	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	50%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	50%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>ANAPAMU(4.16KV) - Customers: 395</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>245.8</b>	<b>2.2</b>	<b>0.0</b>	<b>34.5</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>10.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>1.0</b>	<b>82.2</b>	<b>1.0</b>	<b>0.0</b>	<b>92.3</b>	<b>2.0</b>	<b>1.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	93%	89%	0%	31%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	7%	11%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	89%	50%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	40%	33%	0%	0%	0%	0%	100%	100%	0%	0%	0%	100%	0%	0%	0%	11%	50%	100%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	29%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>ARMOUR(4.16KV) - Customers: 372</b>	<b>6.7</b>	<b>0.0</b>	<b>0.0</b>	<b>242.9</b>	<b>2.1</b>	<b>1.0</b>	<b>132.9</b>	<b>3.3</b>	<b>7.0</b>	<b>360.1</b>	<b>1.2</b>	<b>7.1</b>	<b>325.3</b>	<b>1.7</b>	<b>1.0</b>	<b>83.5</b>	<b>1.0</b>	<b>0.0</b>	<b>339.5</b>	<b>1.3</b>	<b>0.0</b>	<b>1108.3</b>	<b>5.2</b>	<b>8.1</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	61%	48%	100%	0%	0%	0%	100%	100%	30%	0%	0%	0%	0%	0%	0%	0%	0%	0%	32%	24%	27%
Operation	0%	0%	0%	39%	52%	0%	66%	70%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	2%	9%	0%	1%	2%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	100%	100%	100%	0%	98%	91%	0%	37%	41%	12%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	100%	100%	0%	0%	0%	0%	34%	30%	0%	0%	0%	70%	100%	100%	0%	0%	0%	0%	0%	0%	0%	29%	32%	61%

# Reliability Histories for Individual Circuits Serving Santa Barbara

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
<b>BATH(4.16KV) - Customers: 357</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>2.0</b>	<b>58.2</b>	<b>1.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>14.4</b>	<b>1.0</b>	<b>0.0</b>	<b>14.4</b>	<b>1.0</b>	<b>0.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	100%	100%	0%
Other	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>BRAEMER(4.16KV) - Customers: 1,186</b>	<b>0.7</b>	<b>0.0</b>	<b>4.0</b>	<b>79.6</b>	<b>1.0</b>	<b>11.0</b>	<b>4.7</b>	<b>0.0</b>	<b>6.0</b>	<b>124.6</b>	<b>1.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>7.9</b>	<b>0.0</b>	<b>1.0</b>	<b>132.6</b>	<b>1.0</b>	<b>2.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	94%	99%	0%
Equipment Failure	100%	100%	75%	100%	100%	18%	0%	0%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	6%	1%	0%
Operation	0%	0%	0%	0%	0%	0%	86%	96%	17%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	73%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	25%	0%	0%	9%	14%	4%	50%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	100%
<b>CASEY(16KV) - Customers: 783</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>366.5</b>	<b>1.5</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>66.6</b>	<b>1.1</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>66.6</b>	<b>1.1</b>	<b>1.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	39%	11%	0%	0%	0%	0%	47%	5%	0%	0%	0%	0%	0%	0%	0%	47%	5%	0%
Operation	0%	0%	0%	0%	0%	0%	2%	8%	0%	0%	0%	0%	2%	1%	0%	0%	0%	0%	0%	0%	0%	2%	1%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	60%	81%	0%	0%	0%	0%	51%	94%	0%	0%	0%	100%	0%	0%	0%	51%	94%	100%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>CASTILLO(4.16KV) - Customers: 1,123</b>	<b>0.6</b>	<b>0.0</b>	<b>0.0</b>	<b>14.5</b>	<b>0.2</b>	<b>0.0</b>	<b>34.9</b>	<b>3.0</b>	<b>0.0</b>	<b>2.6</b>	<b>0.0</b>	<b>0.0</b>	<b>10.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>2.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>12.6</b>	<b>1.0</b>	<b>2.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	31%	33%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	20%	1%	0%
Operation	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	50%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	40%	33%	0%	0%	0%	0%	100%	100%	0%	0%	0%	50%	0%	0%	0%	80%	99%	50%
Weather/Fire/Earthquake	0%	0%	0%	100%	100%	0%	29%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%



# Reliability Histories for Individual Circuits Serving Santa Barbara

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
<b>CHAPALA(4.16KV) - Customers: 101</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>213.7</b>	<b>0.2</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>5.9</b>	<b>1.0</b>	<b>0.0</b>	<b>5.9</b>	<b>1.0</b>	<b>0.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	100%	100%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>CIENIGITAS(16KV) - Customers: 2,004</b>	<b>5.7</b>	<b>0.0</b>	<b>1.0</b>	<b>103.2</b>	<b>1.6</b>	<b>2.0</b>	<b>3.6</b>	<b>0.0</b>	<b>0.0</b>	<b>8.2</b>	<b>0.0</b>	<b>0.3</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>14.2</b>	<b>1.0</b>	<b>0.0</b>	<b>22.4</b>	<b>1.0</b>	<b>0.3</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	100%	100%	0%	80%	99%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	100%	20%	1%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	63%	98%	0%
Other	0%	0%	0%	0%	0%	50%	0%	0%	0%	100%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	37%	2%	100%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>DEL REY(4.16KV) - Customers: 616</b>	<b>0.0</b>	<b>0.0</b>	<b>4.0</b>	<b>82.0</b>	<b>1.0</b>	<b>10.0</b>	<b>123.1</b>	<b>1.0</b>	<b>7.0</b>	<b>0.0</b>	<b>0.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.6</b>	<b>0.0</b>	<b>1.0</b>	<b>0.6</b>	<b>0.0</b>	<b>2.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	75%	91%	99%	20%	0%	0%	29%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	9%	1%	0%	4%	2%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	100%	100%	0%	100%	100%	0%
Other	0%	0%	0%	0%	0%	70%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	25%	0%	0%	10%	96%	98%	71%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	100%
<b>DRISKILL(16KV) - Customers: 3,557</b>	<b>99.7</b>	<b>0.7</b>	<b>1.3</b>	<b>17.6</b>	<b>0.1</b>	<b>0.0</b>	<b>61.0</b>	<b>1.1</b>	<b>0.6</b>	<b>81.6</b>	<b>0.9</b>	<b>0.2</b>	<b>324.3</b>	<b>3.9</b>	<b>3.4</b>	<b>45.4</b>	<b>0.3</b>	<b>2.1</b>	<b>53.8</b>	<b>0.1</b>	<b>0.5</b>	<b>505.2</b>	<b>5.2</b>	<b>6.2</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	30%	10%	94%	43%	28%	0%	69%	9%	100%	0%	0%	0%	74%	50%	97%	9%	12%	28%	16%	61%	100%	50%	40%	71%
Operation	38%	52%	0%	39%	44%	0%	6%	4%	0%	0%	0%	0%	0%	0%	0%	26%	36%	0%	0%	0%	0%	2%	2%	0%
Other	0%	0%	0%	1%	11%	0%	0%	0%	0%	0%	0%	0%	5%	1%	0%	0%	0%	0%	84%	39%	0%	12%	1%	0%
Vegetation/Animal	33%	38%	0%	7%	15%	0%	25%	88%	0%	0%	0%	0%	4%	26%	0%	65%	52%	72%	0%	0%	0%	9%	22%	24%
Weather/Fire/Earthquake	0%	0%	6%	10%	3%	0%	0%	0%	0%	100%	100%	100%	17%	24%	3%	0%	0%	0%	0%	0%	0%	27%	35%	5%

# Reliability Histories for Individual Circuits Serving Santa Barbara

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
<b>DUFFER(16KV) - Customers: 3,596</b>	<b>31.8</b>	<b>0.5</b>	<b>1.5</b>	<b>309.2</b>	<b>4.6</b>	<b>3.9</b>	<b>397.5</b>	<b>3.9</b>	<b>2.6</b>	<b>1.4</b>	<b>0.0</b>	<b>0.0</b>	<b>107.6</b>	<b>1.0</b>	<b>0.0</b>	<b>37.7</b>	<b>1.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>146.7</b>	<b>2.1</b>	<b>1.0</b>
3rd Party	0%	0%	0%	0%	0%	26%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	16%	1%	0%	68%	63%	48%	90%	45%	58%	0%	0%	0%	20%	2%	0%	91%	99%	0%	0%	0%	0%	38%	49%	0%
Operation	0%	0%	0%	15%	16%	1%	0%	1%	0%	100%	100%	0%	4%	3%	0%	9%	1%	0%	0%	0%	0%	6%	3%	0%
Other	69%	97%	36%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	15%	1%	64%	0%	0%	26%	3%	26%	0%	0%	0%	0%	76%	95%	0%	0%	0%	100%	0%	0%	0%	56%	48%	100%
Weather/Fire/Earthquake	0%	0%	0%	17%	22%	0%	7%	28%	42%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>EMPIRE(16KV) - Customers: 2,583</b>	<b>61.0</b>	<b>0.3</b>	<b>3.5</b>	<b>15.3</b>	<b>0.0</b>	<b>1.0</b>	<b>28.6</b>	<b>1.1</b>	<b>2.0</b>	<b>3.1</b>	<b>0.0</b>	<b>0.0</b>	<b>8.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.0</b>	<b>1.0</b>	<b>354.7</b>	<b>1.9</b>	<b>1.1</b>	<b>365.9</b>	<b>2.9</b>	<b>2.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	100%	97%	44%	80%	76%	0%	54%	5%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	32%	38%	100%	31%	25%	52%
Operation	0%	3%	0%	20%	24%	0%	7%	1%	0%	100%	100%	0%	0%	0%	0%	100%	100%	0%	2%	11%	0%	3%	8%	0%
Other	0%	0%	56%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	66%	51%	0%	64%	34%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	38%	93%	0%	0%	0%	0%	100%	100%	0%	0%	0%	100%	0%	0%	0%	2%	34%	48%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>FAIR ACRES(4.16KV) - Customers: 465</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>1.5</b>	<b>0.2</b>	<b>0.8</b>	<b>244.5</b>	<b>2.0</b>	<b>0.0</b>	<b>42.7</b>	<b>0.4</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>147.2</b>	<b>0.8</b>	<b>0.0</b>	<b>18.1</b>	<b>0.1</b>	<b>0.0</b>	<b>208.0</b>	<b>1.3</b>	<b>0.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	39%	23%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	100%	100%	100%	22%	17%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	29%	39%	0%
Other	0%	0%	0%	0%	0%	0%	23%	40%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	71%	61%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	16%	21%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>FELLOWSHIP(4.16KV) - Customers: 661</b>	<b>76.0</b>	<b>0.6</b>	<b>4.0</b>	<b>73.0</b>	<b>1.0</b>	<b>11.0</b>	<b>130.5</b>	<b>1.2</b>	<b>5.0</b>	<b>227.2</b>	<b>1.6</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>6.7</b>	<b>0.1</b>	<b>0.0</b>	<b>266.4</b>	<b>1.9</b>	<b>1.0</b>	<b>500.3</b>	<b>3.5</b>	<b>2.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	87%	94%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	40%	42%	0%
Equipment Failure	9%	2%	75%	100%	100%	18%	0%	0%	40%	0%	0%	0%	0%	0%	0%	0%	0%	0%	72%	46%	0%	38%	24%	0%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	1%	3%	0%
Other	91%	98%	0%	0%	0%	64%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	25%	0%	0%	18%	100%	100%	60%	13%	6%	100%	0%	0%	0%	0%	0%	0%	28%	54%	100%	21%	31%	100%

# Reliability Histories for Individual Circuits Serving Santa Barbara

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
<b>FIGUEROA(4.16KV) - Customers: 147</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>FOX(4.16KV) - Customers: 979</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>154.9</b>	<b>1.1</b>	<b>1.0</b>	<b>226.5</b>	<b>4.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>10.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>2.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>10.0</b>	<b>1.0</b>	<b>2.0</b>
3rd Party	0%	0%	0%	90%	91%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	1%	1%	0%	89%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	9%	8%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	50%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	6%	25%	0%	0%	0%	0%	100%	100%	0%	0%	0%	50%	0%	0%	0%	100%	100%	50%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	100%	4%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>GARDEN(4.16KV) - Customers: 842</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>2.8</b>	<b>0.0</b>	<b>0.0</b>	<b>1057.4</b>	<b>2.1</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	96%	95%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	4%	5%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>GAUCHO(16KV) - Customers: 1,587</b>	<b>2.1</b>	<b>0.0</b>	<b>2.0</b>	<b>238.6</b>	<b>1.7</b>	<b>1.0</b>	<b>95.5</b>	<b>1.3</b>	<b>5.2</b>	<b>4.8</b>	<b>0.0</b>	<b>2.0</b>	<b>2.2</b>	<b>0.0</b>	<b>0.0</b>	<b>10.1</b>	<b>0.0</b>	<b>1.6</b>	<b>0.0</b>	<b>0.0</b>	<b>2.0</b>	<b>17.2</b>	<b>0.0</b>	<b>5.6</b>
3rd Party	0%	0%	0%	13%	4%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	63%	0%	0%	50%	0%	0%	36%
Equipment Failure	100%	100%	0%	0%	0%	0%	86%	95%	81%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	14%	5%	0%	0%	0%	0%	100%	100%	0%	100%	100%	37%	0%	0%	0%	72%	95%	11%
Other	0%	0%	100%	0%	0%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	50%	28%	5%	54%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	19%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	87%	96%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

# Reliability Histories for Individual Circuits Serving Santa Barbara

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
<b>GLADIOLA(16KV) - Customers: 1,829</b>	<b>69.6</b>	<b>0.2</b>	<b>0.0</b>	<b>72.0</b>	<b>0.4</b>	<b>1.0</b>	<b>257.4</b>	<b>1.9</b>	<b>1.1</b>	<b>114.0</b>	<b>0.9</b>	<b>0.1</b>	<b>86.7</b>	<b>0.6</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>200.6</b>	<b>1.4</b>	<b>0.1</b>
3rd Party	0%	0%	0%	0%	0%	0%	7%	54%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	94%	84%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	6%	16%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	43%	39%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	88%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	93%	46%	12%	100%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	57%	61%	100%
<b>GUTIERREZ(4.16KV) - Customers: 1,059</b>	<b>38.8</b>	<b>0.1</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>2.0</b>	<b>199.1</b>	<b>2.1</b>	<b>0.0</b>	<b>153.3</b>	<b>1.0</b>	<b>2.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>3.6</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>156.9</b>	<b>1.0</b>	<b>2.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	58%	48%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	98%	98%	0%
Equipment Failure	98%	75%	100%	0%	0%	50%	2%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	2%	25%	0%	0%	0%	0%	39%	49%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	2%	2%	0%
Other	0%	0%	0%	0%	0%	50%	2%	2%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>HELENA(4.16KV) - Customers: 998</b>	<b>11.3</b>	<b>0.2</b>	<b>1.9</b>	<b>492.9</b>	<b>2.7</b>	<b>1.8</b>	<b>123.2</b>	<b>0.2</b>	<b>0.0</b>	<b>3.3</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>37.0</b>	<b>0.1</b>	<b>0.0</b>	<b>40.3</b>	<b>0.1</b>	<b>0.0</b>
3rd Party	100%	100%	48%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	24%	20%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	8%	15%	0%
Operation	0%	0%	0%	2%	14%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	52%	21%	22%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	53%	43%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	92%	85%	0%
<b>HOT SPRINGS(16KV) - Customers: 3,661</b>	<b>347.9</b>	<b>2.3</b>	<b>1.6</b>	<b>214.8</b>	<b>3.0</b>	<b>4.7</b>	<b>131.8</b>	<b>2.5</b>	<b>5.4</b>	<b>79.4</b>	<b>1.1</b>	<b>1.1</b>	<b>8.7</b>	<b>0.2</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>88.1</b>	<b>1.4</b>	<b>2.1</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	96%	96%	40%	54%	48%	54%	46%	37%	56%	3%	3%	0%	3%	1%	0%	0%	0%	0%	0%	0%	0%	3%	3%	0%
Operation	2%	2%	0%	8%	1%	12%	52%	62%	26%	28%	29%	0%	97%	99%	0%	100%	100%	0%	0%	0%	0%	35%	42%	0%
Other	0%	0%	0%	0%	0%	21%	2%	1%	18%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	2%	2%	0%	4%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	60%	34%	49%	12%	0%	0%	0%	69%	68%	100%	0%	0%	100%	0%	0%	0%	0%	0%	0%	62%	56%	100%

# Reliability Histories for Individual Circuits Serving Santa Barbara

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
<b>HURST(16KV) - Customers: 2,875</b>	<b>53.1</b>	<b>0.1</b>	<b>1.4</b>	<b>256.9</b>	<b>1.3</b>	<b>1.2</b>	<b>122.9</b>	<b>2.1</b>	<b>1.9</b>	<b>184.0</b>	<b>0.3</b>	<b>0.2</b>	<b>16.2</b>	<b>1.2</b>	<b>0.1</b>	<b>11.0</b>	<b>0.1</b>	<b>1.0</b>	<b>6.2</b>	<b>0.1</b>	<b>0.0</b>	<b>217.6</b>	<b>1.6</b>	<b>1.4</b>
3rd Party	0%	0%	0%	4%	1%	81%	12%	3%	10%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	55%	62%	100%	66%	18%	0%	48%	25%	61%	42%	46%	0%	26%	1%	0%	0%	0%	0%	99%	98%	0%	40%	13%	0%
Operation	13%	8%	0%	0%	1%	0%	1%	6%	0%	0%	0%	0%	31%	14%	100%	80%	39%	0%	1%	2%	0%	6%	11%	10%
Other	29%	23%	0%	2%	5%	8%	16%	9%	9%	1%	3%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	1%	17%
Vegetation/Animal	3%	6%	0%	0%	0%	10%	22%	56%	17%	0%	0%	0%	43%	86%	0%	0%	0%	100%	0%	0%	0%	3%	62%	73%
Weather/Fire/Earthquake	0%	0%	0%	28%	74%	0%	0%	0%	3%	57%	51%	0%	0%	0%	0%	20%	61%	0%	0%	0%	0%	49%	13%	0%
<b>JAMESON(16KV) - Customers: 2,791</b>	<b>169.8</b>	<b>2.3</b>	<b>1.7</b>	<b>174.7</b>	<b>1.7</b>	<b>3.1</b>	<b>100.5</b>	<b>0.6</b>	<b>3.9</b>	<b>0.0</b>	<b>0.0</b>	<b>0.4</b>	<b>0.2</b>	<b>0.0</b>	<b>0.0</b>	<b>58.6</b>	<b>0.1</b>	<b>0.0</b>	<b>1.4</b>	<b>0.0</b>	<b>1.0</b>	<b>60.2</b>	<b>0.2</b>	<b>1.3</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	55%	52%	57%	43%	57%	32%	26%	9%	50%	0%	0%	0%	100%	100%	0%	86%	61%	0%	0%	0%	0%	84%	57%	0%
Operation	3%	1%	0%	1%	1%	0%	70%	36%	0%	0%	0%	0%	0%	0%	0%	14%	39%	0%	0%	0%	0%	13%	36%	0%
Other	0%	0%	0%	13%	21%	68%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	42%	47%	43%	44%	21%	0%	4%	55%	50%	0%	0%	100%	0%	0%	0%	0%	0%	0%	100%	100%	100%	2%	7%	100%
<b>LA CUMBRE(4.16KV) - Customers: 241</b>	<b>20.1</b>	<b>0.1</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>1.0</b>	<b>136.2</b>	<b>0.5</b>	<b>1.7</b>	<b>72.0</b>	<b>1.1</b>	<b>1.0</b>	<b>35.0</b>	<b>2.0</b>	<b>0.0</b>	<b>12.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>119.0</b>	<b>3.1</b>	<b>1.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	100%	100%	0%	0%	0%	0%	7%	3%	0%	41%	9%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	35%	4%	0%
Operation	0%	0%	0%	0%	0%	100%	12%	12%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	43%	50%	0%	0%	0%	0%	0%	0%	0%	13%	32%	0%
Weather/Fire/Earthquake	0%	0%	100%	0%	0%	0%	80%	85%	100%	59%	91%	0%	57%	50%	0%	0%	0%	0%	0%	0%	0%	52%	64%	0%
<b>LAURO(4.16KV) - Customers: 608</b>	<b>21.1</b>	<b>0.7</b>	<b>0.0</b>	<b>130.1</b>	<b>0.4</b>	<b>0.0</b>	<b>286.4</b>	<b>4.0</b>	<b>0.9</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>10.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>10.0</b>	<b>1.0</b>	<b>1.0</b>
3rd Party	0%	0%	0%	65%	87%	0%	23%	11%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	4%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	18%	47%	0%	29%	10%	0%	17%	2%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	82%	53%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	5%	25%	0%	0%	0%	0%	100%	100%	0%	0%	0%	100%	0%	0%	0%	100%	100%	100%
Weather/Fire/Earthquake	0%	0%	0%	6%	3%	0%	51%	37%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

# Reliability Histories for Individual Circuits Serving Santa Barbara

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
<b>MILPAS(16KV) - Customers: 4,926</b>	<b>22.6</b>	<b>0.1</b>	<b>0.0</b>	<b>460.2</b>	<b>2.9</b>	<b>4.1</b>	<b>29.7</b>	<b>0.2</b>	<b>0.0</b>	<b>54.8</b>	<b>0.3</b>	<b>0.0</b>	<b>49.5</b>	<b>0.1</b>	<b>0.0</b>	<b>0.8</b>	<b>0.0</b>	<b>0.0</b>	<b>46.4</b>	<b>2.3</b>	<b>1.3</b>	<b>151.5</b>	<b>2.7</b>	<b>1.4</b>
3rd Party	0%	0%	0%	0%	0%	0%	15%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	96%	95%	52%	0%	0%	0%	72%	74%	0%	52%	38%	0%	0%	0%	0%	48%	44%	66%	58%	47%	66%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	13%	33%	100%	100%	100%	0%	52%	56%	0%	21%	49%	1%
Other	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	4%	5%	48%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	85%	67%	0%	28%	26%	0%	35%	29%	0%	0%	0%	0%	0%	0%	34%	22%	4%	34%
<b>PADRE(16KV) - Customers: 1,389</b>	<b>61.9</b>	<b>2.0</b>	<b>0.0</b>	<b>413.0</b>	<b>4.2</b>	<b>1.0</b>	<b>414.9</b>	<b>3.5</b>	<b>2.4</b>	<b>11.1</b>	<b>0.1</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>138.5</b>	<b>2.0</b>	<b>0.0</b>	<b>149.6</b>	<b>2.1</b>	<b>0.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	100%	100%	0%	99%	100%	100%	69%	71%	38%	47%	54%	0%	0%	0%	0%	0%	0%	0%	90%	50%	0%	87%	50%	0%
Operation	0%	0%	0%	1%	0%	0%	2%	1%	0%	53%	46%	0%	0%	0%	0%	0%	0%	0%	10%	50%	0%	13%	50%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	30%	28%	62%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>PROFESSOR(16KV) - Customers: 595</b>	<b>25.4</b>	<b>0.8</b>	<b>0.2</b>	<b>591.4</b>	<b>0.7</b>	<b>1.9</b>	<b>17.2</b>	<b>1.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>3.4</b>	<b>0.0</b>	<b>0.0</b>	<b>3.4</b>	<b>0.0</b>	<b>0.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	82%	99%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	49%	98%	100%	0%	0%	49%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	100%	100%	0%
Operation	47%	2%	0%	100%	100%	0%	18%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	4%	0%	0%	0%	0%	51%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>PUESTA(4.16KV) - Customers: 1,087</b>	<b>3.3</b>	<b>0.0</b>	<b>0.0</b>	<b>33.0</b>	<b>0.3</b>	<b>0.8</b>	<b>127.7</b>	<b>3.3</b>	<b>0.0</b>	<b>20.7</b>	<b>0.1</b>	<b>0.0</b>	<b>10.0</b>	<b>1.0</b>	<b>0.0</b>	<b>150.4</b>	<b>0.2</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>181.0</b>	<b>1.3</b>	<b>1.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	100%	100%	0%	0%	0%	0%	17%	31%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	83%	19%	0%
Operation	0%	0%	0%	74%	30%	20%	22%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	26%	70%	80%	41%	6%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	11%	30%	0%	0%	0%	0%	100%	100%	0%	0%	0%	100%	0%	0%	0%	6%	76%	100%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	8%	30%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	11%	6%	0%

# Reliability Histories for Individual Circuits Serving Santa Barbara

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
<b>RIVIERA(4.16KV) - Customers: 476</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>57.7</b>	<b>1.0</b>	<b>0.0</b>	<b>0.8</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>14.0</b>	<b>1.0</b>	<b>0.0</b>	<b>14.0</b>	<b>1.0</b>	<b>0.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	100%	100%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>SAN ANDREAS(4.16KV) - Customers: 1,043</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>55.4</b>	<b>4.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>10.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>10.0</b>	<b>1.0</b>	<b>1.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	67%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	20%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	37%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	25%	25%	0%	0%	0%	0%	100%	100%	0%	0%	0%	100%	0%	0%	0%	100%	100%	100%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	18%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>SOLA(4.16KV) - Customers: 627</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>120.5</b>	<b>4.0</b>	<b>0.0</b>	<b>747.3</b>	<b>1.6</b>	<b>0.0</b>	<b>10.1</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>757.4</b>	<b>2.6</b>	<b>1.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	80%	50%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	99%	61%	0%
Operation	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	12%	25%	0%	0%	0%	0%	100%	100%	0%	0%	0%	100%	0%	0%	0%	1%	39%	100%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	8%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>STANWOOD(16KV) - Customers: 1,443</b>	<b>104.8</b>	<b>0.8</b>	<b>4.2</b>	<b>301.0</b>	<b>1.9</b>	<b>4.0</b>	<b>172.5</b>	<b>2.2</b>	<b>0.9</b>	<b>20.6</b>	<b>0.1</b>	<b>0.2</b>	<b>145.1</b>	<b>2.1</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>23.1</b>	<b>0.1</b>	<b>0.0</b>	<b>188.8</b>	<b>2.2</b>	<b>0.3</b>
3rd Party	9%	2%	24%	0%	0%	0%	1%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	45%
Equipment Failure	8%	3%	0%	14%	52%	25%	67%	43%	33%	41%	40%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	4%	1%	0%
Operation	11%	7%	17%	2%	1%	0%	10%	52%	0%	1%	12%	0%	0%	0%	0%	0%	0%	0%	17%	27%	0%	2%	2%	0%
Other	35%	9%	26%	7%	4%	75%	12%	3%	27%	58%	48%	50%	8%	4%	0%	0%	0%	0%	83%	73%	0%	23%	9%	45%
Vegetation/Animal	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	36%	78%	33%	77%	44%	0%	10%	3%	40%	0%	0%	0%	92%	96%	100%	0%	0%	0%	0%	0%	0%	71%	88%	11%

# Reliability Histories for Individual Circuits Serving Santa Barbara

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
<b>TURNPIKE(16KV) - Customers: 3,498</b>	<b>16.5</b>	<b>0.0</b>	<b>0.0</b>	<b>78.5</b>	<b>1.1</b>	<b>2.2</b>	<b>0.8</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>11.2</b>	<b>0.0</b>	<b>0.0</b>	<b>0.6</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>11.9</b>	<b>0.1</b>	<b>0.0</b>
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	85%	51%	0%	14%	16%	54%	71%	19%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	95%	50%	0%
Operation	0%	0%	0%	86%	84%	0%	29%	81%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	5%	50%	0%
Other	0%	0%	0%	0%	0%	46%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	15%	49%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
<b>WESTFALL(4.16KV) - Customers: 637</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>14.0</b>	<b>1.0</b>	<b>1.0</b>	<b>153.7</b>	<b>2.9</b>	<b>2.0</b>	<b>239.3</b>	<b>0.4</b>	<b>0.0</b>	<b>7.0</b>	<b>1.0</b>	<b>0.0</b>	<b>0.2</b>	<b>0.0</b>	<b>0.0</b>	<b>213.7</b>	<b>2.1</b>	<b>0.0</b>	<b>460.2</b>	<b>3.5</b>	<b>0.0</b>
3rd Party	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	50%	3%	8%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	1%	0%
Operation	0%	0%	0%	0%	0%	0%	13%	6%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	50%	6%	0%	97%	92%	0%	0%	0%	0%	0%	0%	0%	21%	48%	0%	60%	39%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	7%	34%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	2%	29%	0%
Weather/Fire/Earthquake	0%	0%	0%	100%	100%	0%	31%	54%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	79%	52%	0%	37%	32%	0%