



Circuit Reliability Review

Fresno District 5

January 2017

Providing Safe, Reliable, and Affordable Power

Southern California Edison is modernizing the power grid to meet the changing needs and expectations of our customers and to help California achieve its clean energy goals.

We are investing more than \$12 billion into our power grid between 2015 – 2017 with the goal of increasing power reliability through significant upgrades. These investments include:

- Updating thousands of transmission and distribution poles
- Replacing hundreds of miles of underground cables
- Replacing hundreds of underground structures such as vaults and manholes
- Upgrading critical distribution equipment; capacitor banks, switches, and circuit breakers
- Building new distribution circuits to serve electrical demands in our communities
- Inspecting and replacing overhead conductor and equipment to improve public safety

Our investments in local communities will help ensure that customers receive safe, reliable, and affordable electricity now and in the future.

Understanding Your Reliability Report

As your electric utility, we want you to always have power when you need it. To get there, we constantly track and monitor electric outages across our service territory, and we measure our “system reliability” from this data.

The two metrics we rely on are common in the electric utility industry: the System Average Interruption Duration Index (SAIDI) and the System Average Interruption Frequency Index (SAIFI). Both are described in more detail on the next page.

Replacing and upgrading our infrastructure will help SCE maintain or improve SAIDI and SAIFI measurements.

This report provides historical reliability data for the circuits that serve your jurisdiction and our proposed infrastructure upgrades for the current year.

To view other reliability reports, visit [sce.com>Outage Center>Maintaining Reliable Service](https://sce.com/Outage-Center/Maintaining-Reliable-Service)

Reliability Metrics

MOMENTARY OUTAGES:

OUTAGES LASTING 5 MINUTES OR LESS

MAIFI:

- The number of times the average customer is interrupted by Momentary outages each year.

SUSTAINED OUTAGES:

OUTAGES LASTING LONGER THAN 5 MINUTES

SAIFI:

- The number of times the average customer is interrupted by Sustained outages each year.

SAIDI:

- The cumulative amount of time the average customer is interrupted by Sustained outages each year.

Cities and Communities in the Shaver Lake District

Fresno County

Shaver Lake

Big Creek

Huntington Lake

Dinkey Creek

Mammoth Pool

Tamarack Ridge

Redinger Lake

Reliability by SCE District (No Exclusions)

District Name	2012				2013				2014				2015				2016			
	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking
ANTELOPE VALLEY	78.60	28	0.56	31	94.42	22	0.62	31	51.05	35	0.59	34	104.34	22	0.68	30	107.67	24	0.87	29
ARROWHEAD	129.58	13	1.31	7	180.59	7	1.39	8	193.25	5	1.59	5	362.61	4	3.97	1	659.46	3	2.85	5
BARSTOW	184.80	7	1.15	12	204.33	6	1.40	7	201.53	4	1.34	10	187.11	8	1.17	12	134.83	18	1.35	9
BIG CREEK	1184.25	1	4.52	1	176.51	8	3.08	1	920.25	1	1.34	11	422.77	2	3.42	2	1062.01	2	4.99	1
BISHOP	463.09	2	1.25	9	104.44	17	0.51	35	118.79	17	0.59	35	298.11	6	2.22	4	168.59	8	1.22	14
BLYTHE	225.88	6	1.53	3	483.13	1	1.38	9	707.54	2	2.42	2	427.00	1	1.52	7	396.38	5	2.71	6
CATALINA	78.46	30	0.72	29	105.94	16	2.97	2	97.02	24	4.17	1	42.56	35	2.25	3	65.01	35	3.66	3
COVINA	108.73	19	0.92	19	100.51	19	0.86	20	91.60	27	0.87	22	100.08	23	0.81	25	112.13	22	0.97	24
DOMINGUEZ HILLS	117.22	18	0.82	24	89.17	26	0.80	21	82.30	29	0.71	28	130.63	15	0.97	17	146.38	12	1.11	17
FOOTHILL	91.69	25	0.90	20	85.80	27	0.79	24	93.35	25	0.93	21	109.64	20	0.95	20	142.81	14	1.03	21
FULLERTON	68.99	33	0.42	35	90.57	25	0.79	22	82.23	30	0.72	27	76.59	29	0.67	31	92.72	30	0.76	34
HUNTINGTON BEACH	95.78	23	0.89	21	66.51	32	0.68	29	79.61	31	0.78	25	98.32	25	0.95	19	128.02	20	1.26	12
KERNVILLE	226.76	5	1.31	6	232.18	4	1.96	3	178.69	8	1.99	3	286.38	7	0.96	18	2421.32	1	3.67	2
LONG BEACH	75.83	31	0.55	33	75.11	30	0.70	28	66.33	34	0.61	32	164.46	9	0.89	23	135.16	17	0.86	31
MENIFEE	99.32	22	0.84	23	107.39	15	1.26	10	156.68	11	1.32	12	111.46	19	0.98	16	156.75	9	1.31	10
MONROVIA	108.11	20	1.13	15	99.12	20	1.02	16	133.32	14	1.16	16	96.68	26	0.88	24	116.57	21	0.84	32
MONTEBELLO	131.06	12	1.13	14	118.08	13	1.17	12	158.34	10	1.16	15	150.28	12	1.18	11	133.52	19	1.17	15
ONTARIO	93.09	24	0.87	22	77.39	29	0.79	23	97.91	23	1.00	19	94.04	27	0.74	27	105.07	27	0.93	27
PALM SPRINGS	175.92	8	1.27	8	112.80	14	0.77	25	107.04	20	0.71	29	99.54	24	0.80	26	107.58	25	1.07	19
REDLANDS	120.13	16	1.11	16	96.48	21	1.04	15	154.25	12	1.04	18	124.52	17	1.01	14	137.11	16	0.98	23
RIDGECREST	229.65	4	1.44	4	161.95	9	1.12	13	176.84	9	1.57	6	148.90	13	1.01	15	254.31	6	1.05	20
SADDLEBACK	83.01	27	0.73	27	70.69	31	0.53	34	99.07	22	0.74	26	46.03	34	0.39	35	65.99	34	0.65	35
SAN JOAQUIN	135.90	10	1.04	18	244.44	2	1.45	6	138.25	13	1.17	14	127.50	16	1.05	13	108.44	23	1.09	18
SANTA ANA	78.60	29	0.55	32	93.35	24	0.74	26	91.68	26	0.84	23	67.46	32	0.71	29	97.27	29	1.00	22
SANTA BARBARA	153.81	9	1.15	13	82.00	28	0.70	27	183.78	7	1.38	9	152.37	11	1.52	6	156.66	10	1.41	8
SANTA MONICA	101.69	21	0.79	25	122.78	12	1.00	17	110.76	19	0.99	20	75.41	30	0.62	32	91.08	31	0.95	26
SOUTH BAY	122.68	15	1.17	10	142.15	10	1.49	5	125.28	16	1.39	8	164.07	10	1.31	8	183.90	7	1.88	7
TEHACHAPI	117.96	17	1.43	5	232.67	3	1.12	14	130.70	15	1.29	13	298.96	5	1.21	9	97.29	28	1.13	16
THOUSAND OAKS	127.73	14	1.05	17	93.86	23	0.91	18	104.37	21	1.10	17	106.59	21	0.92	21	143.78	13	1.31	11
VALENCIA	62.01	35	0.46	34	51.04	34	0.53	33	79.23	32	0.61	33	72.27	31	0.61	33	105.09	26	0.97	25
VENTURA	134.81	11	1.15	11	100.52	18	1.21	11	183.79	6	1.65	4	148.85	14	1.19	10	150.41	11	1.24	13
VICTORVILLE	67.70	34	0.66	30	61.33	33	0.63	30	68.85	33	0.63	31	87.03	28	0.91	22	79.35	33	0.92	28
WHITTIER	72.60	32	0.74	26	135.04	11	0.86	19	87.60	28	0.70	30	114.52	18	0.73	28	137.34	15	0.81	33
WILDOMAR	88.54	26	0.72	28	40.51	35	0.56	32	118.49	18	0.81	24	52.70	33	0.60	34	84.01	32	0.87	30
YUCCA VALLEY	319.82	3	3.41	2	216.97	5	1.50	4	304.25	3	1.49	7	389.08	3	1.80	5	463.68	4	3.39	4
SCE SystemWide	108.13		0.89		102.61		0.91		112.00		0.96		114.83		0.92		134.48		1.10	

Exclusions are days which utilities are allowed to remove from their metrics because the outages on those days were caused by a severe acts of nature.

**In the columns showing "Rank," lower numbers indicate poorer performance.


Overview of Fresno District 5

There are 17 circuits that serve Fresno District 5

Circuit Type	Sum of Customers	Circuit Type	Sum of Customers	Circuit Type	Sum of Customers	Circuit Type	Sum of Customers
BIG CREEK-PORTAL(33KV)	5						
BILLY CREEK(4.16KV)	197						
CASCADA(12KV)	135						
CHINA PEAK(12KV)	147						
DINKEY CREEK(4.16KV)	56						
GROUSE(7KV)	12						
MICRO(4.16KV)	114						
MT. GIVENS(2.4KV)	7						
PERIMETER(12KV)	1,247						
RANCHERIA(2.4KV)	25						
ROSEBUD(12KV)	792						
SAGINAW(12KV)	3						
SIPHON(4.16KV)	50						
SNO CAT(12KV)	3						
STEVENSON(12KV)	35						
TOLLHOUSE(4.16KV)	7						
TRAIL(4.16KV)	84						


Grand Total 2,919

Reliability History of Circuits Serving Fresno District 5 (No Exclusions)



Causes of Repair Outages in Fresno District 5 Circuits 2016 YTD


Contributions to SAIDI by Outage Cause



SAIDI = the cumulative amount of time the average customer is interrupted by “sustained” outages each year.

Causes of Repair Outages in Fresno District 5 Circuits 2016 YTD

Contributions to SAIFI by Outage Cause



- **Equipment Failure**
e.g., in-service failure of transformer, switch, or conductors
- **Vegetation/Animal**
e.g., tree branch, rodent, or bird causing a short circuit between conductors
- **Other**
e.g., patrolled but no cause found
- **Operations**
e.g., urgent maintenance w/o 3-day notice
- **3rd Party**
e.g., balloon, car hit pole, dig-in

SAIFI = the number of times the average customer is interrupted by “sustained” outages each year.

Fresno County District 5 Unincorporated Areas 2017 All Circuits

- Unincorporated Community
- Unincorporated County Area
- Supervisory District

Distribution Circuit

- ADAMS
- BIG CREEK-PORTAL
- BULLY CREEK
- CASCADE
- CHINA PEAK
- DINKY CREEK
- DROUSE
- JUMBO
- KOKANELL
- MANFOLD
- MENDO
- MT. GIVENS
- MUSICK
- PERIMETER
- RANCHERIA
- ROSEBUD
- SACRAMENTO
- SHOSH
- SNOOK
- STEVENS
- TOLL-HOUSE
- TRAIL

Disclaimer: This report is intended solely for informational purposes. The information included is reflective as of January 1, 2017 and is subject to change without further notice.



Date: 2/23/2017
File Name: SUPER_AC_D0V8_v2data_UPDATED104.mxd

Features displayed herein are showing actual accuracy, are intended for informational purposes only. Data was and accuracy may be distorted at this scale. Always consult with the proper local government or agencies for more information. Real Estate is not a warranty of title. Southern California Edison Company is not responsible for any errors or omissions. All rights reserved. Southern California Edison Company is not responsible for any errors or omissions. All rights reserved.



Fresno County District 5 Unincorporated Areas 2017 Capital Improvement Plan

Unincorporated Community

Unincorporated County Area

Supervisory District

Replacement/Equipment Upgrade

• Pole Replacement

Other Work

• Structures & Equipment

Other Work (Transmission)

■ Bulk Power

Disclaimer: This report is intended solely for informational purposes. The information included is reflective as of January 1, 2017 and is subject to change without further notice.



0 2 4 8
Miles

Date: 2/22/2017

File Name: Fresno_District 5_2017_CIP.mxd

Files not depicted herein are showing, new accuracy, are intended for informational purposes only. Discrepancies and omissions may be identified at all scales. Always consult with the proper legal documents or agencies regarding such items. Always consult with the proper legal documents. Turner DSS, Inc. is a registered provider of the State of California. Periodically with revision issued by Turner DSS, Inc. © Turner DSS, Inc. & Company.

All rights reserved.

Source Layer Credits: Content may not reflect National Geographic current map policy.

Source: National Geographic, Esri, DeLorme, NAVTEQ, USGS, AeroGRID, IGN, SDA, Esri, etc.



Back-up Slides

Reliability Histories of Circuits Serving Fresno District 5

Updated through Year-End 2016

Average Reliability of 17 Circuits Serving Fresno District 5

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
Fresno District 5	160.9	3.1	5.1	932.1	1.4	5.0	427.8	3.5	9.4	807.7	3.2	2.6	83.9	0.2	0.7	31.4	0.6	0.7	149.3	0.7	0.3	1072.4	4.7	4.2
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	99%	0%	0%	0%	0%	3%	12%	0%
Equipment Failure	36%	29%	19%	3%	3%	6%	32%	10%	7%	0%	0%	0%	55%	81%	98%	0%	0%	0%	67%	61%	93%	14%	13%	21%
Operation	24%	32%	20%	11%	1%	0%	43%	33%	7%	4%	10%	0%	1%	2%	0%	0%	1%	15%	3%	3%	0%	4%	8%	2%
Other	22%	24%	61%	27%	31%	69%	3%	21%	7%	73%	32%	32%	0%	0%	1%	0%	0%	85%	0%	0%	5%	55%	22%	34%
Vegetation/Animal	0%	0%	0%	17%	25%	0%	0%	0%	3%	0%	0%	0%	40%	14%	0%	0%	0%	0%	2%	1%	1%	3%	1%	0%
Weather/Fire/Earthquake	18%	15%	0%	43%	39%	24%	22%	36%	76%	23%	57%	68%	4%	4%	0%	0%	0%	0%	28%	35%	1%	22%	44%	42%
SCE Systemwide	102.6	0.9	1.2	112.0	1.0	1.4	114.8	0.9	1.4	40.5	0.3	0.4	34.8	0.3	0.4	29.4	0.2	0.3	29.8	0.3	0.4	134.5	1.1	1.6

Notes:

No outages are excluded from the metrics.

Outage Causes:

Other: e.g., patrolled but no cause could be found

Operations: e.g., urgent maintenance w/o 3-day notice to customers

3rd Party: e.g., balloons, car hit pole, dig-in

Vegetation/Animal: e.g., tree branch, rodent, or bird causing short circuit across conductors

SAIDI (minutes) = the cumulative amount of time the average customer is interrupted by "sustained" (longer than 5 minutes) outages.

SAIFI (interruptions) = the number of times the average customer is interrupted by "sustained" outages.

MAIFI (interruptions) = the number of times the average customer is interrupted by "momentary" (lasting 5 minutes or less) outages.

Reliability Histories for Individual Circuits Serving Fresno District 5

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
BIG CREEK-PORTAL(33KV) - Customers:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1348.4	0.9	0.9	47.5	0.2	0.7	9.2	0.9	0.0	0.0	0.0	0.0	1405.1	2.1	1.6
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	1%	44%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	0%	0%	0%	3%	11%	43%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	96%	44%	57%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
BILLY CREEK(4.16KV) - Customers: 197	6.9	1.0	1.0	1820.1	1.2	2.0	901.3	1.3	9.4	2391.9	2.9	4.8	0.0	0.0	0.0	138.3	1.0	0.0	0.0	0.0	0.0	2530.2	3.9	4.8
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	5%	26%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	100%	3%	14%	0%	67%	82%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	50%	0%	0%	0%	95%	33%	20%	0%	0%	0%	0%	0%	0%	0%	0%	0%	90%	25%	20%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	97%	86%	50%	33%	18%	100%	5%	67%	80%	0%	0%	0%	0%	0%	0%	0%	0%	0%	4%	49%	80%
CASCADA(12KV) - Customers: 135	7.0	1.0	2.0	28.3	1.0	2.0	138.3	3.0	9.9	20.9	1.0	1.0	0.0	0.0	0.0	10.1	1.0	0.0	0.0	0.0	0.0	31.0	2.1	1.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	33%	49%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	50%	0%	0%	0%	100%	100%	20%	37%	4%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	25%	2%	0%
Other	0%	0%	50%	0%	0%	51%	0%	0%	0%	63%	96%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	42%	49%	100%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	100%	100%	49%	0%	0%	80%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
CHINA PEAK(12KV) - Customers: 147	7.3	1.0	1.0	2028.1	1.0	2.1	594.0	1.0	8.0	5045.1	4.9	4.0	0.0	0.0	0.0	134.0	1.0	0.0	0.0	0.0	0.0	5179.1	5.9	4.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	3%	17%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	100%	0%	0%	0%	100%	100%	0%	9%	20%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	9%	16%	0%
Other	0%	0%	0%	0%	0%	52%	0%	0%	0%	89%	39%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	86%	32%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	100%	100%	48%	0%	0%	100%	2%	41%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	2%	34%	100%

Reliability Histories for Individual Circuits Serving Fresno District 5

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
DINKEY CREEK(4.16KV) - Customers: 56	1118.0	4.0	6.0	461.9	1.0	7.0	226.9	3.1	5.0	293.1	3.3	3.3	0.0	0.0	1.1	9.7	1.0	0.0	0.0	0.0	0.0	302.8	4.3	4.4
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	3%	23%	0%
Equipment Failure	95%	50%	0%	100%	100%	0%	25%	3%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	24%
Operation	1%	25%	17%	0%	0%	0%	0%	0%	0%	41%	34%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	40%	26%	0%
Other	0%	0%	83%	0%	0%	100%	8%	32%	20%	11%	33%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	11%	25%	25%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	5%	25%	0%	0%	0%	0%	67%	65%	80%	48%	34%	67%	0%	0%	0%	0%	0%	0%	0%	0%	0%	46%	26%	51%
GROUSE(7KV) - Customers: 12	7.0	1.0	1.0	2628.2	3.3	2.0	539.0	4.0	9.0	146.0	3.0	4.0	0.0	0.0	0.0	10.0	1.0	0.0	0.0	0.0	1.0	156.0	4.0	5.0
3rd Party	0%	0%	0%	1%	3%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	6%	25%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	100%	0%	0%	0%	16%	50%	22%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	50%	0%	0%	0%	21%	33%	25%	0%	0%	0%	0%	0%	0%	0%	0%	100%	20%	25%	40%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	27%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	99%	98%	50%	57%	25%	78%	79%	67%	75%	0%	0%	0%	0%	0%	0%	0%	0%	0%	74%	50%	60%
MICRO(4.16KV) - Customers: 114	7.0	1.0	1.0	1769.4	1.0	2.0	595.7	1.0	9.0	2259.5	2.9	4.0	0.0	0.0	0.0	135.6	1.0	0.0	0.0	0.0	0.0	2395.2	3.9	4.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	6%	26%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	100%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	50%	0%	0%	11%	95%	31%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	89%	23%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	100%	100%	50%	0%	0%	89%	5%	69%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	5%	51%	100%
MT. GIVENS(2.4KV) - Customers: 7	7.0	1.0	1.0	2027.0	1.0	2.0	594.0	1.0	8.0	2947.0	4.0	4.0	0.0	0.0	0.0	134.0	1.0	0.0	0.0	0.0	0.0	3081.0	5.0	4.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	4%	20%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	100%	0%	0%	0%	100%	100%	0%	16%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	15%	20%	0%
Other	0%	0%	0%	0%	0%	50%	0%	0%	0%	80%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	77%	20%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	100%	100%	50%	0%	0%	100%	4%	50%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	4%	40%	100%

Reliability Histories for Individual Circuits Serving Fresno District 5

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
PERIMETER(12KV) - Customers: 1,247	224.2	5.8	8.3	609.5	1.0	5.7	417.1	3.8	7.4	215.6	3.0	3.0	0.2	0.0	1.0	0.0	0.0	0.8	236.4	1.0	0.6	452.2	4.0	5.3
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	36%	35%	21%	1%	1%	13%	73%	20%	22%	0%	0%	0%	0%	0%	100%	0%	0%	0%	100%	100%	100%	52%	25%	29%
Operation	3%	17%	12%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	38%	31%	67%	99%	99%	69%	4%	27%	10%	14%	33%	33%	0%	0%	0%	0%	0%	100%	0%	0%	0%	7%	25%	33%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	23%	17%	0%	0%	0%	17%	22%	53%	67%	85%	66%	67%	0%	0%	0%	0%	0%	0%	0%	0%	0%	41%	50%	38%
RANCHERIA(2.4KV) - Customers: 25	7.0	1.0	1.0	2027.0	1.0	2.0	594.0	1.0	8.0	2947.0	4.0	3.0	0.0	0.0	0.0	134.0	1.0	0.0	0.0	0.0	0.0	3081.0	5.0	3.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	4%	20%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	100%	0%	0%	0%	100%	100%	0%	16%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	15%	20%	0%
Other	0%	0%	0%	0%	0%	50%	0%	0%	0%	80%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	77%	20%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	100%	100%	50%	0%	0%	100%	4%	50%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	4%	40%	100%
ROSEBUD(12KV) - Customers: 792	7.3	1.0	3.8	612.3	2.3	6.8	238.4	4.8	13.9	313.2	3.7	1.0	171.5	0.7	0.7	11.0	1.0	1.3	157.9	0.9	0.0	653.6	6.3	3.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	2%	16%	0%
Equipment Failure	0%	0%	24%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	0%	0%	0%	26%	11%	24%
Operation	100%	100%	26%	0%	0%	0%	85%	60%	14%	2%	24%	0%	0%	0%	0%	0%	0%	30%	4%	2%	0%	2%	14%	13%
Other	0%	0%	50%	0%	0%	70%	7%	19%	6%	4%	27%	100%	0%	0%	0%	0%	0%	70%	0%	0%	0%	2%	16%	63%
Vegetation/Animal	0%	0%	0%	95%	56%	0%	0%	0%	6%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	5%	44%	30%	8%	21%	73%	93%	50%	0%	0%	0%	0%	0%	0%	0%	96%	98%	0%	68%	43%	0%
SAGINAW(12KV) - Customers: 3	5802.1	1.8	0.0	0.0	0.0	0.0	9.5	0.9	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving Fresno District 5

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
SIPHON(4.16KV) - Customers: 50	310.8	4.0	5.0	605.7	1.0	2.0	94.2	3.0	6.0	248.3	3.2	6.1	400.3	1.5	0.9	9.9	1.0	0.0	0.0	0.0	0.0	658.5	5.7	6.9
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	2%	17%	0%
Equipment Failure	3%	25%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	12%
Operation	2%	25%	20%	0%	0%	0%	0%	0%	0%	0%	0%	0%	7%	11%	0%	0%	0%	0%	0%	0%	0%	5%	3%	0%
Other	4%	25%	80%	0%	0%	100%	28%	67%	33%	13%	32%	17%	0%	0%	0%	0%	0%	0%	0%	0%	0%	5%	18%	15%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	93%	89%	0%	0%	0%	0%	0%	0%	0%	56%	23%	0%
Weather/Fire/Earthquake	91%	25%	0%	0%	0%	0%	72%	33%	67%	87%	68%	83%	0%	0%	0%	0%	0%	0%	0%	0%	0%	33%	38%	73%
SNO CAT(12KV) - Customers: 3	0.0	0.0	1.0	8.0	1.0	1.0	847.0	3.0	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	3%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	100%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	100%	97%	67%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
STEVENSON(12KV) - Customers: 35	1647.2	1.6	3.2	7896.3	0.7	1.5	2030.7	4.7	0.6	0.0	0.0	0.2	373.8	1.0	0.7	2.6	0.3	0.0	550.5	1.8	0.0	926.9	3.0	0.9
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	4%	2%	0%	0%	0%	28%	48%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	96%	9%	100%	100%	26%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	44%	77%	0%	27%	55%	0%
Other	0%	0%	89%	0%	0%	74%	0%	0%	50%	0%	0%	100%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	100%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	28%	29%	0%	0%	0%	0%	56%	23%	0%	44%	23%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	72%	52%	50%	0%	0%	0%	72%	71%	0%	0%	0%	0%	0%	0%	0%	29%	23%	0%
TOLLHOUSE(4.16KV) - Customers: 7	6.5	0.9	0.9	1807.9	0.9	4.6	1182.8	4.1	3.9	2400.0	2.9	3.9	9215.3	1.9	1.0	146.2	1.1	0.0	0.0	0.0	4.7	11761.5	5.9	9.6
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	1%	18%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	100%	0%	0%	0%	51%	24%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	81%	0%	0%	0%	95%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	59%	19%	16%	29%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	0%	0%	21%	78%	33%	20%
Weather/Fire/Earthquake	0%	0%	0%	100%	100%	19%	49%	76%	100%	5%	67%	100%	0%	0%	0%	0%	0%	0%	0%	0%	21%	1%	33%	51%

Reliability Histories for Individual Circuits Serving Fresno District 5

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
TRAIL(4.16KV) - Customers: 84	6.9	1.0	1.0	1777.5	1.0	2.0	675.9	1.1	9.0	2457.3	3.0	4.0	0.0	0.0	0.0	137.6	1.0	0.0	0.0	0.0	0.0	2594.9	4.0	4.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	5%	26%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	2%	4%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	100%	0%	0%	0%	89%	92%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	50%	0%	0%	11%	95%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	90%	25%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	100%	100%	50%	9%	4%	89%	5%	67%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	5%	50%	100%