



Circuit Reliability Review

Rosemead

January 2017

Providing Safe, Reliable, and Affordable Power

Southern California Edison is modernizing the power grid to meet the changing needs and expectations of our customers and to help California achieve its clean energy goals.

We are investing more than \$12 billion into our power grid between 2015 – 2017 with the goal of increasing power reliability through significant upgrades. These investments include:

- Updating thousands of transmission and distribution poles
- Replacing hundreds of miles of underground cables
- Replacing hundreds of underground structures such as vaults and manholes
- Upgrading critical distribution equipment; capacitor banks, switches, and circuit breakers
- Building new distribution circuits to serve electrical demands in our communities
- Inspecting and replacing overhead conductor and equipment to improve public safety

Our investments in local communities will help ensure that customers receive safe, reliable, and affordable electricity now and in the future.

Understanding Your Reliability Report

As your electric utility, we want you to always have power when you need it. To get there, we constantly track and monitor electric outages across our service territory, and we measure our “system reliability” from this data.

The two metrics we rely on are common in the electric utility industry: the System Average Interruption Duration Index (SAIDI) and the System Average Interruption Frequency Index (SAIFI). Both are described in more detail on the next page.

Replacing and upgrading our infrastructure will help SCE maintain or improve SAIDI and SAIFI measurements.

This report provides historical reliability data for the circuits that serve your jurisdiction and our proposed infrastructure upgrades for the current year.

To view other reliability reports, visit [sce.com>Outage Center>Maintaining Reliable Service](https://www.sce.com/Outage-Center/Maintaining-Reliable-Service)

Reliability Metrics

MOMENTARY OUTAGES:

OUTAGES LASTING 5 MINUTES OR LESS

MAIFI:

- The number of times the average customer is interrupted by Momentary outages each year.

SUSTAINED OUTAGES:

OUTAGES LASTING LONGER THAN 5 MINUTES

SAIFI:

- The number of times the average customer is interrupted by Sustained outages each year.

SAIDI:

- The cumulative amount of time the average customer is interrupted by Sustained outages each year.

Cities in the Montebello District

Alhambra

East Los Angeles

El Monte

Los Angeles

Montebello

Monterey Park

North El Monte

Pico Rivera

Rosemead

South El Monte

South San Gabriel

Reliability by SCE District (No Exclusions)

District Name	2012				2013				2014				2015				2016			
	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking
ANTELOPE VALLEY	78.60	28	0.56	31	94.42	22	0.62	31	51.05	35	0.59	34	104.34	22	0.68	30	107.67	24	0.87	29
ARROWHEAD	129.58	13	1.31	7	180.59	7	1.39	8	193.25	5	1.59	5	362.61	4	3.97	1	659.46	3	2.85	5
BARSTOW	184.80	7	1.15	12	204.33	6	1.40	7	201.53	4	1.34	10	187.11	8	1.17	12	134.83	18	1.35	9
BIG CREEK	1184.25	1	4.52	1	176.51	8	3.08	1	920.25	1	1.34	11	422.77	2	3.42	2	1062.01	2	4.99	1
BISHOP	463.09	2	1.25	9	104.44	17	0.51	35	118.79	17	0.59	35	298.11	6	2.22	4	168.59	8	1.22	14
BLYTHE	225.88	6	1.53	3	483.13	1	1.38	9	707.54	2	2.42	2	427.00	1	1.52	7	396.38	5	2.71	6
CATALINA	78.46	30	0.72	29	105.94	16	2.97	2	97.02	24	4.17	1	42.56	35	2.25	3	65.01	35	3.66	3
COVINA	108.73	19	0.92	19	100.51	19	0.86	20	91.60	27	0.87	22	100.08	23	0.81	25	112.13	22	0.97	24
DOMINGUEZ HILLS	117.22	18	0.82	24	89.17	26	0.80	21	82.30	29	0.71	28	130.63	15	0.97	17	146.38	12	1.11	17
FOOTHILL	91.69	25	0.90	20	85.80	27	0.79	24	93.35	25	0.93	21	109.64	20	0.95	20	142.81	14	1.03	21
FULLERTON	68.99	33	0.42	35	90.57	25	0.79	22	82.23	30	0.72	27	76.59	29	0.67	31	92.72	30	0.76	34
HUNTINGTON BEACH	95.78	23	0.89	21	66.51	32	0.68	29	79.61	31	0.78	25	98.32	25	0.95	19	128.02	20	1.26	12
KERNVILLE	226.76	5	1.31	6	232.18	4	1.96	3	178.69	8	1.99	3	286.38	7	0.96	18	2421.32	1	3.67	2
LONG BEACH	75.83	31	0.55	33	75.11	30	0.70	28	66.33	34	0.61	32	164.46	9	0.89	23	135.16	17	0.86	31
MENIFEE	99.32	22	0.84	23	107.39	15	1.26	10	156.68	11	1.32	12	111.46	19	0.98	16	156.75	9	1.31	10
MONROVIA	108.11	20	1.13	15	99.12	20	1.02	16	133.32	14	1.16	16	96.68	26	0.88	24	116.57	21	0.84	32
MONTEBELLO	131.06	12	1.13	14	118.08	13	1.17	12	158.34	10	1.16	15	150.28	12	1.18	11	133.52	19	1.17	15
ONTARIO	93.09	24	0.87	22	77.39	29	0.79	23	97.91	23	1.00	19	94.04	27	0.74	27	105.07	27	0.93	27
PALM SPRINGS	175.92	8	1.27	8	112.80	14	0.77	25	107.04	20	0.71	29	99.54	24	0.80	26	107.58	25	1.07	19
REDLANDS	120.13	16	1.11	16	96.48	21	1.04	15	154.25	12	1.04	18	124.52	17	1.01	14	137.11	16	0.98	23
RIDGECREST	229.65	4	1.44	4	161.95	9	1.12	13	176.84	9	1.57	6	148.90	13	1.01	15	254.31	6	1.05	20
SADDLEBACK	83.01	27	0.73	27	70.69	31	0.53	34	99.07	22	0.74	26	46.03	34	0.39	35	65.99	34	0.65	35
SAN JOAQUIN	135.90	10	1.04	18	244.44	2	1.45	6	138.25	13	1.17	14	127.50	16	1.05	13	108.44	23	1.09	18
SANTA ANA	78.60	29	0.55	32	93.35	24	0.74	26	91.68	26	0.84	23	67.46	32	0.71	29	97.27	29	1.00	22
SANTA BARBARA	153.81	9	1.15	13	82.00	28	0.70	27	183.78	7	1.38	9	152.37	11	1.52	6	156.66	10	1.41	8
SANTA MONICA	101.69	21	0.79	25	122.78	12	1.00	17	110.76	19	0.99	20	75.41	30	0.62	32	91.08	31	0.95	26
SOUTH BAY	122.68	15	1.17	10	142.15	10	1.49	5	125.28	16	1.39	8	164.07	10	1.31	8	183.90	7	1.88	7
TEHACHAPI	117.96	17	1.43	5	232.67	3	1.12	14	130.70	15	1.29	13	298.96	5	1.21	9	97.29	28	1.13	16
THOUSAND OAKS	127.73	14	1.05	17	93.86	23	0.91	18	104.37	21	1.10	17	106.59	21	0.92	21	143.78	13	1.31	11
VALENCIA	62.01	35	0.46	34	51.04	34	0.53	33	79.23	32	0.61	33	72.27	31	0.61	33	105.09	26	0.97	25
VENTURA	134.81	11	1.15	11	100.52	18	1.21	11	183.79	6	1.65	4	148.85	14	1.19	10	150.41	11	1.24	13
VICTORVILLE	67.70	34	0.66	30	61.33	33	0.63	30	68.85	33	0.63	31	87.03	28	0.91	22	79.35	33	0.92	28
WHITTIER	72.60	32	0.74	26	135.04	11	0.86	19	87.60	28	0.70	30	114.52	18	0.73	28	137.34	15	0.81	33
WILDOMAR	88.54	26	0.72	28	40.51	35	0.56	32	118.49	18	0.81	24	52.70	33	0.60	34	84.01	32	0.87	30
YUCCA VALLEY	319.82	3	3.41	2	216.97	5	1.50	4	304.25	3	1.49	7	389.08	3	1.80	5	463.68	4	3.39	4
SCE SystemWide	108.13		0.89		102.61		0.91		112.00		0.96		114.83		0.92		134.48		1.10	

Exclusions are days which utilities are allowed to remove from their metrics because the outages on those days were caused by a severe acts of nature.


**In the columns showing "Rank," lower numbers indicate poorer performance.

Overview of Rosemead

There are 29 circuits that serve Rosemead


Circuit Type	Sum of Customers	Circuit Type	Sum of Customers	Circuit Type	Sum of Customers	Circuit Type	Sum of Customers
ARBOLES(16KV)	2,668						
BARTLETT(4.16KV)	488						
BENTEL(4.16KV)	564						
BILTON(16KV)	4,459						
BLEEKER(16KV)	2						
BROOKLINE(16KV)	1,540						
CHANGE(16KV)	1,745						
CLAYTON(16KV)	3,105						
EDMOND(4.16KV)	658						
FORBID(16KV)	1,966						
GERONA(16KV)	1,679						
GLADYS(16KV)	3,265						
HIGHCLIFF(16KV)	1,914						
HONOR(16KV)	2,157						
KEIM(4.16KV)	551						
LODESTAR(16KV)	7						
MUSCATEL(4.16KV)	602						
OLNEY(16KV)	1,780						
OPPORTUNITY(16KV)	1,765						
PALJAY(16KV)	1,869						
PECK(16KV)	710						
PICADOR(16KV)	4,418						
RURAL(4.16KV)	1,061						
SARAH(4.16KV)	770						
SAXON(4.16KV)	677						
SEGOVIA(16KV)	1,485						
TAMORA(16KV)	558						
TELSTAR(16KV)	2,846						
WHITMORE(16KV)	864						
Grand Total			46,173				

Reliability History of Circuits Serving Rosemead (No Exclusions)



Causes of Repair Outages in Rosemead Circuits 2016 YTD


Contributions to SAIDI by Outage Cause




SAIDI = the cumulative amount of time the average customer is interrupted by “sustained” outages each year.

Causes of Repair Outages in Rosemead Circuits 2016 YTD

Contributions to SAIFI by Outage Cause



SAIFI = the number of times the average customer is interrupted by “sustained” outages each year.



☒ Pole Replacement

**SOUTHERN CALIFORNIA
EDISON®**
An EDISON INTERNATIONAL® Company

Back-up Slides

Reliability Histories of Circuits Serving Rosemead

Updated through Year-End 2016

Average Reliability of 29 Circuits Serving Rosemead

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
Rosemead	134.5	1.5	1.8	150.4	1.2	2.2	150.9	1.0	2.2	15.3	0.1	0.5	38.3	0.2	1.1	24.3	0.1	0.4	78.3	0.5	0.4	156.2	1.0	2.5
3rd Party	5%	4%	18%	16%	25%	24%	30%	31%	13%	0%	0%	0%	1%	2%	3%	20%	17%	59%	21%	29%	11%	14%	17%	13%
Equipment Failure	79%	58%	30%	51%	46%	34%	25%	36%	12%	37%	26%	2%	95%	85%	34%	67%	50%	16%	12%	11%	15%	43%	33%	21%
Operation	3%	4%	0%	4%	6%	5%	6%	7%	3%	1%	1%	0%	1%	3%	6%	12%	33%	3%	53%	49%	0%	29%	30%	3%
Other	2%	1%	24%	14%	10%	13%	9%	11%	40%	13%	17%	64%	2%	1%	22%	0%	0%	12%	2%	1%	19%	3%	3%	28%
Vegetation/Animal	2%	22%	21%	1%	0%	13%	1%	2%	27%	8%	9%	33%	1%	9%	35%	0%	0%	10%	12%	10%	55%	7%	9%	34%
Weather/Fire/Earthquake	8%	11%	8%	15%	13%	11%	29%	13%	5%	41%	48%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	4%	7%	0%
SCE Systemwide	102.6	0.9	1.2	112.0	1.0	1.4	114.8	0.9	1.4	40.5	0.3	0.4	34.8	0.3	0.4	29.4	0.2	0.3	29.8	0.3	0.4	134.5	1.1	1.6

Notes:

No outages are excluded from the metrics.

Outage Causes:

Other: e.g., patrolled but no cause could be found

Operations: e.g., urgent maintenance w/o 3-day notice to customers

3rd Party: e.g., balloons, car hit pole, dig-in

Vegetation/Animal: e.g., tree branch, rodent, or bird causing short circuit across conductors

SAIDI (minutes) = the cumulative amount of time the average customer is interrupted by "sustained" (longer than 5 minutes) outages.

SAIFI (interruptions) = the number of times the average customer is interrupted by "sustained" outages.

MAIFI (interruptions) = the number of times the average customer is interrupted by "momentary" (lasting 5 minutes or less) outages.

Reliability Histories for Individual Circuits Serving Rosemead

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
ARBOLES(16KV) - Customers: 2,668	429.2	4.1	1.0	265.9	2.0	6.0	327.8	1.2	0.0	0.0	0.0	1.7	32.0	0.1	0.0	44.4	0.1	1.1	55.0	1.1	0.0	131.3	1.3	2.8
3rd Party	28%	25%	0%	1%	0%	17%	51%	86%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	99%	100%	0%	42%	87%	39%
Equipment Failure	69%	75%	100%	12%	50%	0%	46%	10%	0%	0%	0%	0%	97%	83%	0%	91%	50%	0%	0%	0%	0%	54%	9%	0%
Operation	0%	0%	0%	0%	0%	0%	4%	3%	100%	0%	0%	0%	3%	17%	0%	9%	50%	0%	1%	0%	0%	4%	4%	0%
Other	3%	1%	0%	0%	0%	33%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	61%
Vegetation/Animal	0%	0%	0%	0%	0%	17%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	87%	50%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
BARTLETT(4.16KV) - Customers: 488	0.0	0.0	1.0	9.2	0.1	1.0	0.0	0.0	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3rd Party	0%	0%	0%	51%	19%	100%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	49%	81%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	100%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
BENTEL(4.16KV) - Customers: 564	125.1	1.0	2.0	357.6	2.1	1.0	0.3	0.0	2.3	0.0	0.0	0.0	0.8	0.0	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.8	0.0	1.0
3rd Party	0%	0%	49%	51%	50%	100%	0%	0%	87%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	51%	14%	4%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	0%	35%	46%	0%	100%	100%	13%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	100%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
BILTON(16KV) - Customers: 4,459	12.5	1.0	2.0	175.6	1.6	3.0	71.3	1.0	5.0	69.5	0.8	0.0	180.5	1.1	1.1	3.0	0.0	1.1	147.5	1.1	0.2	400.6	3.0	2.4
3rd Party	0%	0%	0%	0%	0%	0%	84%	98%	20%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	100%	100%	37%	36%	54%
Equipment Failure	3%	0%	0%	100%	100%	33%	16%	2%	20%	0%	0%	0%	96%	99%	100%	0%	0%	0%	0%	0%	0%	43%	37%	46%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	1%	0%	0%
Other	0%	0%	0%	0%	0%	33%	0%	0%	20%	0%	0%	0%	4%	1%	0%	0%	0%	0%	0%	0%	0%	2%	1%	0%
Vegetation/Animal	97%	100%	100%	0%	0%	33%	0%	0%	40%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	17%	26%	0%

Reliability Histories for Individual Circuits Serving Rosemead

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
BLEEKER(16KV) - Customers: 2	0.0	0.0	0.0	0.0	0.0	0.0	558.5	0.5	1.0	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	100%
Operation	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
BROOKLINE(16KV) - Customers: 1,540	284.5	3.9	3.1	224.5	2.6	5.9	663.5	5.8	7.5	4.4	0.0	1.0	24.5	0.1	0.9	0.0	0.0	0.0	1.2	0.0	0.0	30.1	0.1	1.9
3rd Party	11%	13%	16%	4%	1%	17%	43%	17%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	44%	17%	0%	2%	0%	0%
Equipment Failure	82%	86%	53%	47%	60%	17%	31%	57%	47%	69%	33%	0%	61%	11%	100%	0%	0%	0%	0%	0%	0%	59%	11%	47%
Operation	1%	0%	0%	1%	0%	0%	0%	0%	0%	19%	50%	0%	18%	87%	0%	0%	0%	0%	0%	0%	0%	17%	83%	0%
Other	1%	0%	0%	0%	0%	16%	15%	17%	39%	0%	0%	0%	22%	3%	0%	0%	0%	0%	0%	0%	0%	18%	3%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	34%	0%	0%	0%	12%	17%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	2%	0%	53%
Weather/Fire/Earthquake	5%	0%	32%	48%	39%	17%	10%	9%	13%	0%	0%	0%	0%	0%	0%	0%	0%	0%	56%	83%	0%	2%	2%	0%
CHANGE(16KV) - Customers: 1,745	117.2	1.1	0.0	1.0	0.0	0.0	104.7	1.6	2.6	1.0	0.0	0.0	1.7	0.0	3.9	0.0	0.0	0.0	0.0	0.0	1.0	2.7	0.0	4.9
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	100%	100%	0%	0%	0%	0%	6%	0%	0%	0%	0%	0%	0%	0%	25%	0%	0%	0%	0%	0%	0%	0%	0%	20%
Operation	0%	0%	0%	100%	100%	0%	36%	60%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	36%	46%	0%
Other	0%	0%	0%	0%	0%	0%	55%	38%	62%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	40%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	2%	1%	38%	0%	0%	0%	100%	100%	25%	0%	0%	0%	0%	0%	100%	64%	54%	41%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
CLAYTON(16KV) - Customers: 3,105	20.0	0.3	1.8	64.7	1.2	2.4	248.6	2.0	1.0	0.0	0.0	0.9	120.9	0.3	4.5	0.0	0.0	0.0	52.5	1.1	0.0	173.4	1.4	5.4
3rd Party	14%	5%	56%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	12%	17%	33%	39%	50%	100%	0%	0%	0%	100%	100%	53%	0%	0%	0%	9%	2%	0%	72%	24%	45%
Operation	21%	20%	0%	0%	0%	0%	1%	0%	0%	0%	0%	0%	0%	0%	23%	0%	0%	0%	46%	94%	0%	14%	73%	20%
Other	65%	75%	44%	0%	0%	0%	60%	50%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	36%	2%	0%	11%	2%	16%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	23%	0%	0%	0%	10%	2%	0%	3%	1%	20%
Weather/Fire/Earthquake	0%	0%	0%	88%	83%	67%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving Rosemead

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
EDMOND(4.16KV) - Customers: 658	0.3	0.0	2.0	0.0	0.0	1.0	37.0	1.0	1.1	0.0	0.0	0.0	25.2	0.4	1.6	99.3	0.7	0.0	0.0	0.0	0.0	124.6	1.1	1.6
3rd Party	0%	0%	50%	0%	0%	0%	0%	0%	95%	0%	0%	0%	98%	99%	39%	0%	0%	0%	0%	0%	0%	20%	35%	39%
Equipment Failure	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	0%	0%	0%	0%	0%	0%	5%	0%	0%	0%	2%	1%	0%	100%	100%	0%	0%	0%	0%	80%	65%	0%
Other	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	61%	0%	0%	0%	0%	0%	0%	0%	0%	61%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
FORBID(16KV) - Customers: 1,966	25.9	1.1	1.0	155.9	1.5	3.3	49.3	0.0	3.6	24.1	0.0	0.0	8.3	0.0	0.0	0.0	0.0	0.0	115.4	1.2	2.3	147.7	1.3	2.3
3rd Party	0%	0%	0%	42%	24%	67%	92%	69%	27%	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%	33%	0%	0%	33%
Equipment Failure	3%	0%	0%	58%	75%	0%	4%	18%	28%	0%	0%	0%	100%	100%	0%	0%	0%	0%	99%	100%	67%	83%	98%	67%
Operation	73%	5%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	28%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	16%	2%	0%
Vegetation/Animal	24%	95%	100%	0%	0%	33%	4%	13%	17%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
GERONA(16KV) - Customers: 1,679	429.3	0.9	0.7	329.9	1.6	0.5	11.1	0.1	3.0	0.0	0.0	1.5	0.0	0.0	0.0	9.4	0.0	0.8	0.0	0.0	0.0	9.4	0.0	2.3
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	100%	100%	100%	96%	81%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	100%	100%	36%
Operation	0%	0%	0%	2%	2%	0%	91%	94%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	50%	0%	0%	67%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	64%
Vegetation/Animal	0%	0%	0%	2%	2%	0%	0%	0%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	1%	15%	50%	9%	6%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
GLADYS(16KV) - Customers: 3,265	328.4	3.1	4.9	237.9	1.2	2.8	108.4	1.3	3.0	13.0	0.3	0.9	134.6	1.0	1.0	108.9	0.1	0.0	48.3	0.1	1.0	304.7	1.5	2.9
3rd Party	0%	0%	0%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	98%	97%	81%	97%	97%	100%	100%	100%	0%	0%	0%	0%	100%	100%	0%	91%	50%	0%	85%	59%	0%	90%	74%	0%
Operation	1%	0%	0%	3%	3%	0%	0%	0%	0%	3%	0%	0%	0%	0%	0%	9%	50%	0%	0%	0%	0%	3%	3%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	33%	97%	100%	100%	0%	0%	100%	0%	0%	0%	15%	41%	100%	7%	23%	100%
Vegetation/Animal	2%	3%	19%	0%	0%	0%	0%	0%	67%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving Rosemead

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
HIGHCLIFF(16KV) - Customers: 1,914	3.5	0.0	1.0	87.8	1.5	3.5	51.4	0.5	2.5	35.4	0.1	0.0	5.1	0.5	1.0	70.4	0.1	0.0	0.0	0.0	0.0	110.9	0.7	1.0
3rd Party	0%	0%	0%	36%	66%	28%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	71%	77%	0%	45%	31%	43%	43%	3%	0%	100%	100%	0%	0%	0%	0%	100%	99%	0%	0%	0%	0%	95%	27%	0%
Operation	29%	23%	0%	0%	0%	0%	9%	1%	0%	0%	0%	0%	7%	1%	0%	0%	1%	0%	0%	0%	0%	0%	1%	0%
Other	0%	0%	100%	5%	2%	0%	0%	0%	41%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	13%	1%	28%	48%	96%	59%	0%	0%	0%	93%	99%	100%	0%	0%	0%	0%	0%	0%	4%	72%	100%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
HONOR(16KV) - Customers: 2,157	85.1	1.0	0.9	0.0	0.0	0.0	64.7	0.7	3.0	1.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0	22.9	0.0	0.0	24.1	0.0	1.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	95%	99%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	3%	1%	0%	0%	0%	0%	2%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	95%	70%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	33%	100%	100%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	5%	30%	100%
Vegetation/Animal	3%	0%	100%	0%	0%	0%	0%	0%	67%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	98%	98%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
KEIM(4.16KV) - Customers: 551	0.0	0.0	1.0	0.0	0.0	1.0	6.6	0.0	1.0	0.0	0.0	0.0	0.0	0.0	2.0	0.0	0.0	1.0	0.0	0.0	0.0	0.0	0.0	3.0
3rd Party	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	33%
Other	0%	0%	100%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	67%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
LODESTAR(16KV) - Customers: 7	274.8	1.2	1.1	0.0	0.0	0.0	0.0	0.0	1.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	44%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	56%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving Rosemead

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
MUSCATEL(4.16KV) - Customers: 602	1.3	0.1	1.0	5.9	0.0	2.0	0.0	0.0	3.0	0.0	0.0	1.0	0.0	0.0	1.0	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	3.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	100%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	67%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	67%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	33%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
OLNEY(16KV) - Customers: 1,780	159.0	1.1	3.8	273.4	1.6	1.5	227.3	1.6	3.2	0.0	0.0	0.0	10.5	0.0	2.0	0.0	0.0	1.0	0.0	0.0	0.0	10.5	0.0	3.0
3rd Party	0%	0%	0%	66%	29%	100%	76%	35%	14%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	33%
Equipment Failure	89%	9%	25%	0%	0%	0%	24%	65%	0%	0%	0%	0%	100%	100%	50%	0%	0%	0%	0%	0%	0%	100%	100%	33%
Operation	11%	91%	0%	16%	12%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	50%	18%	59%	0%	0%	0%	55%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	25%	0%	0%	0%	0%	0%	31%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	33%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
OPPORTUNITY(16KV) - Customers: 1,765	2.1	0.0	0.0	0.0	0.0	0.0	22.7	0.0	1.0	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	2.0	0.0	0.0	0.0	0.0	0.0	3.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	33%
Equipment Failure	69%	45%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	17%	36%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	33%
Vegetation/Animal	14%	18%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	33%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
PALJAY(16KV) - Customers: 1,869	167.3	1.8	1.0	38.5	1.3	0.0	9.7	0.1	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3rd Party	0%	0%	0%	94%	99%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	98%	99%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	2%	1%	0%	6%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving Rosemead

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
PECK(16KV) - Customers: 710	190.2	2.0	1.0	0.0	0.0	0.0	230.4	1.2	2.0	86.9	1.0	1.3	0.0	0.0	1.0	0.0	0.0	0.0	0.0	0.0	0.0	86.9	1.0	2.3
3rd Party	0%	0%	0%	0%	0%	0%	23%	85%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	23%	49%	100%	0%	0%	0%	0%	0%	0%	94%	99%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	94%	99%	43%
Operation	0%	0%	0%	0%	0%	0%	77%	15%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	6%	1%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	6%	1%	57%
Weather/Fire/Earthquake	77%	51%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
PICADOR(16KV) - Customers: 4,418	41.2	1.0	3.0	34.1	0.1	1.0	60.7	0.5	0.5	13.1	0.0	1.1	0.0	0.0	0.0	4.3	0.1	0.0	142.6	0.9	1.4	160.1	1.0	2.5
3rd Party	13%	1%	67%	0%	0%	0%	79%	92%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	68%	3%	0%	99%	91%	0%	6%	3%	0%	85%	85%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	7%	3%	0%
Operation	2%	0%	0%	1%	9%	100%	15%	5%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	36%	42%	0%	35%	45%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	17%	96%	0%	0%	0%	0%	0%	0%	0%	15%	15%	100%	0%	0%	0%	0%	0%	0%	64%	58%	100%	58%	52%	100%
Weather/Fire/Earthquake	0%	0%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
RURAL(4.16KV) - Customers: 1,061	36.0	0.1	3.0	29.6	1.0	2.0	97.2	1.0	3.0	0.0	0.0	1.0	2.1	0.0	3.0	15.1	0.0	0.0	7.9	1.0	0.0	25.1	1.0	4.0
3rd Party	0%	0%	0%	90%	98%	50%	5%	2%	0%	0%	0%	0%	0%	0%	33%	0%	0%	0%	0%	0%	0%	0%	0%	25%
Equipment Failure	100%	100%	0%	10%	2%	50%	21%	1%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	60%	2%	0%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	33%	0%	0%	0%	100%	100%	0%	0%	0%	0%	100%	100%	0%	40%	98%	0%
Other	0%	0%	100%	0%	0%	0%	0%	0%	67%	0%	0%	100%	0%	0%	67%	0%	0%	0%	0%	0%	0%	0%	0%	75%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	74%	96%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
SARAH(4.16KV) - Customers: 770	0.0	0.0	3.0	764.4	1.1	3.0	0.0	0.0	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3rd Party	0%	0%	0%	0%	0%	33%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	0%	10%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	100%	100%	90%	67%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving Rosemead

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
SAXON(4.16KV) - Customers: 677	0.0	0.0	1.0	90.2	2.6	2.9	78.9	1.1	1.0	118.2	1.0	0.8	0.0	0.0	0.0	10.1	0.0	0.0	0.0	0.0	0.0	128.3	1.0	0.8
3rd Party	0%	0%	0%	44%	38%	100%	95%	94%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	38%	37%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	100%	100%	0%	0%	0%	0%	100%	100%	100%
Operation	0%	0%	0%	17%	25%	0%	5%	6%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	100%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
SEGOVIA(16KV) - Customers: 1,485	160.4	1.8	0.0	190.6	3.0	2.2	44.6	0.1	0.0	0.0	0.0	0.0	1.7	0.0	1.0	100.3	0.8	0.9	39.8	0.1	0.0	141.7	1.0	1.9
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	5%	0%	0%	69%	37%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	100%	100%	100%	0%	99%	98%	47%
Operation	0%	0%	0%	4%	1%	0%	87%	83%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	27%	63%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	1%	2%	0%
Vegetation/Animal	3%	1%	0%	0%	0%	0%	13%	17%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	53%
Weather/Fire/Earthquake	92%	99%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
TAMORA(16KV) - Customers: 558	0.0	0.0	0.0	28.5	1.0	1.0	63.1	0.5	2.0	74.8	1.0	0.0	0.8	0.0	1.0	412.7	1.0	0.0	0.3	0.0	0.0	488.6	2.0	1.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	84%	50%	0%
Equipment Failure	0%	0%	0%	61%	2%	0%	20%	3%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	100%
Operation	0%	0%	0%	39%	98%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	100%	80%	97%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	15%	50%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
TELSTAR(16KV) - Customers: 2,846	163.0	4.1	1.3	187.8	1.4	4.1	736.7	2.6	1.5	0.0	0.0	0.0	8.8	0.0	2.0	0.6	0.0	0.0	538.6	2.0	1.0	548.0	2.0	3.0
3rd Party	0%	0%	0%	54%	91%	31%	10%	26%	22%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	64%	49%	0%	45%	8%	69%	11%	39%	0%	0%	0%	0%	91%	64%	0%	0%	0%	0%	0%	0%	0%	1%	0%	0%
Operation	0%	0%	0%	2%	1%	0%	1%	8%	0%	0%	0%	0%	9%	36%	0%	0%	0%	0%	100%	100%	0%	98%	99%	0%
Other	7%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	5%	25%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	100%	0%	0%	0%	100%	0%	0%	100%
Weather/Fire/Earthquake	23%	26%	0%	0%	0%	0%	78%	26%	78%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving Rosemead

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
WHITMORE(16KV) - Customers: 864	324.8	1.9	0.6	296.4	2.3	2.4	203.1	1.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	0.0	7.6	0.6	0.0	7.6	0.6	1.0
3rd Party	0%	0%	0%	6%	44%	41%	92%	96%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	100%	100%	100%	0%	0%	0%	6%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	2%	44%	0%	2%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	100%	100%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	100%
Weather/Fire/Earthquake	0%	0%	0%	92%	11%	59%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%