



Circuit Reliability Review

Orange District 1

January 2017

Providing Safe, Reliable, and Affordable Power

Southern California Edison is modernizing the power grid to meet the changing needs and expectations of our customers and to help California achieve its clean energy goals.

We are investing more than \$12 billion into our power grid between 2015 – 2017 with the goal of increasing power reliability through significant upgrades. These investments include:

- Updating thousands of transmission and distribution poles
- Replacing hundreds of miles of underground cables
- Replacing hundreds of underground structures such as vaults and manholes
- Upgrading critical distribution equipment; capacitor banks, switches, and circuit breakers
- Building new distribution circuits to serve electrical demands in our communities
- Inspecting and replacing overhead conductor and equipment to improve public safety

Our investments in local communities will help ensure that customers receive safe, reliable, and affordable electricity now and in the future.

Understanding Your Reliability Report

As your electric utility, we want you to always have power when you need it. To get there, we constantly track and monitor electric outages across our service territory, and we measure our “system reliability” from this data.

The two metrics we rely on are common in the electric utility industry: the System Average Interruption Duration Index (SAIDI) and the System Average Interruption Frequency Index (SAIFI). Both are described in more detail on the next page.

Replacing and upgrading our infrastructure will help SCE maintain or improve SAIDI and SAIFI measurements.

This report provides historical reliability data for the circuits that serve your jurisdiction and our proposed infrastructure upgrades for the current year.

To view other reliability reports, visit [sce.com>Outage Center>Maintaining Reliable Service](https://sce.com/OutageCenter/MaintainingReliableService)

Reliability Metrics

MOMENTARY OUTAGES:

OUTAGES LASTING 5 MINUTES OR LESS

MAIFI:

- The number of times the average customer is interrupted by Momentary outages each year.

SUSTAINED OUTAGES:

OUTAGES LASTING LONGER THAN 5 MINUTES

SAIFI:

- The number of times the average customer is interrupted by Sustained outages each year.

SAIDI:

- The cumulative amount of time the average customer is interrupted by Sustained outages each year.

Orange County District 1 – Santa Ana and Huntington Beach Districts

Fountain Valley

Garden Grove

Orange County

Santa Ana

Westminster

Reliability by SCE District (No Exclusions)

District Name	2012				2013				2014				2015				2016			
	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking
ANTELOPE VALLEY	78.60	28	0.56	31	94.42	22	0.62	31	51.05	35	0.59	34	104.34	22	0.68	30	107.67	24	0.87	29
ARROWHEAD	129.58	13	1.31	7	180.59	7	1.39	8	193.25	5	1.59	5	362.61	4	3.97	1	659.46	3	2.85	5
BARSTOW	184.80	7	1.15	12	204.33	6	1.40	7	201.53	4	1.34	10	187.11	8	1.17	12	134.83	18	1.35	9
BIG CREEK	1184.25	1	4.52	1	176.51	8	3.08	1	920.25	1	1.34	11	422.77	2	3.42	2	1062.01	2	4.99	1
BISHOP	463.09	2	1.25	9	104.44	17	0.51	35	118.79	17	0.59	35	298.11	6	2.22	4	168.59	8	1.22	14
BLYTHE	225.88	6	1.53	3	483.13	1	1.38	9	707.54	2	2.42	2	427.00	1	1.52	7	396.38	5	2.71	6
CATALINA	78.46	30	0.72	29	105.94	16	2.97	2	97.02	24	4.17	1	42.56	35	2.25	3	65.01	35	3.66	3
COVINA	108.73	19	0.92	19	100.51	19	0.86	20	91.60	27	0.87	22	100.08	23	0.81	25	112.13	22	0.97	24
DOMINGUEZ HILLS	117.22	18	0.82	24	89.17	26	0.80	21	82.30	29	0.71	28	130.63	15	0.97	17	146.38	12	1.11	17
FOOTHILL	91.69	25	0.90	20	85.80	27	0.79	24	93.35	25	0.93	21	109.64	20	0.95	20	142.81	14	1.03	21
FULLERTON	68.99	33	0.42	35	90.57	25	0.79	22	82.23	30	0.72	27	76.59	29	0.67	31	92.72	30	0.76	34
HUNTINGTON BEACH	95.78	23	0.89	21	66.51	32	0.68	29	79.61	31	0.78	25	98.32	25	0.95	19	128.02	20	1.26	12
KERNVILLE	226.76	5	1.31	6	232.18	4	1.96	3	178.69	8	1.99	3	286.38	7	0.96	18	2421.32	1	3.67	2
LONG BEACH	75.83	31	0.55	33	75.11	30	0.70	28	66.33	34	0.61	32	164.46	9	0.89	23	135.16	17	0.86	31
MENIFEE	99.32	22	0.84	23	107.39	15	1.26	10	156.68	11	1.32	12	111.46	19	0.98	16	156.75	9	1.31	10
MONROVIA	108.11	20	1.13	15	99.12	20	1.02	16	133.32	14	1.16	16	96.68	26	0.88	24	116.57	21	0.84	32
MONTEBELLO	131.06	12	1.13	14	118.08	13	1.17	12	158.34	10	1.16	15	150.28	12	1.18	11	133.52	19	1.17	15
ONTARIO	93.09	24	0.87	22	77.39	29	0.79	23	97.91	23	1.00	19	94.04	27	0.74	27	105.07	27	0.93	27
PALM SPRINGS	175.92	8	1.27	8	112.80	14	0.77	25	107.04	20	0.71	29	99.54	24	0.80	26	107.58	25	1.07	19
REDLANDS	120.13	16	1.11	16	96.48	21	1.04	15	154.25	12	1.04	18	124.52	17	1.01	14	137.11	16	0.98	23
RIDGECREST	229.65	4	1.44	4	161.95	9	1.12	13	176.84	9	1.57	6	148.90	13	1.01	15	254.31	6	1.05	20
SADDLEBACK	83.01	27	0.73	27	70.69	31	0.53	34	99.07	22	0.74	26	46.03	34	0.39	35	65.99	34	0.65	35
SAN JOAQUIN	135.90	10	1.04	18	244.44	2	1.45	6	138.25	13	1.17	14	127.50	16	1.05	13	108.44	23	1.09	18
SANTA ANA	78.60	29	0.55	32	93.35	24	0.74	26	91.68	26	0.84	23	67.46	32	0.71	29	97.27	29	1.00	22
SANTA BARBARA	153.81	9	1.15	13	82.00	28	0.70	27	183.78	7	1.38	9	152.37	11	1.52	6	156.66	10	1.41	8
SANTA MONICA	101.69	21	0.79	25	122.78	12	1.00	17	110.76	19	0.99	20	75.41	30	0.62	32	91.08	31	0.95	26
SOUTH BAY	122.68	15	1.17	10	142.15	10	1.49	5	125.28	16	1.39	8	164.07	10	1.31	8	183.90	7	1.88	7
TEHACHAPI	117.96	17	1.43	5	232.67	3	1.12	14	130.70	15	1.29	13	298.96	5	1.21	9	97.29	28	1.13	16
THOUSAND OAKS	127.73	14	1.05	17	93.86	23	0.91	18	104.37	21	1.10	17	106.59	21	0.92	21	143.78	13	1.31	11
VALENCIA	62.01	35	0.46	34	51.04	34	0.53	33	79.23	32	0.61	33	72.27	31	0.61	33	105.09	26	0.97	25
VENTURA	134.81	11	1.15	11	100.52	18	1.21	11	183.79	6	1.65	4	148.85	14	1.19	10	150.41	11	1.24	13
VICTORVILLE	67.70	34	0.66	30	61.33	33	0.63	30	68.85	33	0.63	31	87.03	28	0.91	22	79.35	33	0.92	28
WHITTIER	72.60	32	0.74	26	135.04	11	0.86	19	87.60	28	0.70	30	114.52	18	0.73	28	137.34	15	0.81	33
WILDOMAR	88.54	26	0.72	28	40.51	35	0.56	32	118.49	18	0.81	24	52.70	33	0.60	34	84.01	32	0.87	30
YUCCA VALLEY	319.82	3	3.41	2	216.97	5	1.50	4	304.25	3	1.49	7	389.08	3	1.80	5	463.68	4	3.39	4
SCE SystemWide	108.13		0.89		102.61		0.91		112.00		0.96		114.83		0.92		134.48		1.10	

Exclusions are days which utilities are allowed to remove from their metrics because the outages on those days were caused by a severe acts of nature.

**In the columns showing "Rank," lower numbers indicate poorer performance.

Overview of Orange District 1


There are 17 circuits that serve Orange District 1

Circuit Type	Sum of Customers	Circuit Type	Sum of Customers	Circuit Type	Sum of Customers	Circuit Type	Sum of Customers
CALLA(12KV)	934						
EXPLORER(12KV)	222						
HAWK(12KV)	2,504						
JEROME(12KV)	1,740						
JOPLIN(12KV)	2,824						
LAKERS(12KV)	1,682						
LISA ANNE(12KV)	1,466						
MELISSA(12KV)	1,582						
MIDWAY(4.16KV)	441						
PARROT(12KV)	869						
PELICAN(12KV)	106						
RAVEN(12KV)	1,239						
RUTH(12KV)	920						
SONICS(12KV)	3,608						
TITTLE(12KV)	3,074						
WILLETS(12KV)	2,391						

Drag


Grand Total 25,602

Reliability History of Circuits Serving Orange District 1 (No Exclusions)



Causes of Repair Outages in Orange District 1 Circuits 2016 YTD


Contributions to SAIDI by Outage Cause



SAIDI = the cumulative amount of time the average customer is interrupted by “sustained” outages each year.

Causes of Repair Outages in Orange District 1 Circuits 2016 YTD

Contributions to SAIFI by Outage Cause




SAIFI = the number of times the average customer is interrupted by “sustained” outages each year.

Orange County District 1 Unincorporated Areas 2017 All Circuits

- Unincorporated County Area
 Supervisory District
Distribution Circuit
 — GALLA
 — EXP. ORER
 — ANK
 — ABORLE
 — LD LUN
 — AKTER
 — SAANNE
 — KEBISA
 — KILWAY
 — KKKO
 — KELLCA
 — KACN
 — KULTI
 — KODICS
 — KITTIF
 — KILLET

Disclaimer: This report is intended solely for informational purposes. The information included is reflective as of January 1, 2017 and is subject to change without further notice.




Date: 1/31/2017
File Name: SUPER_AC_DDv8.mxd

Features depicted herein are showing, with accuracy, are intended for informational purposes only. Distribution and accuracy may be distorted at its scale. Always consult with the proper legal authorities or engineering professionals for accurate information. Always consult with the proper legal authorities or engineering professionals for accurate information. Always consult with the proper legal authorities or engineering professionals for accurate information. Always consult with the proper legal authorities or engineering professionals for accurate information.



- Replacement/Equipment Upgrade (Transmission)
 - ✕ Pole Replacement

Disclaimer: This report is intended solely for informational purposes. The information included is reflective as of January 1, 2017 and is subject to change without further notice.



Date: 2/2/2017
File Name: SUPER_CIP_Orange.mxd

Feature depicted herein are planning view accuracy and intended for informational purposes only.
Distances and locations may be distorted at this scale. Always consult with the proper legal authorities or agencies regarding such features. Real Estate is important.
Tanner Bros. Maps is a registered trademark of Tanner, Mulhally & Company.
Reproduced with permission granted by Tanner Mulhally & Company. © Tanner Mulhally & Company.
All rights reserved.
Survey Labels: Credit: Content may include National Geographic's current map policy.
Source: National Geographic, City of Phoenix, IRTG, LUP, WACB, JAGS, JAGA, TPA, NCTI.



Back-up Slides

Reliability Histories of Circuits Serving Orange District 1

Updated through Year-End 2016

Average Reliability of 17 Circuits Serving Orange District 1

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
Orange District 1	71.3	0.9	1.3	125.4	1.3	1.4	123.0	1.2	2.0	48.2	0.5	0.2	30.2	0.3	0.4	21.4	0.2	0.4	19.8	0.1	0.4	119.6	1.2	1.4
3rd Party	47%	56%	62%	20%	23%	26%	39%	33%	33%	1%	2%	0%	35%	45%	65%	86%	94%	31%	14%	24%	56%	27%	32%	44%
Equipment Failure	37%	21%	9%	56%	39%	22%	39%	55%	13%	6%	1%	0%	13%	4%	0%	13%	4%	23%	58%	16%	0%	18%	4%	7%
Operation	7%	7%	3%	9%	11%	9%	20%	11%	21%	3%	13%	49%	7%	1%	0%	1%	1%	0%	19%	46%	11%	6%	12%	10%
Other	0%	0%	0%	5%	1%	8%	0%	0%	7%	22%	73%	0%	34%	47%	0%	0%	0%	38%	0%	0%	25%	17%	45%	19%
Vegetation/Animal	3%	10%	19%	8%	20%	21%	0%	0%	13%	0%	0%	0%	11%	3%	35%	0%	0%	9%	0%	0%	0%	3%	1%	12%
Weather/Fire/Earthquake	6%	5%	6%	2%	4%	14%	1%	1%	13%	67%	11%	51%	0%	0%	0%	0%	0%	0%	9%	14%	8%	28%	6%	9%
SCE Systemwide	102.6	0.9	1.2	112.0	1.0	1.4	114.8	0.9	1.4	40.5	0.3	0.4	34.8	0.3	0.4	29.4	0.2	0.3	29.8	0.3	0.4	134.5	1.1	1.6

Notes:

No outages are excluded from the metrics.

Outage Causes:

Other: e.g., patrolled but no cause could be found

Operations: e.g., urgent maintenance w/o 3-day notice to customers

3rd Party: e.g., balloons, car hit pole, dig-in

Vegetation/Animal: e.g., tree branch, rodent, or bird causing short circuit across conductors

SAIDI (minutes) = the cumulative amount of time the average customer is interrupted by "sustained" (longer than 5 minutes) outages.

SAIFI (interruptions) = the number of times the average customer is interrupted by "sustained" outages.

MAIFI (interruptions) = the number of times the average customer is interrupted by "momentary" (lasting 5 minutes or less) outages.

Reliability Histories for Individual Circuits Serving Orange District 1

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
CALLA(12KV) - Customers: 934	97.07	1.14	-	350.07	3.44	0.99	43.67	0.14	4.99	0.87	0.01	-	11.98	1.16	1.16	-	-	1.16	-	-	-	12.85	1.17	2.32
3rd Party	44%	11%	-	45%	59%	99%	-	-	20%	-	-	-	87%	100%	100%	-	-	-	-	-	-	81%	99%	50%
Equipment Failure	53%	89%	-	26%	7%	1%	57%	35%	20%	-	-	-	-	-	-	-	-	100%	-	-	-	-	-	50%
Operation	3%	1%	-	13%	29%	-	11%	20%	-	100%	100%	-	-	-	-	-	-	-	-	-	-	7%	1%	-
Other	-	-	-	15%	4%	-	-	-	-	-	-	-	13%	0%	-	-	-	-	-	-	-	12%	0%	-
Vegetation/Animal	0%	0%	-	1%	0%	-	-	-	20%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Weather/Fire/Earthquake	-	-	-	-	-	-	32%	45%	40%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
EXPLORER(12KV) - Customers: 222	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3rd Party	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Equipment Failure	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Operation	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Other	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Vegetation/Animal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Weather/Fire/Earthquake	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
HAWK(12KV) - Customers: 2,504	84.29	0.33	1.73	74.83	0.70	-	15.13	1.04	1.00	-	-	-	16.07	0.05	-	-	-	-	34.37	0.06	-	50.44	0.11	-
3rd Party	86%	97%	43%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Equipment Failure	14%	3%	57%	100%	100%	-	-	-	-	-	-	-	97%	87%	-	-	-	-	84%	50%	-	88%	66%	-
Operation	-	-	-	0%	0%	-	100%	100%	100%	-	-	-	3%	13%	-	-	-	-	16%	50%	-	12%	34%	-
Other	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Vegetation/Animal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Weather/Fire/Earthquake	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
JEROME(12KV) - Customers: 1,740	55.69	1.10	-	344.44	2.04	2.88	68.00	1.07	-	19.58	1.22	-	-	-	0.92	-	-	-	-	-	-	19.58	1.22	0.92
3rd Party	-	-	-	-	-	-	85%	93%	-	-	-	-	-	-	100%	-	-	-	-	-	-	-	-	100%
Equipment Failure	72%	7%	-	100%	100%	65%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Operation	2%	1%	-	-	-	-	15%	7%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Other	-	-	-	-	-	35%	-	-	-	100%	100%	-	-	-	-	-	-	-	-	-	-	100%	100%	-
Vegetation/Animal	26%	93%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Weather/Fire/Earthquake	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Reliability Histories for Individual Circuits Serving Orange District 1

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
JOPLIN(12KV) - Customers: 2,824	50.13	1.21	2.00	75.54	2.03	0.95	54.64	0.14	1.91	42.21	0.87	-	21.59	0.03	-	0.19	0.00	-	7.40	0.03	1.05	71.40	0.93	1.05
3rd Party	69%	91%	100%	-	-	-	5%	26%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Equipment Failure	9%	2%	-	44%	50%	-	44%	46%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Operation	22%	7%	-	4%	0%	-	49%	26%	100%	4%	3%	-	100%	100%	-	100%	100%	-	-	-	-	33%	6%	-
Other	-	-	-	1%	1%	-	3%	3%	-	96%	97%	-	-	-	-	-	-	-	-	-	100%	56%	91%	100%
Vegetation/Animal	-	-	-	51%	49%	100%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Weather/Fire/Earthquake	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	100%	100%	-	10%	3%	-
LAKERS(12KV) - Customers: 1,682	14.04	0.12	-	35.71	0.15	0.97	101.14	0.97	0.21	43.12	1.08	-	-	-	-	2.78	0.03	-	-	-	-	45.90	1.11	-
3rd Party	-	-	-	37%	19%	100%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Equipment Failure	91%	95%	-	45%	20%	-	92%	93%	100%	65%	7%	-	-	-	-	-	-	-	-	-	-	61%	7%	-
Operation	9%	5%	-	19%	61%	-	8%	7%	-	-	-	-	-	-	-	100%	100%	-	-	-	-	6%	3%	-
Other	-	-	-	-	-	-	-	-	-	35%	93%	-	-	-	-	-	-	-	-	-	-	33%	90%	-
Vegetation/Animal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Weather/Fire/Earthquake	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
LISA ANNE(12KV) - Customers: 1,466	18.63	0.33	0.74	11.61	0.03	1.01	408.68	2.37	1.30	-	-	-	-	-	-	5.46	0.01	-	18.81	0.34	1.66	24.26	0.35	1.66
3rd Party	-	-	-	-	-	100%	12%	42%	77%	-	-	-	-	-	-	-	-	-	-	-	60%	-	-	60%
Equipment Failure	69%	13%	-	100%	100%	-	13%	42%	-	-	-	-	-	-	-	100%	100%	-	-	-	-	22%	3%	-
Operation	31%	87%	100%	-	-	-	75%	16%	23%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Other	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Vegetation/Animal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Weather/Fire/Earthquake	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	100%	100%	40%	78%	97%	40%
MELISSA(12KV) - Customers: 1,582	-	-	-	155.58	3.11	-	166.98	3.05	2.86	-	-	-	248.46	2.08	0.63	-	-	-	6.52	0.02	2.00	254.98	2.11	2.63
3rd Party	-	-	-	-	-	-	-	-	35%	-	-	-	65%	48%	100%	-	-	-	100%	100%	100%	66%	49%	100%
Equipment Failure	-	-	-	71%	34%	-	98%	98%	30%	-	-	-	3%	3%	-	-	-	-	-	-	-	3%	3%	-
Operation	-	-	-	4%	2%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Other	-	-	-	-	-	-	-	-	-	-	-	-	29%	48%	-	-	-	-	-	-	-	28%	47%	-
Vegetation/Animal	-	-	-	5%	32%	-	2%	2%	35%	-	-	-	3%	2%	-	-	-	-	-	-	-	3%	2%	-
Weather/Fire/Earthquake	-	-	-	19%	32%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Reliability Histories for Individual Circuits Serving Orange District 1

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
MIDWAY(4.16KV) - Customers: 441	609.10	2.00	-	-	-	1.00	550.71	0.99	-	14.75	0.98	-	-	-	-	16.57	0.06	1.00	-	-	-	31.32	1.05	1.00
3rd Party	5%	50%	-	-	-	100%	100%	100%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Equipment Failure	95%	50%	-	-	-	-	-	-	-	-	-	-	-	-	-	100%	100%	-	-	-	-	53%	6%	-
Operation	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Other	-	-	-	-	-	-	-	-	-	100%	100%	-	-	-	-	-	100%	-	-	-	-	47%	94%	100%
Vegetation/Animal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Weather/Fire/Earthquake	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
PARROT(12KV) - Customers: 869	-	-	1.00	195.13	2.01	0.99	107.03	1.05	0.97	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3rd Party	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Equipment Failure	-	-	100%	100%	100%	100%	92%	99%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Operation	-	-	-	-	-	-	8%	1%	100%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Other	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Vegetation/Animal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Weather/Fire/Earthquake	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
PELICAN(12KV) - Customers: 106	-	-	0.97	-	-	-	-	-	-	-	-	-	-	-	-	0.32	0.06	-	185.21	1.01	-	185.53	1.07	-
3rd Party	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Equipment Failure	-	-	100%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Operation	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	100%	100%	-	100%	100%	-	100%	100%	-
Other	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Vegetation/Animal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Weather/Fire/Earthquake	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
RAVEN(12KV) - Customers: 1,239	89.14	1.07	1.00	1.17	0.01	-	-	-	-	-	-	-	0.20	0.01	1.25	1.10	0.01	-	5.37	0.07	1.23	6.67	0.09	2.48
3rd Party	-	-	-	-	-	-	-	-	-	-	-	-	-	-	99%	-	-	-	-	-	-	-	-	50%
Equipment Failure	-	-	100%	18%	33%	-	-	-	-	-	-	-	-	-	-	100%	100%	-	-	-	-	16%	10%	-
Operation	100%	100%	-	82%	67%	-	-	-	-	-	-	-	100%	100%	1%	-	-	-	100%	100%	100%	84%	90%	50%
Other	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Vegetation/Animal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Weather/Fire/Earthquake	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Reliability Histories for Individual Circuits Serving Orange District 1

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
RUTH(12KV) - Customers: 920	-	-	1.00	3.44	0.11	1.00	58.41	1.06	1.00	-	-	-	-	-	-	-	-	1.00	122.61	1.08	2.02	122.61	1.08	3.02
3rd Party	-	-	100%	-	-	-	-	-	100%	-	-	-	-	-	-	-	-	-	56%	93%	96%	56%	93%	64%
Equipment Failure	-	-	-	-	-	-	91%	94%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Operation	-	-	-	100%	100%	-	-	-	-	-	-	-	-	-	-	-	-	-	44%	7%	4%	44%	7%	2%
Other	-	-	-	-	-	100%	9%	6%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Vegetation/Animal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	100%	-	-	-	-	-	-	33%
Weather/Fire/Earthquake	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
SONICS(12KV) - Customers: 3,608	165.48	2.61	1.73	28.77	0.10	-	82.05	1.05	1.00	32.44	1.01	-	69.95	0.81	0.94	103.36	1.01	1.90	65.70	0.15	-	271.46	2.99	2.84
3rd Party	79%	87%	100%	-	-	-	-	-	100%	-	-	-	-	-	-	94%	99%	48%	-	-	-	36%	33%	32%
Equipment Failure	16%	7%	-	29%	54%	-	82%	98%	-	10%	1%	-	8%	3%	-	6%	1%	-	100%	98%	-	30%	7%	-
Operation	5%	6%	-	71%	46%	-	18%	2%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Other	-	-	-	-	-	-	-	-	-	90%	99%	-	61%	89%	-	-	-	52%	0%	2%	-	27%	58%	35%
Vegetation/Animal	-	-	-	-	-	-	-	-	-	-	-	-	31%	8%	100%	-	-	-	-	-	-	8%	2%	33%
Weather/Fire/Earthquake	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TITTLE(12KV) - Customers: 3,074	63.73	0.51	4.54	82.55	1.21	5.42	88.46	1.10	4.00	270.06	0.93	1.40	8.44	0.02	-	52.98	0.53	-	-	-	-	331.48	1.48	1.40
3rd Party	17%	13%	43%	47%	36%	19%	56%	91%	50%	-	-	-	-	-	-	81%	91%	-	-	-	-	13%	32%	-
Equipment Failure	22%	4%	-	16%	7%	19%	32%	5%	-	3%	0%	-	100%	100%	-	19%	9%	-	-	-	-	8%	5%	-
Operation	2%	1%	-	-	-	18%	9%	3%	25%	2%	51%	49%	-	-	-	0%	0%	-	-	-	-	1%	32%	49%
Other	-	-	-	-	-	-	2%	0%	25%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Vegetation/Animal	9%	12%	43%	37%	57%	26%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Weather/Fire/Earthquake	50%	70%	14%	-	-	18%	-	-	-	96%	49%	51%	-	-	-	-	-	-	-	-	-	78%	31%	51%
WILLETS(12KV) - Customers: 2,391	14.89	0.11	-	112.80	0.24	0.97	379.25	2.80	1.99	15.59	0.19	-	3.66	0.01	-	-	-	-	5.14	0.64	-	24.39	0.84	-
3rd Party	-	-	-	-	-	-	76%	40%	-	49%	49%	-	-	-	-	-	-	-	-	-	-	31%	11%	-
Equipment Failure	10%	62%	-	69%	42%	-	23%	60%	50%	-	-	-	100%	100%	-	-	-	-	-	-	-	15%	1%	-
Operation	77%	17%	-	19%	49%	-	1%	0%	-	51%	51%	-	-	-	-	-	-	-	100%	100%	-	54%	88%	-
Other	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Vegetation/Animal	-	-	-	-	-	-	0%	0%	50%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Weather/Fire/Earthquake	13%	21%	-	12%	9%	100%	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-