



Circuit Reliability Review

Lawndale

January 2017

Providing Safe, Reliable, and Affordable Power

Southern California Edison is modernizing the power grid to meet the changing needs and expectations of our customers and to help California achieve its clean energy goals.

We are investing more than \$12 billion into our power grid between 2015 – 2017 with the goal of increasing power reliability through significant upgrades. These investments include:

- Updating thousands of transmission and distribution poles
- Replacing hundreds of miles of underground cables
- Replacing hundreds of underground structures such as vaults and manholes
- Upgrading critical distribution equipment; capacitor banks, switches, and circuit breakers
- Building new distribution circuits to serve electrical demands in our communities
- Inspecting and replacing overhead conductor and equipment to improve public safety

Our investments in local communities will help ensure that customers receive safe, reliable, and affordable electricity now and in the future.

Understanding Your Reliability Report

As your electric utility, we want you to always have power when you need it. To get there, we constantly track and monitor electric outages across our service territory, and we measure our “system reliability” from this data.

The two metrics we rely on are common in the electric utility industry: the System Average Interruption Duration Index (SAIDI) and the System Average Interruption Frequency Index (SAIFI). Both are described in more detail on the next page.

Replacing and upgrading our infrastructure will help SCE maintain or improve SAIDI and SAIFI measurements.

This report provides historical reliability data for the circuits that serve your jurisdiction and our proposed infrastructure upgrades for the current year.

To view other reliability reports, visit [sce.com>Outage Center>Maintaining Reliable Service](https://sce.com/Outage-Center/Maintaining-Reliable-Service)

Reliability Metrics

MOMENTARY OUTAGES:

OUTAGES LASTING 5 MINUTES OR LESS

MAIFI:

- The number of times the average customer is interrupted by Momentary outages each year.

SUSTAINED OUTAGES:

OUTAGES LASTING LONGER THAN 5 MINUTES

SAIFI:

- The number of times the average customer is interrupted by Sustained outages each year.

SAIDI:

- The cumulative amount of time the average customer is interrupted by Sustained outages each year.

Cities in the South Bay District

Alondra Park

Del Aire

El Segundo

Gardena

Hawthorne

Hermosa Beach

Inglewood

Ladera Heights

Lawndale

Lennox

Lomita

Los Angeles

Manhattan Beach

Palos Verdes Estates

Rancho Palos Verdes

Redondo Beach

Rolling Hills

Rolling Hills Estates

Torrance

View Park-Windsor Hills

West Athens

Westmont

Reliability by SCE District (No Exclusions)

District Name	2012				2013				2014				2015				2016			
	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking	District SAIDI	SAIDI RANKING	District SAIFI	SAIFI Ranking
ANTELOPE VALLEY	78.60	28	0.56	31	94.42	22	0.62	31	51.05	35	0.59	34	104.34	22	0.68	30	107.67	24	0.87	29
ARROWHEAD	129.58	13	1.31	7	180.59	7	1.39	8	193.25	5	1.59	5	362.61	4	3.97	1	659.46	3	2.85	5
BARSTOW	184.80	7	1.15	12	204.33	6	1.40	7	201.53	4	1.34	10	187.11	8	1.17	12	134.83	18	1.35	9
BIG CREEK	1184.25	1	4.52	1	176.51	8	3.08	1	920.25	1	1.34	11	422.77	2	3.42	2	1062.01	2	4.99	1
BISHOP	463.09	2	1.25	9	104.44	17	0.51	35	118.79	17	0.59	35	298.11	6	2.22	4	168.59	8	1.22	14
BLYTHE	225.88	6	1.53	3	483.13	1	1.38	9	707.54	2	2.42	2	427.00	1	1.52	7	396.38	5	2.71	6
CATALINA	78.46	30	0.72	29	105.94	16	2.97	2	97.02	24	4.17	1	42.56	35	2.25	3	65.01	35	3.66	3
COVINA	108.73	19	0.92	19	100.51	19	0.86	20	91.60	27	0.87	22	100.08	23	0.81	25	112.13	22	0.97	24
DOMINGUEZ HILLS	117.22	18	0.82	24	89.17	26	0.80	21	82.30	29	0.71	28	130.63	15	0.97	17	146.38	12	1.11	17
FOOTHILL	91.69	25	0.90	20	85.80	27	0.79	24	93.35	25	0.93	21	109.64	20	0.95	20	142.81	14	1.03	21
FULLERTON	68.99	33	0.42	35	90.57	25	0.79	22	82.23	30	0.72	27	76.59	29	0.67	31	92.72	30	0.76	34
HUNTINGTON BEACH	95.78	23	0.89	21	66.51	32	0.68	29	79.61	31	0.78	25	98.32	25	0.95	19	128.02	20	1.26	12
KERNVILLE	226.76	5	1.31	6	232.18	4	1.96	3	178.69	8	1.99	3	286.38	7	0.96	18	2421.32	1	3.67	2
LONG BEACH	75.83	31	0.55	33	75.11	30	0.70	28	66.33	34	0.61	32	164.46	9	0.89	23	135.16	17	0.86	31
MENIFEE	99.32	22	0.84	23	107.39	15	1.26	10	156.68	11	1.32	12	111.46	19	0.98	16	156.75	9	1.31	10
MONROVIA	108.11	20	1.13	15	99.12	20	1.02	16	133.32	14	1.16	16	96.68	26	0.88	24	116.57	21	0.84	32
MONTEBELLO	131.06	12	1.13	14	118.08	13	1.17	12	158.34	10	1.16	15	150.28	12	1.18	11	133.52	19	1.17	15
ONTARIO	93.09	24	0.87	22	77.39	29	0.79	23	97.91	23	1.00	19	94.04	27	0.74	27	105.07	27	0.93	27
PALM SPRINGS	175.92	8	1.27	8	112.80	14	0.77	25	107.04	20	0.71	29	99.54	24	0.80	26	107.58	25	1.07	19
REDLANDS	120.13	16	1.11	16	96.48	21	1.04	15	154.25	12	1.04	18	124.52	17	1.01	14	137.11	16	0.98	23
RIDGECREST	229.65	4	1.44	4	161.95	9	1.12	13	176.84	9	1.57	6	148.90	13	1.01	15	254.31	6	1.05	20
SADDLEBACK	83.01	27	0.73	27	70.69	31	0.53	34	99.07	22	0.74	26	46.03	34	0.39	35	65.99	34	0.65	35
SAN JOAQUIN	135.90	10	1.04	18	244.44	2	1.45	6	138.25	13	1.17	14	127.50	16	1.05	13	108.44	23	1.09	18
SANTA ANA	78.60	29	0.55	32	93.35	24	0.74	26	91.68	26	0.84	23	67.46	32	0.71	29	97.27	29	1.00	22
SANTA BARBARA	153.81	9	1.15	13	82.00	28	0.70	27	183.78	7	1.38	9	152.37	11	1.52	6	156.66	10	1.41	8
SANTA MONICA	101.69	21	0.79	25	122.78	12	1.00	17	110.76	19	0.99	20	75.41	30	0.62	32	91.08	31	0.95	26
SOUTH BAY	122.68	15	1.17	10	142.15	10	1.49	5	125.28	16	1.39	8	164.07	10	1.31	8	183.90	7	1.88	7
TEHACHAPI	117.96	17	1.43	5	232.67	3	1.12	14	130.70	15	1.29	13	298.96	5	1.21	9	97.29	28	1.13	16
THOUSAND OAKS	127.73	14	1.05	17	93.86	23	0.91	18	104.37	21	1.10	17	106.59	21	0.92	21	143.78	13	1.31	11
VALENCIA	62.01	35	0.46	34	51.04	34	0.53	33	79.23	32	0.61	33	72.27	31	0.61	33	105.09	26	0.97	25
VENTURA	134.81	11	1.15	11	100.52	18	1.21	11	183.79	6	1.65	4	148.85	14	1.19	10	150.41	11	1.24	13
VICTORVILLE	67.70	34	0.66	30	61.33	33	0.63	30	68.85	33	0.63	31	87.03	28	0.91	22	79.35	33	0.92	28
WHITTIER	72.60	32	0.74	26	135.04	11	0.86	19	87.60	28	0.70	30	114.52	18	0.73	28	137.34	15	0.81	33
WILDOMAR	88.54	26	0.72	28	40.51	35	0.56	32	118.49	18	0.81	24	52.70	33	0.60	34	84.01	32	0.87	30
YUCCA VALLEY	319.82	3	3.41	2	216.97	5	1.50	4	304.25	3	1.49	7	389.08	3	1.80	5	463.68	4	3.39	4
SCE SystemWide	108.13		0.89		102.61		0.91		112.00		0.96		114.83		0.92		134.48		1.10	

Exclusions are days which utilities are allowed to remove from their metrics because the outages on those days were caused by a severe acts of nature.

**In the columns showing "Rank," lower numbers indicate poorer performance.


Overview of Lawndale

There are 15 circuits that serve Lawndale

Circuit Type	Sum of Customers	Circuit Type	Sum of Customers	Circuit Type	Sum of Customers	Circuit Type	Sum of Customers
ALBACORE(16KV)	1,756						
BLOSSOM(16KV)	1,701						
BLUEGILL(16KV)	3,197						
DEBORAH(16KV)	2,712						
FLYWHEEL(16KV)	1,565						
FREEMAN(4.16KV)	1,231						
GRAVEYARD(16KV)	1,395						
KORNBLUM(4.16KV)	977						
ROSEMARY(4.16KV)	1,161						
SHOUP(4.16KV)	936						
SUTRO(4.16KV)	623						
TALENT(4.16KV)	543						
TRANSPLANT(4.16KV)	1,497						
WHALE(16KV)	751						
ZEBRA(16KV)	2,063						


Grand Total 22,108

Reliability History of Circuits Serving Lawndale (No Exclusions)



Causes of Repair Outages in Lawndale Circuits 2016 YTD


Contributions to SAIDI by Outage Cause



SAIDI = the cumulative amount of time the average customer is interrupted by “sustained” outages each year.

Causes of Repair Outages in Lawndale Circuits 2016 YTD

Contributions to SAIFI by Outage Cause



SAIFI = the number of times the average customer is interrupted by “sustained” outages each year.



Back-up Slides

Reliability Histories of Circuits Serving Lawndale

Updated through Year-End 2016

Average Reliability of 15 Circuits Serving Lawndale

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
Lawndale	93.4	1.2	0.9	308.4	2.5	1.1	141.7	1.5	1.2	18.2	0.2	0.7	45.5	1.1	1.0	6.8	0.2	0.1	37.7	0.5	0.5	108.2	2.0	2.2
3rd Party	43%	31%	30%	5%	3%	0%	5%	13%	37%	1%	0%	10%	70%	20%	26%	0%	0%	100%	6%	11%	31%	32%	13%	25%
Equipment Failure	41%	43%	28%	41%	33%	26%	57%	36%	7%	52%	67%	10%	8%	30%	3%	60%	25%	0%	53%	39%	11%	34%	36%	7%
Operation	15%	17%	4%	4%	3%	14%	15%	25%	2%	3%	1%	0%	7%	4%	0%	2%	1%	0%	20%	46%	27%	10%	14%	6%
Other	0%	0%	0%	12%	33%	30%	8%	10%	22%	2%	2%	9%	0%	0%	39%	0%	0%	0%	0%	0%	11%	0%	0%	22%
Vegetation/Animal	1%	9%	38%	6%	14%	12%	11%	11%	21%	0%	0%	31%	15%	46%	32%	38%	74%	0%	0%	0%	0%	32%	23%	
Weather/Fire/Earthquake	0%	0%	0%	32%	13%	18%	4%	5%	11%	42%	29%	39%	0%	0%	0%	0%	0%	0%	21%	4%	20%	14%	4%	16%
SCE Systemwide	102.6	0.9	1.2	112.0	1.0	1.4	114.8	0.9	1.4	40.5	0.3	0.4	34.8	0.3	0.4	29.4	0.2	0.3	29.8	0.3	0.4	134.5	1.1	1.6

Notes:

No outages are excluded from the metrics.

Outage Causes:

Other: e.g., patrolled but no cause could be found

Operations: e.g., urgent maintenance w/o 3-day notice to customers

3rd Party: e.g., balloons, car hit pole, dig-in

Vegetation/Animal: e.g., tree branch, rodent, or bird causing short circuit across conductors

SAIDI (minutes) = the cumulative amount of time the average customer is interrupted by "sustained" (longer than 5 minutes) outages.

SAIFI (interruptions) = the number of times the average customer is interrupted by "sustained" outages.

MAIFI (interruptions) = the number of times the average customer is interrupted by "momentary" (lasting 5 minutes or less) outages.

Reliability Histories for Individual Circuits Serving Lawndale

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
ALBACORE(16KV) - Customers: 1,756	376.4	4.0	1.3	296.1	4.7	1.2	360.1	4.6	1.3	1.4	0.0	0.0	46.0	1.5	1.4	3.1	0.0	0.0	114.9	1.0	0.0	165.3	2.5	1.4
3rd Party	61%	34%	48%	0%	0%	0%	0%	0%	82%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	11%	19%	18%	38%	16%	18%	54%	39%	0%	34%	14%	0%	58%	36%	30%	100%	100%	0%	100%	100%	0%	88%	62%	30%
Operation	27%	28%	34%	3%	1%	0%	44%	58%	18%	66%	86%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%	0%
Other	0%	0%	0%	51%	61%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	1%	19%	0%	8%	21%	82%	2%	2%	0%	0%	0%	0%	42%	64%	70%	0%	0%	0%	0%	0%	0%	12%	38%	70%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
BLOSSOM(16KV) - Customers: 1,701	20.8	1.0	0.0	108.3	0.7	0.9	69.4	1.0	2.0	1.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	34.0	1.0	0.0	35.4	1.0	0.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	100%	100%	0%	9%	29%	0%	2%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	0%	0%	0%	91%	71%	100%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	100%	100%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	98%	98%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
BLUEGILL(16KV) - Customers: 3,197	15.3	0.3	1.0	251.2	5.7	1.1	208.8	3.4	2.9	3.9	0.5	1.5	22.0	1.0	0.0	0.5	0.0	0.0	110.2	0.3	1.0	136.6	1.8	2.5
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	100%	5%	0%	0%	11%	26%	12%	100%	100%	32%	0%	0%	0%	0%	0%	0%	48%	44%	0%	41%	35%	19%
Operation	100%	100%	0%	0%	0%	0%	13%	24%	0%	0%	0%	0%	4%	1%	0%	100%	100%	0%	3%	11%	83%	3%	3%	34%
Other	0%	0%	0%	48%	64%	72%	39%	31%	24%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	47%	35%	28%	36%	20%	30%	0%	0%	68%	96%	99%	0%	0%	0%	0%	0%	0%	0%	15%	55%	40%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	34%	0%	0%	0%	0%	0%	0%	0%	0%	0%	50%	44%	17%	40%	8%	7%
DEBORAH(16KV) - Customers: 2,712	73.4	1.0	1.0	1270.2	6.0	3.6	293.7	1.4	1.3	6.7	0.0	0.0	213.9	1.3	1.7	20.3	1.1	0.0	0.0	0.0	0.0	240.9	2.4	1.7
3rd Party	93%	99%	0%	0%	0%	0%	8%	47%	74%	0%	0%	0%	100%	100%	41%	0%	0%	0%	0%	0%	0%	89%	55%	41%
Equipment Failure	7%	1%	0%	40%	56%	27%	90%	50%	26%	86%	70%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	2%	0%	0%
Operation	0%	0%	0%	0%	0%	0%	2%	3%	0%	14%	30%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%	0%
Other	0%	0%	0%	0%	0%	28%	0%	0%	0%	0%	0%	0%	0%	0%	59%	0%	0%	0%	0%	0%	0%	0%	0%	59%
Vegetation/Animal	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	8%	45%	0%
Weather/Fire/Earthquake	0%	0%	0%	60%	44%	45%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving Lawndale

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
FLYWHEEL(16KV) - Customers: 1,565	32.0	1.0	0.0	0.0	0.0	0.0	43.6	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	31.6	1.0	0.0	31.6	1.0	0.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	0%	0%	0%	0%	0%	0%	11%	16%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Operation	100%	100%	0%	0%	0%	0%	89%	84%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	100%	100%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
FREEMAN(4.16KV) - Customers: 1,231	1.6	0.1	0.0	0.0	0.0	0.0	2.2	0.0	1.0	160.2	2.1	0.0	13.5	1.9	1.9	0.0	0.0	0.0	0.0	0.0	0.0	173.6	4.0	1.9
3rd Party	100%	100%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	50%
Equipment Failure	0%	0%	0%	0%	0%	0%	0%	0%	0%	48%	50%	0%	43%	50%	0%	0%	0%	0%	0%	0%	0%	48%	50%	0%
Operation	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	57%	50%	50%	0%	0%	0%	0%	0%	0%	4%	24%	50%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	52%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	48%	26%	0%
GRAVEYARD(16KV) - Customers: 1,395	249.4	1.9	2.0	116.7	1.8	2.2	361.3	3.0	1.0	0.6	0.0	1.9	0.0	0.0	2.0	0.0	0.0	0.0	2.1	0.0	0.0	2.7	0.0	4.0
3rd Party	0%	1%	0%	5%	4%	0%	7%	30%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	99%	97%	24%	90%	90%	60%	74%	35%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%	76%	51%	0%
Operation	0%	0%	0%	5%	5%	0%	1%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	40%	0%	0%	0%	0%	0%	50%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	50%
Vegetation/Animal	0%	2%	76%	0%	0%	0%	18%	33%	100%	100%	100%	50%	0%	0%	50%	0%	0%	0%	0%	0%	0%	24%	49%	50%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
KORNBLUM(4.16KV) - Customers: 977	249.7	2.5	1.1	143.6	0.9	0.0	53.3	1.0	1.0	0.0	0.0	0.0	73.9	3.0	2.0	72.6	1.0	0.0	0.0	0.0	0.0	146.5	4.1	2.0
3rd Party	70%	82%	50%	0%	0%	0%	99%	99%	100%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	50%
Equipment Failure	30%	18%	50%	93%	50%	0%	0%	0%	0%	0%	0%	0%	8%	33%	0%	100%	100%	0%	0%	0%	0%	54%	50%	0%
Operation	0%	0%	0%	7%	50%	0%	1%	1%	0%	0%	0%	0%	81%	34%	0%	0%	0%	0%	0%	0%	0%	41%	25%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	11%	33%	50%	0%	0%	0%	0%	0%	0%	5%	25%	50%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving Lawndale

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
ROSEMARY(4.16KV) - Customers: 1,161	129.8	2.0	2.0	171.5	2.0	1.0	2.0	0.0	3.0	0.0	0.0	0.0	90.9	1.0	3.0	0.0	0.0	1.0	54.2	2.0	3.0	145.1	3.0	7.0
3rd Party	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	99%	0%	0%	0%	100%	81%	50%	33%	93%	66%	29%
Equipment Failure	100%	100%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	13%	50%	34%	5%	33%	14%
Operation	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	100%	0%	0%	67%	0%	0%	0%	0%	0%	100%	0%	0%	0%	6%	1%	33%	2%	0%	57%
Vegetation/Animal	0%	0%	50%	0%	0%	0%	0%	0%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
SHOUP(4.16KV) - Customers: 936	0.0	0.0	0.0	565.0	1.3	0.0	28.9	0.1	1.0	5.9	0.0	0.0	13.9	2.0	2.0	13.1	0.0	0.0	0.0	0.0	0.0	32.9	2.0	2.0
3rd Party	0%	0%	0%	0%	0%	0%	32%	89%	100%	0%	0%	0%	0%	0%	50%	0%	0%	0%	0%	0%	0%	0%	0%	50%
Equipment Failure	0%	0%	0%	94%	85%	0%	68%	11%	0%	0%	0%	0%	43%	50%	0%	100%	100%	0%	0%	0%	0%	58%	50%	0%
Operation	0%	0%	0%	0%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	1%	10%	0%	0%	0%	0%	0%	0%	0%	57%	50%	50%	0%	0%	0%	0%	0%	0%	24%	49%	50%
Weather/Fire/Earthquake	0%	0%	0%	4%	3%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	18%	1%	0%
SUTRO(4.16KV) - Customers: 623	4.4	0.0	0.0	0.0	0.0	0.0	0.6	0.0	1.0	0.0	0.0	0.0	13.9	2.0	2.0	0.0	0.0	1.0	0.0	0.0	0.0	13.9	2.0	3.0
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	50%	0%	0%	100%	0%	0%	0%	0%	0%	67%
Equipment Failure	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	43%	50%	0%	0%	0%	0%	0%	0%	0%	43%	50%	0%
Operation	0%	0%	0%	0%	0%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	57%	50%	50%	0%	0%	0%	0%	0%	0%	57%	50%	33%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
TALENT(4.16KV) - Customers: 543	255.8	3.0	1.0	87.3	1.0	0.0	143.5	1.0	1.0	3.9	0.0	0.0	0.0	0.0	1.1	0.0	0.0	0.0	0.0	0.0	0.0	3.9	0.0	1.1
3rd Party	50%	33%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	50%	67%	0%	100%	100%	0%	100%	100%	0%	100%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	100%	0%
Operation	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	100%
Vegetation/Animal	0%	0%	100%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Reliability Histories for Individual Circuits Serving Lawndale

	2013			2014			2015			1st Qtr 2016			2nd Qtr 2016			3rd Qtr 2016			4th Qtr 2016			2016		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
TRANSPLANT(4.16KV) - Customers: 1,497	13.7	0.0	1.9	224.2	1.0	1.0	85.5	1.1	0.0	50.5	0.4	1.0	2.6	0.0	0.0	0.0	0.0	0.0	32.4	1.0	1.0	85.6	1.4	2.0
3rd Party	0%	0%	100%	94%	96%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	50%
Equipment Failure	38%	74%	0%	5%	3%	100%	97%	90%	0%	93%	95%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	55%	27%	0%
Operation	57%	25%	0%	0%	1%	0%	3%	10%	0%	7%	5%	0%	100%	100%	0%	0%	0%	0%	100%	100%	0%	45%	73%	0%
Other	5%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	50%
WHALE(16KV) - Customers: 751	113.1	3.0	2.0	103.8	1.0	0.0	1.1	0.0	0.0	0.0	0.0	0.0	13.9	2.0	0.0	0.0	0.0	0.0	87.5	1.0	0.0	101.4	3.0	0.0
3rd Party	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Equipment Failure	81%	67%	50%	100%	100%	0%	100%	100%	0%	0%	0%	0%	43%	50%	0%	0%	0%	0%	99%	98%	0%	91%	66%	0%
Operation	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	2%	0%	1%	1%	0%
Other	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Vegetation/Animal	18%	33%	50%	0%	0%	0%	0%	0%	0%	0%	0%	0%	57%	50%	0%	0%	0%	0%	0%	0%	0%	8%	33%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
ZEBRA(16KV) - Customers: 2,063	0.0	0.0	0.0	129.2	1.1	1.0	10.1	0.0	0.0	41.8	0.2	2.8	14.8	2.0	0.0	0.7	0.0	0.0	0.0	0.0	1.0	57.3	2.2	3.8
3rd Party	0%	0%	0%	0%	0%	0%	0%	0%	0%	5%	5%	0%	0%	0%	0%	0%	0%	0%	0%	0%	100%	4%	0%	26%
Equipment Failure	0%	0%	0%	0%	0%	0%	100%	100%	0%	14%	8%	0%	41%	50%	0%	0%	0%	0%	0%	0%	0%	21%	47%	0%
Operation	0%	0%	0%	38%	6%	100%	0%	0%	0%	0%	0%	0%	5%	0%	0%	100%	100%	0%	0%	0%	0%	3%	0%	0%
Other	0%	0%	0%	62%	94%	0%	0%	0%	0%	9%	29%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	6%	2%	0%
Vegetation/Animal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	54%	50%	0%	0%	0%	0%	0%	0%	0%	14%	46%	0%
Weather/Fire/Earthquake	0%	0%	0%	0%	0%	0%	0%	0%	0%	72%	58%	100%	0%	0%	0%	0%	0%	0%	0%	0%	0%	52%	4%	74%