


## GROUND LOADING PLAN

SCALE 1 : 500




## ROOF LOADING PLAN

SCALE 1 : 500

## LOADING NOTES

1. REFER S0.001-S0.003 FOR CONSTRUCTION NOTES
2. THE STRUCTURE HAS BEEN DESIGNED FOR THE LOADS NOMINATED ON THIS DRAWING.
3. LOADS HAVE BEEN APPLIED IN ACCORDANCE WITH 1170.1 USING SAFETY FACTORS AND PROBABILITY LOADING EVENTS.
4. LOADING IN EXCESS OF PROBABILITY LOADING EVENT WILL RESULT IN DAMAGE TO STRUCTURE REQUIRING MAINTENANCE OR REPAIR.
5. THE HYDRAULIC ENGINEER IS RESPONSIBLE FOR RESOLVING ALL HYDRULIC THRUSTING FORCES FROM PUMPS AND PIPE WORK. ANY FORCES BEING IMPOSED ON OR NEAR THE STRUCTURE THE HYDRAULIC ENGINEER MUST PROVIDE LOADING DETAILS.
6. INTERNAL WIND PRESSURE CO-EFFICIENT (Cpi)
   WAREHOUSE +0.2 -0.3
   OFFICE +0.2 -0.3
7. ALL DOORS AND WINDOWS SHALL BE DESIGNED, MANUFACTURED AND INSTALLED TO RESIST THE FOLLOWING WIND PRESSURES:
   INWARDS WIND PRESSURE: 1.25 kPa
   OUTWARDS WIND PRESSURE: 1.06 kPa
8. LOCAL PRESSURE CO-EFFICIENTS HAVE NOT BEEN APPLIED TO THE ABOVE LOADING. REFER AS1170.2

## GROUND LOADING LEGEND

1 AREA 51
7.5kPa DISTRIBUTED LOAD (750kg/m²)

2 GAME OVER
7.5kPa DISTRIBUTED LOAD (750kg/m²)

3 DRIVEWAY AND CARPARK
UNLIMTED REPETITIONS OF CARS AND VEHICLES NOT EXCEEDING 3500kg GROSS MASS

4 FOOTPATH
LIVE LOAD:
3kPa
SUPERIMPOSED DEAD LOAD:
1kPa

5 FIRE TANK
LIVE LOAD:
5kPa
SUPERIMPOSED DEAD LOAD:
60kPa

6 BUILDING SERVICE
LIVE LOAD:
5kPa
SUPERIMPOSED DEAD LOAD:
1kPa

7 TRANSFORMER
LIVE LOAD:
5kPa
SUPERIMPOSED DEAD LOAD:
1kPa

## ROOF LOADING LEGEND

10 SNOW WORLD
LIVE LOAD:
0.25kPa
SUPERIMPOSED DEAD LOAD:
0.5kPa
PLANT:
TO BE CONFIRMED
SOLAR:
0.15kPa
HAIL:
0.32kPa

11 AREA 51
LIVE LOAD:
0.25kPa
SUPERIMPOSED DEAD LOAD:
0.2kPa
PLANT:
TO BE CONFIRMED
SOLAR:
0.15kPa
HAIL:
0.32kPa

12 GAMEOVER
LIVE LOAD:
0.25kPa
SUPERIMPOSED DEAD LOAD:
0.15kPa
PLANT:
TO BE CONFIRMED
SOLAR:
0.15kPa
HAIL:
0.32kPa

13 AWNING
LIVE LOAD:
0.25kPa
SUPERIMPOSED DEAD LOAD:
0.15kPa



| DRN | AMENDMENTS | DATE | REV |
|---|---|---|---|
| NS | BAC APPROVAL | 11.06.26 | B |
| NS | PRELIM STEEL ISSUE | 29.05.26 | A |

NORTHROP
PROJECT NUMBER: 250946

| | |
|---|---|
| Drawn: HP | Checked: |
| Design Coordinated: HP | Compliance Checked: -- |
| Authorised For Issue: NS | Construction Checked: -- |

**SKYGATE PLAY**

**LOADING PLANS**


Brisbane Airport
BRISBANE AIRPORT CORPORATION PTY LTD
11 THE CIRCUIT, BRISBANE AIRPORT, QLD, 4008, AUSTRALIA
PO BOX 61, HAMILTON CENTRAL, QLD, 4007, AUSTRALIA
T: +61 7 3406 3000
E: INFO@BNE.COM.AU
W: BNE.COM.AU


Scale: As indicated
Size: A1
Revision: B

| Drawing Number | Project No. | Originator | Volume | Level | Type | Discipline | Number |
|---|---|---|---|---|---|---|---|
| | 25021 | NOR | XX | 01 | DR | ST | 000021 |


File Path: Autodesk Docs://250946 - BNE Play/25021-NOR-ZZ-ZZ-M3-ST-000001.rvt
Plot Date & Time: 11/06/2026 10:03:12 AM