

SLAB ON GROUND NOTES

1. REFER S0.001-S0.003 FOR CONSTRUCTION NOTES
2. UNLESS NOTED OTHERWISE ON PLAN LOADS AS FOLLOWS:

AREA OF LOAD	LIVE LOAD	SUPERIMPOSED DEAD LOAD
GENERAL	4kPa	1kPa
PLANT	5kPa	

3. THE 28 DAY CONCRETE STRENGTH SHALL BE S32
4. THE CLEAR CONCRETE COVER TO ALL
REINFORCEMENT SHALL BE:

COMPONENT	COVER		
	BTM	TOP	SIDE
INTERNAL SLAB	20	20	N/A
EXTERNAL SLAB	30	40	N/A
BEAMS	50	50	50

5. MINIMUM REINFORCEMENT BAR LAPS SHALL BE:

BAR SIZE	TOP BAR	BTM BAR
N12	600	500
N16	900	700
N20	1200	950
N24	1550	1200
N28	1950	1500
N32	2300	1800
N36	2700	2100
TRENCH MESH	500	500

LAP MESH 1 SQUARE PLUS 30 MIN

A TOP BAR HAS 300 MIN CONCRETE UNDER BAR

6. COORDINATE ALL SERVICE PENETRATIONS, SIZE AND LOCATIONS WITH ARCHITECTURAL, MECHANICAL, HYDRAULIC AND ELECTRICAL ENGINEERING DRAWINGS.
7. REFER ARCHITECT FOR SLAB SETOUT INCLUDING BUT NOT LIMITED TO; LEVELS, FALLS, STEPS, RAMPS, SET DOWNS, REBATES, HOBS AND DIMENSIONS.
8. REFER CIVIL ENGINEER FOR BUILDING PAD PREPARATION.
9. PROVIDE TRIMMER BARS AT ALL RE ENTRANT CORNERS, SERVICE PENETRATIONS AND COLUMNS IN ACCORDANCE WITH SLAB TRIMMER DETAILS
10. UNO ALL SLABS TO BE POURED ON 2 LAYERS OF POLYETHYLENE SHEETING OVER CBR15 SUBBASE

SLAB ON GROUND LEGEND

The diagram illustrates a cross-section of a road structure. At the top, a yellow diamond-shaped callout labeled '200 SGT' points to the 'SLAB THICKNESS' label. Below this, a light green layer is labeled 'SLAB DESCRIPTION REFER SCHEDULE'. The next layer is a light blue-grey 'FIBRE SLAB'. Below that is a dark grey 'EXTERNAL INSITU SLAB'. The bottom-most layer is a light grey 'EXTERNAL FOOTPATH SLAB'. A cross-section of a 'SLAB STEP LOCATION' is shown on the left. Below the step, two labels 'DJ1' and 'DJ2' are connected by a red line, with the text 'DOWEL JOINT FOR DETAILS REFER 002901' to the right. Below these, 'SJ1' and 'SJ2' are connected by a red line, with the text 'SAWN JOINT FOR DETAILS REFER 002901' to the right. Further down, a layer labeled 'BW#' is shown with a red line, with the text 'LOAD BEARING BLOCK WALL FOR DETAILS REFER 002901' to the right. Below that, a layer labeled 'PW#' is shown with a red line, with the text 'PRECAST WALL FOR DETAILS REFER 003991' to the right. At the very bottom, a 'STEELWORK COLUMN' is shown with the text 'FOR DETAILS REFER 006902' to the right. A legend at the bottom left shows a 'I' symbol for a column and a '□' symbol for a wall.

200 SGT

SLAB THICKNESS

SLAB DESCRIPTION REFER SCHEDULE

FIBRE SLAB

EXTERNAL INSITU SLAB

EXTERNAL FOOTPATH SLAB

SLAB STEP LOCATION

DJ1 DJ2

DOWEL JOINT
FOR DETAILS REFER 002901

SJ1 SJ2

SAWN JOINT
FOR DETAILS REFER 002901

BW#

LOAD BEARING BLOCK WALL
FOR DETAILS REFER 002901

PW#

PRECAST WALL
FOR DETAILS REFER 003991

STEELWORK COLUMN
FOR DETAILS REFER 006902

I □

SLAB ON GROUND SCHEDULE

MARK	THICKNESS	REINFORCEMENT	CONCRETE STRENGTH
EXTERNAL JOINTED SLAB ON GROUND			
EP1	150	SL82 TOP	N32
FIBRE SLAB ON GROUND			
FR1	150	DRAMIX 4D 65/60GB AT 20kg/m ³	S40
JOINTED SLAB ON GROUND			
SG1	300	SL102 TOP N16-200 EACHWAY BOTTOM	N32
SG2	150	SL82 TOP	N32
SG3	120	SL82 TOP DJ2 MAX 25m CTRS SJ2 MAX 5m CTRS	N32
SG4	150	SL92 TOP & BOTTOM	N32

EXTERNAL PAVEMENT PLAN

SCALE 1 : 400

COPYRIGHT :
REPRODUCTION OF WHOLE OR PART OF THIS
DOCUMENT CONSTITUTES AN INFRINGEMENT
OF COPYRIGHT. THE INFORMATION, IDEAS,
AND CONCEPTS CONTAINED IN THIS
DOCUMENT ARE CONFIDENTIAL. THE
RECIPIENT(S) OF THIS DOCUMENT IS
PROHIBITED FROM DISCLOSING SUCH
INFORMATION IDEAS AND CONCEPTS TO ANY
PERSON WITHOUT THE PRIOR WRITTEN
CONSENT OF THE BRISBANE AIRPORT
CORPORATION PTY. LTD.

NS	BAC APPROVAL	11.06.26	A
DRN	AMENDMENTS	DATE	REV

NORTHROP
PROJECT NUMBER: 250946

Drawn: HP	Checked:
Design Coordinated: HP	Compliance Checked: --
Authorised For Issue: NS	Construction Checked: --

SKYGATE PLAY

EXTERNAL PAVEMENT PLAN

 **Brisbane
Airport**

e:	indicated
c:	A1
ision:	A

Drawing Number	Project No.	Originator	Volume	Level	Type	Discipline	Number
	25021	NOR	XX	01	DR	ST	002000