

Service Advice Notice

Skygate Play – SAN26



Date of issue: 2 October 2025

Section A – Property Information

Development Site Name:	Skygate Play - SKG26
Development Site Address:	The circuit, Brisbane Airport
Precinct:	Skygate
Building Use:	Indoor Playgrounds

Section B – Minimum Design Criteria

In alignment with applicable standards and regulations, Brisbane Airport Corporation (BAC) strictly prohibits conducting on-site field tests to measure water pressures and flows for hydraulic design purposes. This policy ensures compliance with industry best practices, maintains system integrity, and minimises potential risks associated with the BAC water network.

The design engineer must use the hydraulic profile (at the point of connection) in the table below and select the appropriate parameters to develop the design.

Table 1 - BAC Hydraulic Pressure at point of connection

Flow (L/s)	Existing pipe size (mm)	BAC SAN (m)
0	150	53.2
10	150	51.2
20	150	48
30	150	47.2
40	150	40

(Refer to **Attachment 1** for locality)

Section C – Network Demand and Capacity

An assessment of the water supply available at the site, including computational hydraulic modelling of the water network under peak demand and fire flow conditions, has been completed, and the results of these can be found in the table above. Although greater capacity may currently exist in the network, an assessment has been undertaken considering future growth and conditional changes of the supply from Urban Utilities.

The assessment was completed considering the requirements of NCC 2022/AS 2419.1:2021

Section D – Notes

BAC, as a registered water service provider, issues the advice above, including conditions that may apply and other relevant matters about the proposed water connection.

This Services Advice Notice does not constitute an application for connection, is not an approval to connect to the BAC network and does not bind any future BAC decision if the applicant applies for a connection.

This Services Advice Notice is current for a period of twelve (12) months from the date of issue. Should you wish to proceed with applying for a service connection, please lodge your application via the Building Approval process. Please include your Services Advice Notice reference number in your application.

If you have any questions in relation to this Services Advice Notice, please do not hesitate to contact your Building Approval representative.

Section E – Disclaimer

Information provided by BAC is based on hydraulic modelling. Model results are for the anticipated performance.

Due to the fact that BAC is supplied from Urban Utilities by a gravity main and BAC does not have an overall boosting system, pressure and flows delivered to a service may vary depending on Urban Utilities supply conditions.

The pressure and flow of BAC's water supply may fluctuate depending on the conditions of the Urban Utilities' supply conditions, as BAC is supplied from Urban Utilities and does not have a boosting system in place.

Designers are advised to make adequate provisions within the fire system installation for the pressure, flow, and reliability requirements for the life of the system.

Further enquiries regarding this document should be directed to the following BAC representative:

Costel Mustatea

Development Manager
Development & Delivery

T +61734063017 **E** Costel.Mustatea@bne.com.au
W bne.com.au

Attachment 1

It provides an illustration of the connection point and existing water infrastructure surrounding the development site.

