	LOCATION			TIME		SUB-CATCHMENT RUN OFF				INLET DESIGN										DRAIN DESIGN											HEAD LOSSES							PART FULL		DESIGN LEVELS							
				tc	I	C	A	+C x A	Q				w	d	dv		Qg	Qb		tc	I	+C x A	Qt	Qp	L	S		V	t		V2/2g	Ku	hu	Kw	hw	Sf	hf		Vp							
AEP	STRUCTURE No.	DRAIN SECTION	SUB-CATCHMENT CONTRIBUTING	SUB-CATCHMENT TIME OF CONC.	RAINFALL INTENSITY	COEFFICIENT OF RUNOFF	SUB-CATCHMENT AREA	SUM OF (C x A)	SUB-CATCHMENT DISCHARGE	FLOW IN K & C (INC. BYPASS)	ROAD GRADE AT INLET	MINOR FLOW ROAD CAPACITY	FLOW WIDTH	FLOW DEPTH	FLOW DxV	INLET TYPE	FLOW INTO INLET	BYPASS FLOW	BYPASS STRUCTURE No.	CRITICAL TIME OF CONC.	RAINFALL INTENSITY	TOTAL (C x A)	TOTAL FLOW	PIPE FLOW	REACH LENGTH	PIPE GRADE	PIPE/BOX DIMENSIONS (CLASS)	FULL FLOW VELOCITY (PIPE GRADE VELOCITY)	TIME OF FLOW IN REACH	STRUCTURE CHART No.	VELOCITY HEAD	U/S HEAD LOSS COEFFICIENT	U/S PIPE STRUCT HEAD LOSS	WSE COEFFICIENT	CHANGE IN WSE	PIPE FRICTION SLOPE	PIPE FRICTION HEAD LOSS (L x Sf)	DEPTH	VELOCITY	OBVERT LEVELS	DRAIN SECTION HGL	UPSTREAM HGL	WSE	SURFACE OR K & C LIP LEVEL	FREEBOARD	STRUCTURE No.
				min	mm/h		Ha	Ha	L/s	L/s	%	L/s	m	m	m2/s		L/s	L/s		min	mm/h	Ha	L/s	L/s	m	%		m/s	min		m		m		m	%	m	m	m/s	m	m	m	m	m	m	
5 1	F1/2	F1/2 to F2/2	0.139	5 5	239 311		0.139 0.139	0.139 0.139	92.1 119.9	92.1 119.9		92.1		0.111 0.130		900x900 GRATED PIT WITH ATLAN FILTER BASKET. CLASS B HEELSAFE GRATE. REFER BCC STD DRG BSD-8091	92.1 119.9		F1/3	5.01 5.01	239 311	0.139 0.139		392.1 419.9	31	0.4	600 HDPE PN100 SN8	1.43 1.53	0.31 0.34		0.104 0.120	1.00 1.00	0.100 0.100	0.10 0.10	4.745 4.745	0.24 0.27	0.070 0.090	0.469 0.591	1.68 1.53	3.885 3.761	4.804 4.745	4.804	4.699	4.745	0.046	F1/2
5 1	F1/3	F1/3 to F2/2	0.127	5 5	239 311		0.127	0.127 0.127	84 109.4	84 109.4		84		0.106 0.124		900x900 GRATED PIT WITH ATLAN FILTER BASKET. CLASS B HEELSAFE GRATE. REFER BCC STD DRG BSD-8091	84 109.4		F2/2	5.02 5.02	239 311	0.127 0.127		198 223.3	10.4	0.5	525 HDPE PN100 SN8	0.95 1.08	0.11 0.11		0.046 0.059	1.00 1.00	0.000 0.100	0.00 0.10	4.900 4.900	0.13 0.17	0.010 0.020	0.298 0.322	1.59 1.63	3.736 3.684	4.685 4.745	4.685	4.638	4.9	0.262	F1/3
5 1	F2/2	F2/2 to FI3/2	0.32	5 5	239 311		0.054	0.054 0.054	36 46.9	36 46.9		36		0.066 0.076		900x900 GRATED PIT WITH ATLAN FILTER BASKET. CLASS D GRATE. REFER BCC STD DRG BSD-8091	36 46.9		FI3/2	5.32 5.35	239 311	0.320 0.320		623.7 686.4	35.1	0.4	900 HDPE PN100 SN8	1.05 1.16	0.30 0.29		0.056 0.068	1.00 1.00	0.100 0.100	0.10 0.10	4.745 4.745	0.09 0.10	0.030 0.040	0.461 0.489	1.95 2.00	4.019 3.879	4.625 4.769	4.625	4.568	4.745	0.177	F2/2
5 1	FI3/2	FI3/2 to F4/2	0.402	5 5	239 311		0.082	0.082 0.082	54.6 71.1	54.6 71.1		54.6		0.083 0.096		900x900 GRATED PIT WITH ATLAN FILTER BASKET. CLASS D GRATE. REFER BCC STD DRG BSD-8091	54.6 71.1			5.62 5.64	239 311	0.402 0.402		801.7 879.6	40	0.4	900 HDPE PN100 SN8	1.35 1.48	0.32 0.32		0.093 0.112	1.00 1.00	0.100 0.100	0.10 0.10	4.769 4.769	0.14 0.17	0.060 0.070	0.541 0.577	2.07 2.11	3.859 3.699	4.538 4.649	4.538	4.445	4.769	0.324	FI3/2
5 1	F1/1	F1/1 to F2/1	0.05	5 5	239 311		0.05	0.050 0.050	33.3 43.4	33.3 43.4		33.3				900x900 GRATED PIT WITH ATLAN FILTER BASKET. CLASS D GRATE. REFER BCC STD DRG BSD-8091	33.3 43.4	26	F2/1	5.02 5.02	239 311	0.050 0.050		74.5 77.4	80.4	0.4	375 PVC	0.67 0.70	0.94 0.93		0.023 0.025	3.50 3.50	0.100 0.100	0.10 0.10	4.411 4.411	0.10 0.11	0.080 0.090	0.180 0.184	1.42 1.44	3.757 3.435	4.366 4.478	4.366	4.284	4.411	0.126	F1/1
5 1	F4/2	F4/2 to F5/2	0.488	5 5	239 311		0.086	0.086 0.086	57.2 74.5	57.2 74.5		57.2		0.085 0.099		900x900 GRATED PIT WITH ATLAN FILTER BASKET. CLASS D GRATE. REFER BCC STD DRG BSD-8091	57.2 74.5		F5/2	5.94 5.96	239 311	0.488 0.488		984.7 1077.9	39.4	0.4	900 HDPE PN100 SN8	1.66 1.82	0.31 0.30		0.141 0.169	1.00 1.00	0.100 0.200	0.10 0.20	4.769 4.769	0.21 0.25	0.080 0.100	0.628 0.679	2.15 2.17	3.679 3.521	4.389 4.384	4.389	4.249	4.769	0.52	F4/2
5 1	F2/1	F2/1 to F3/1	0.118	5 5	239 311		0.068	0.068 0.068	45 58.6	45 84.5		45		0.074 0.106		900x900 GRATED PIT WITH ATLAN FILTER BASKET. CLASS D GRATE. REFER BCC STD DRG BSD-8091	45 58.6		F3/1	5.96 5.95	239 311	0.118 0.118		211.5 252.1	69.3	0.4	525 HDPE PN100 SN8	1.02 1.22	0.78 0.76		0.053 0.075	1.20 1.20	0.100 0.100	0.10 0.10	4.800 4.800	0.15 0.21	0.100 0.140	0.335 0.383	1.48 1.52	3.554 3.277	4.203 4.242	4.203	4.139	4.8	0.661	F2/1
5 1	F5/2	F5/2 to F6/2	0.574	5 5	239 311		0.086	0.086 0.086	57.2 74.4	57.2 74.4		57.2		0.085 0.099		900x900 GRATED PIT WITH ATLAN FILTER BASKET. CLASS D GRATE. REFER BCC STD DRG BSD-8091	57.2 74.4		F6/2	6.24 6.26	239 311	0.574 0.574		1100.4 1208.6	29.1	0.4	1050 HDPE PN100 SN8	1.25 1.38	0.22 0.21		0.080 0.097	1.00 1.00	0.100 0.100	0.10 0.10	4.740 4.740	0.10 0.11	0.030 0.030	0.577 0.612	2.25 2.30	3.689 3.573	4.168 4.255	4.168	4.087	4.74	0.653	F5/2
5 1	F3/1	F3/1 to F4/1	0.176	5 5	239 311		0.058	0.058 0.058	38.2 49.8	38.2 49.8		38.2		0.068 0.079		900x900 GRATED PIT WITH ATLAN FILTER BASKET. CLASS D GRATE. REFER BCC STD DRG BSD-8091	38.2 49.8		F4/1	6.74 6.71	239 311	0.176 0.176		345.7 395.5	67.6	0.4	750 HDPE PN100 SN8	0.82 0.94	0.67 0.65		0.035 0.045	1.00 1.00			4.845 4.845	0.07 0.08	0.040 0.060	0.359 0.389	1.69 1.74	3.474 3.203	4.035 4.140	4.035	4.001	4.845	0.844	F3/1
5 1	F6/2	F6/2 to F7/2	0.597	5 5	239 311		0.022	0.022 0.022	14.7 19.2	14.7 19.2		14.7		0.042 0.048		300 WIDE ACO KLASSIK DRAIN 900x900 GRATED PIT WITH ATLAN FILTER BASKET. CLASS D GRATE. REFER BCC STD DRG BSD-8091	14.7 19.2		F7/2	6.46 6.47	239 311	0.597 0.597	1222.6	1111.2 31.5	31.5	0.4	1050 1.39	1.27 0.23	0.23	0.082	1.000 1.000	0.10 0.10	0.100 0.100	4.95 4.95	0.100 0.120	0.03 0.04	0.580 0.616	2.254 2.304	2.50 2.50	2.374 1057.00 4	3.947 4.255	3.978	4.952	0.974	F6/2	
5 1	F4/1	F4/1 to MH5/1	0.253	5 5	239 311		0.077	0.077 0.077	51.1 66.4	51.1 66.4		51.1		0.080 0.092		900x900 GRATED PIT WITH ATLAN FILTER BASKET. CLASS D GRATE. REFER BCC STD DRG BSD-8091	51.1 66.4		MH5/1	7.41 7.36	239 311	0.253 0.253		517.7 580	27.8	0.5	750 HDPE PN100 SN8	1.23 1.38	0.23 0.22		0.077 0.097	1.40 1.40	0.100 0.100	0.10 0.10	4.789 4.789	0.14 0.17	0.040 0.050	0.429 0.463	2.02 2.07	3.183 3.044	3.956 3.953	3.956	3.845	4.789	0.944	F4/1
5 1	F7/2	F7/2 to F6/1	0.627	5 5	239 311		0.03	0.030 0.030	20 26	20 26		20		0.049 0.056		900x900 GRATED PIT WITH ATLAN FILTER BASKET OVER 1500 DIA MANHOLE CLASS D COVER. REFER BCC STD DRG BSD-8021	20 26		F6/1	6.69 6.7	239 311	0.627 0.627		1254.5 1370.3	30.4	0.4	1050 HDPE PN100 SN8	1.43 1.56	0.22 0.22		0.104 0.124	1.40 1.40	0.200 0.200	0.20 0.20	4.808 4.808	0.12 0.15	0.040 0.040	0.626 0.664	2.32 2.36	3.407 3.285	3.947 3.895	3.947	3.797	4.808	1.011	F7/2
5 1	MH5/1	MH5/1 to F6/1	0.253		239 311											1200 DIA MH WITH CLASS D COVER. REFER BCC STD DRG BSD-8021			F6/1	7.64 7.58	239 311	0.253 0.253		516.5 578	13	0.5	900 HDPE PN100 SN8	0.87 0.97	0.11 0.10		0.039 0.048	1.00 1.00			4.882 4.882	0.06 0.07	0.010 0.010	0.387 0.413	2.02 2.08	3.162 3.097	3.806 3.895	3.806	3.767	4.882	1.114	MH5/1
5 1	F6/1	F6/1 to SQID/1	0.92	5 5	239 311		0.041	0.041 0.041	27.1 35.2	27.1 35.2		27.1		0.057 0.065		900x900 GRATED PIT WITH ATLAN FILTER BASKET OVER 1500 DIA MANHOLE CLASS D COVER. REFER BCC STD DRG BSD-8021	27.1 35.2		HW8/1	7.75 7.69	239 311	0.920 0.920		1778.1 1958	3.7	0.3	1050 HDPE PN100 SN8	2.03 2.23	0.03 0.03		0.208 0.251	2.10 2.10	0.400 0.500	0.40 0.50	4.679 4.679	0.24 0.29	0.010 0.010	1.057 1.057	2.03 2.23	3.265 3.254	3.760 3.355	3.76	3.321	4.679	1.359	F6/1
5 1	SQID/1	SQID/1 to HW8/1	0.92		239 311											HUMEFILTER UPT3000				7.78 7.71	239 311	0.920 0.920		1777.5 1957.1	15.7	0.3	1050 HDPE PN100 SN8	2.03 2.23	0.13 0.12		0.208 0.251	1.00 1.00	0.200 0.300	0.20 0.30	4.752 4.752	0.24 0.29	0.040 0.040	1.057 1.057	2.03 2.23	3.104 3.057	3.312 3.057	3.312	3.104	4.752	1.648	SQID/1

NOT FOR CONSTRUCTION

COPYRIGHT :
REPRODUCTION OF WHOLE OR PART OF THIS DOCUMENT CONSTITUTES AN INFRINGEMENT OF COPYRIGHT. THE INFORMATION, IDEAS AND CONCEPTS CONTAINED IN THIS DOCUMENT ARE CONFIDENTIAL. THE RECIPIENT(S) OF THIS DOCUMENT IS PROHIBITED FROM DISCLOSING SUCH INFORMATION IDEAS AND CONCEPTS TO ANY PERSON WITHOUT THE PRIOR WRITTEN CONSENT OF THE BRISBANE AIRPORT CORPORATION PTY. LTD.

JD	ISSUED FOR TENDER	23.12.25	A
JD	ISSUED FOR TENDER	28.01.26	B
LQ	ISSUED FOR TENDER	30.01.26	C
MM	ISSUED FOR APPROVAL	11.06.26	D
DRN	AMENDMENTS	DATE	REV

XENIA

NORTHROP
Brisbane
The Annex, Level 8, 12 Creek Street, Brisbane QLD 4000
GPO BOX 423 Brisbane QLD 4001
(07) 3365 0400 brisbane@northrop.com.au
ABN 81 094 433 100

Drawn M.MANLAPIT 11.06.26	Checked A.TATHAM 11.06.26
Design Coordinated R.MITCHELL 11.06.26	Compliance Checked S.KILLORAN 11.06.26
Authorised For Issue S.KILLORAN 11.06.26	Construction Checked N/A

SKYGATE PLAY
BRISBANE AIRPORT

STORMWATER DRAINAGE CALCULATION TABLE

Brisbane Airport
BRISBANE AIRPORT CORPORATION PTY LTD
11 THE CIRCUIT, BRISBANE AIRPORT QLD 4008
PO BOX 61, HAMILTON CENTRAL QLD 4007 AUSTRALIA
T +61 7 3406 3000
E INFO@BNE.COM.AU
W BNE.COM.AU

Scale	Size	Revision
AS ABOVE	A1	D

Drawing Number	Project No.	Originator	Volume	Level	Type	Discipline	Number
	25021	NRP	XX	XX	DR	CI	000341

File: 250946-C-000341-SwdCalc.dwg
C:\12dS\data\NorthropSYN\250946 - BNE PLAY Skygate_572\CAD\4-DD

Pentable: ----

Printer: AUTOCAD PDF (GENERAL DOCUMENTATION)

User: Mark Manlapit

Plot Date & Time: 6/11/2026 8:47:05 AM