



Room/Space	Lighting Requirements to AS1680	Fitting type	Control method
Bowling, Go Karting	160 lux	High Bay Luminaires	Switches located near entrances in BOH areas
FOH	320 lux	Recessed LED Panels	Switches located near FOH entrances
Amenities	80 lux	Recessed LED downlights	Motion sensor
PWD	200 lux	Recessed LED downlights	Motion sensor
Outdoor Area	80 lux	IP rated surface mounted luminaires	Switches located on inside of building
PROVIDE EXIT AND EMERGENCY LIGHTING TO NCC AND AS2293 REQUIREMENTS			

LIGHTING TO GAME OVER BASE BUILD

D&C PRICING ISSUE

This drawing is diagrammatic & approximate only. The (sub-)contractor shall make all allowances necessary to price the project on a Design & Construct methodology. Where items are not specifically shown or included, but are required, the (sub-)contractor shall make all allowances for such items to ensure compliant system(s) are provided that satisfy the client's expectations & operational requirements.