

Project:	Skygate Play
Address:	The Circuit, Brisbane Airport
Tenancies:	Area 51, Racquet Club
ESTIMATED VA/M2 MAXIMUM DEMAND	
NOTE This is not to AS3000 Table C2	

Last Updated:	20/08/2025
Author:	RA/DE

Maximum Demand VA/m2 Actual			
Location	Area (m ²)	VA/m ²	Total A/ph
Racquet Club Tenancy			
Lighting & Power	3600	20	104
Area 51 Tenancy			
Light & power	7000	10	101
Air conditioned space	5000	50	360
Café (cooking)	240	600	207
Amenities	261	20	8
Snow World	2000		400
External Lighting/Power			
Lighting- carpark + outdoor play	5900	5	42
Pumps, gates, misc	1	5000	7
EV charging	4	11000	63
Spare Capacity	25%		323
		Total (A)	1615

Comments
Estimate from Bundamba Area 51 tenancy
3 ph 22kW each 50% diversity
VA/m2 ESTIMATED MAXIMUM DEMAND