1 2 3 4 5 6 7 8 9 10 11 12

A B C D E F G H

IV IN CLASS 'D' PATHBOX TO FSL (TYPICAL)

SERVICE ROAD

IV IN CLASS 'D' PATHBOX TO FSL (TYPICAL)

DUAL PILLAR HYDRANT (TYPICAL)

150Ø FS

HT/VB/VDP

DPH

FHR

MECHANICAL SERVICES

MECHANICAL SERVICES.

RW TANK

MSB

PV-DB

INVERTER

DB

20Ø CW

25Ø FS

REFER TO DETAIL ON DWG H001203

CONTINUATION TO STORAGE AREA HOSETAP - TBC

ROLLER DOOR

WATER SUPPLY & BACKFLOW FOR MECHANICAL PLANT TBC PENDING SELECTION OF MECHANICAL PLANT

25Ø RW
25Ø CW
32Ø FS

150Ø FS

HT/VB/VDP

ROOF RIDGE OVER

20Ø CW

DRAIN LOCATION AND LENGTH SHOWN INDICATIVE ONLY

1200W CLEARANCE ZONE REQUIRED IN FRONT OF MSB

HYDRANT PUMP SET TO AS 2419, AS 2941 & QFD & BAC REQUIREMENTS C/W 1x DIESEL & JACKING PUMP, DIESEL EXHAUST TO ATMOSPHERE, & 150mm HIGH CONCRETE PLINTH EXTENDING 150mm BEYOND BASE OF PUMP SKID (ESTIMATED DUTY: 10L/s @ 70 m/head)

50Ø CAPPED & VALVED CW SERVICE AT HIGH LEVEL TO SERVE SNOW WORLD - AWAITING DETAILS

CAPPED 150Ø FIRE HYDRANT SUPPLY AT HIGH LEVEL FOR FUTURE FITOUT IF REQUIRED

DUAL PILLAR HYDRANT (TYPICAL)

2x 32Ø CW SERVICE AT HIGH LEVEL TO SERVE TENANCIES

AREA 51
TENANT 1
BUILDING 346
7,115m²
(including Amenities & Cafe)

PIPEWORK AT HIGH LEVEL

2x 32Ø CW SERVICE AT HIGH LEVEL TO SERVE TENANCIES

PROPOSED LOCATION OF WATER SUB-METER CUPBOARD TO BAC REQUIREMENTS

65Ø 32Ø

150Ø QUAD FIRE SPRINKLER BOOSTER & TANK SUCTION ASSEMBLY TO AS2118, & QFES REQUIREMENTS C/W VISUAL ALARM DEVICE (VAD). COORDINATE IN-GROUND WORKS WITH SPRINKLER TRADE.

IV IN CLASS 'D' PATHBOX TO FSL (TYPICAL)

FIRE TANK 6m DIA 3.6m HIGH

PUMP-DB

FIRE PUMP ROOM 8x6m

AMENITIES

Cleaners Room

Male

Female

SETDOWNS FOR KITCHEN (FITOUT BY OTHERS)

VALVED & CAPPED POINT TO SERVE TENANCY 1 KITCHEN

REFER TO DETAIL ON DWG H001203

32Ø FIRE SERVICE AT HIGH LEVEL

32Ø CW SERVICE AT HIGH LEVEL TO SERVE BASEBUILD

CREAM SHOP LOCATION (FITOUT BY OTHERS)

150Ø DUAL FIRE HYDRANT BOOSTER ASSEMBLY TO AS2419, & QFES REQUIREMENTS C/W VISUAL ALARM DEVICE (VAD).

DN100Ø ROLL GROOVE FLANGE 200mm AFFL FOR CONTINUATION BY SPRINKLER TRADE - ENSURE EDMI METER IS INSTALLED AT TANK IN ACCORDANCE WITH BAC DOCUMENT #ADG-635 SUPPLIED & INSTALLED C/W CONDUIT & WIRING

HT/VB C/W RPZD & NPWS FOR MAINTENANCE OF GREASE TRAP

HT/VB/VDP

150Ø FS

DPH

FHR

80Ø RPZD, 150Ø SINGLE TESTABLE CHECK VALVE C/W 16kPa SPRING FOR HYDRANT & 100Ø DOUBLE CHECK VALVE FOR SPRINKLER SERVICE

NEW 150Ø FIRE SERVICE METER & 80Ø POTABLE WATER METER TO BAC REQUIREMENTS. REFER TO CIVIL ENGINEER'S DRAWINGS FOR DETAILS

CIVIL WORKS

PROPOSED CIVIL CW SERVICE -REFER TO CIVIL ENGINEER'S DRAWINGS

HT/VB C/W RPZD & NPWS FOR MAINTENANCE OF GREASE TRAP

7 BAYS

CAR PARKING

NORTH

e100Ø RW
e65Ø CCW

e100Ø RW
e150Ø CCW

IV IN CLASS 'D' PATHBOX TO FSL (TYPICAL)

HT/VB C/W RPZD & NPWS FOR MAINTENANCE OF ORG & GREASE TRAP

ROOF OVERHEAD SHOWN DASHED

NOTE

ALLOW ALL COSTS TO FIX PIPEWORK UNDERNEATH SLAB VIA STAINLESS STEEL RODS TO SUIT UNSTABLE SOIL CONDITIONS

CAUTION

OTHER SERVICES EXIST ON-SITE. CONTRACTOR IS TO CONDUCT "DIAL BEFORE YOU DIG" AND SURVEY PRIOR TO COMMENCEMENT OF WORKS & MAKE ON-SITE ROUTE ADJUSTMENTS AS REQUIRED

B

NOTE

3 OPTIONS HAVE BEEN PROVIDED FOR SPRINKLER SERVICES. REFER TO SPRINKLER DRAWINGS FOR DETAILS.

OPTION 1 - ALLOW TO PROVIDE 600x600 GRATED DRAIN & OVERFLOW TO SPRINKLER TANK, PROVIDE GRATED DRAINS TO SPRINKLER VALVE SET & SPRINKLER PUMP ROOM. ALLOW TO EXTEND WATER SERVICE TO CAPPED POINT FOR CONTINUATION BY SPRINKLER TRADE TO 80kL SPRINKLER TANK.

OPTION 2 - ALLOW TO PROVIDE 450x450 GRATED DRAIN TO SPRINKLER VALVE SET.

OPTION 3 - SIMILAR REQUIREMENTS TO OPTION 1 EXCEPT IN PROPOSED ALTERNATIVE LOCATION.

D&C PRICING ISSUE

This drawing is diagrammatic & approximate only. The (sub-)contractor shall make all allowances necessary to price the project on a Design & Construct methodology. Where items are not specifically shown or included, but are required, the (sub-)contractor shall make all allowances for such items to ensure compliant system(s) are provided that satisfy the client's expectations & operational requirements.

REFER TO DWG 101202 FOR CONTINUATION

COPYRIGHT :
REPRODUCTION OF WHOLE OR PART OF THIS DOCUMENT CONSTITUTES AN INFRINGEMENT OF COPYRIGHT. THE INFORMATION, IDEAS AND CONCEPTS CONTAINED IN THIS DOCUMENT ARE CONFIDENTIAL. THE RECIPIENT(S) OF THIS DOCUMENT IS PROHIBITED FROM DISCLOSING SUCH INFORMATION IDEAS AND CONCEPTS TO ANY PERSON WITHOUT THE PRIOR WRITTEN CONSENT OF THE BRISBANE AIRPORT CORPORATION PTY. LTD.

BW	D&C PRICING ISSUE	04/02/26	B
BW	D&C PRICING ISSUE	18/12/25	A
DRN	AMENDMENTS	DATE	REV

25-0437

Ashburner Francis
Ashburner Francis Pty Ltd ABN 46 009 975 197
T 07 3510 8888
E brisbane@ashburnerfrancis.com.au
977 Stanley Street East, East Brisbane QLD 4169
BRISBANE | TOOWOOMBA | TOWNSVILLE | DARWIN
HYDRAULIC SERVICES
QBCC LICENCE No: 15265403

Archipelago
Archipelago
Level 3, 199 George Street, Brisbane QLD 4000
T +617 3236 4606 www.archipelago.com.au

© ARCHIPELAGO ARCHITECTS PTY. LTD. All Rights Reserved
This work is copyright and cannot be reproduced or copied by any means without written permission of Archipelago Architects Pty Ltd. Any ... license, express or implied, to use this document for any purpose whatsoever is restricted to the terms of the agreement between Archipelago Architects Pty Ltd and the instructing party.

Drawn	BW
Checked	
Design Coordinated	IS
Compliance Checked	
Authorised For Issue	BD
Construction Checked	

SKYGATE PLAY
THE CIRCUIT, BRISBANE AIRPORT

HYDRAULIC SERVICES

GROUND FLOOR WATER LAYOUT 1

Brisbane Airport
Brisbane Airport Corporation Pty Ltd
11 The Circuit Brisbane Airport QLD 4008
PO Box 61 Hamilton QLD 4007 Australia
Telephone : 61 7 3406 3000
Facsimile : 61 7 3406 3111
Email : info@bne.com.au
www.brisbaneairport.com.au
ABN 54 076 870 650

Scale	1:200
Size	A1
Revision	B

Drawing Number	Project No.	Originator	Volume	Level	Type	Discipline	Number
	25021	ASH	XX	XX	DR	HY	001201

File: 2528 - TMR Depot | Pentable: | Printer: | User: #### | Plot Date & Time: 27/08/2025 7:54 PM