


ASSESSMENT: NATIONAL AIRPORT SAFEGUARDING FRAMEWORK (NASF)


Table 1 Assessment against National Airport Safeguarding Framework


Planning Element	Assessment
NASAG Guideline A – Aircraft Noise	A portion of the proposed development site is located within the ANEF 20-25 contour interval as shown in Figure 1. Table 2.1 of the <i>Australian Standard 2021 (2015) – Acoustics – Aircraft Noise Intrusion – Building Siting and Construction (AS2021:2015)</i>, outlines that a commercial building in this contour interval is acceptable. Despite this, the proposed development must consider appropriate building attenuation measures to manage indoor noise levels in accordance with Clause 3.3 of AS2021:2015. Figure 1 ANEF Mapping 
NASAG Guideline B – Windshear and turbulence	The development site is outside of the windshear assessment envelope therefore no further assessment is warranted.
NASAG Guideline C – Wildlife strike risk	The development site is located within the 3 km – 8 km wildlife strike zone for Brisbane Airport. Attachment 1 of Guideline C identifies several land uses/activities that are reflected in the amended plan including: • Park/Playground – moderate risk associated with natural elements and, food and waste. Mitigation measures required. • Fast food/outdoor restaurant – low risk associated with structural elements and, food and waste. Land use required to be monitored. Property will need to clearly define who is responsible for the common open space/park. Mitigation measures may include the development of a proactive litter and waste management plan to ensure that any debris or rubbish is not permitted to culminate to avoid attraction of high risk species such as feral pigeons or the Australian White Ibis.

Planning Element	Assessment
	Care will need to be taken in the landscape design and plant species selection to avoid design that supports roosting or habitat for key risk species. It is recommended that early engagement with Wildlife Manager to understand key risks. Development of the landscape plan will need to ensure compliance with the relevant species listing and planting constraints of the Landscape Setting Strategy.
NASAG Guideline D – Risk of wind turbine farms to airport operations	Not applicable to developments on airport.
NASAG Guideline E – Pilot Distraction and lighting in the vicinity of airports	The development site falls within Restricted Lighting Zone D meaning the maximum intensity of light measured at 3° above the horizontal cannot exceed 450 cd. Figure 2 Restricted Lighting Zones 
NASAG Guideline F – Protected Airspace	The current and future Obstacle Limitation Surface (OLS) is 48.50 m. The current and future PANSOPS surface across the proposed development site is 107.88 m. Refer to critical height mapping provided in Appendix A.
NASAG Guideline G – Communications, Navigation and Surveillance facilities	The current and future CNS limitation height ranges across the site is 57.92 m to 58.55 m. Refer to critical height mapping provided in Appendix A.
NASAG Guideline H –	Not applicable to on airport development.

Planning Element	Assessment
Strategically Important helicopter Landing Sites	
NASAG Guideline I – Public Safety Areas	The proposed development site is located outside of the Public Safety Areas.

APPENDIX A CRITICAL HEIGHT ASSESSMENT MAPPING









Drawn: YB Date: 02/04/24 Issue No.: 1 Approved: Alstie Standards Manager	BRISBANE AIRPORT SKG26 SITE AIRSPACE ASSESSMENT FUTURE OLS	<table border="1"> <tr> <td data-bbox="558 1937 718 2094"> </td> <td data-bbox="718 1937 1037 2094"> Brisbane Airport Corporation Pty Ltd 11 The Circuit Brisbane Airport QLD 4008 PO Box 97, Brisbane QLD 4007 Australia Telephone: 61 7 3438 9800 Fax: 61 7 3438 2111 Email: info@brisbaneairport.com.au Website: www.brisbaneairport.com.au </td> <td data-bbox="1037 1937 1428 2094"> Scale: 1:7 500 Size: A3 Revision: 1 Sub-Number: 0005 </td> </tr> <tr> <td data-bbox="558 2094 718 2094"> Design Ref: BAC / 241147 / O / 00 </td> <td data-bbox="718 2094 1037 2094"> Project Ref: O / 00 </td> <td data-bbox="1037 2094 1428 2094"> Airport Precedence: 0005 </td> </tr> </table>		Brisbane Airport Corporation Pty Ltd 11 The Circuit Brisbane Airport QLD 4008 PO Box 97, Brisbane QLD 4007 Australia Telephone: 61 7 3438 9800 Fax: 61 7 3438 2111 Email: info@brisbaneairport.com.au Website: www.brisbaneairport.com.au	Scale: 1:7 500 Size: A3 Revision: 1 Sub-Number: 0005	Design Ref: BAC / 241147 / O / 00	Project Ref: O / 00	Airport Precedence: 0005
	Brisbane Airport Corporation Pty Ltd 11 The Circuit Brisbane Airport QLD 4008 PO Box 97, Brisbane QLD 4007 Australia Telephone: 61 7 3438 9800 Fax: 61 7 3438 2111 Email: info@brisbaneairport.com.au Website: www.brisbaneairport.com.au	Scale: 1:7 500 Size: A3 Revision: 1 Sub-Number: 0005						
Design Ref: BAC / 241147 / O / 00	Project Ref: O / 00	Airport Precedence: 0005						





Drawn: YB	 Brisbane Airport Corporation Pty Ltd 11 The Circuit Brisbane Airport QLD 4008 PO Box 9711 Brisbane QLD 4008 Australia Telephone: 017 3458 3000 Fax: 017 3458 3111 Email: info@brisbaneairport.com.au www.brisbaneairport.com.au AS/NZS 4470:2015	Scale: 1:7,500
Date: 02/04/24		Size: A3
Issue No.: 1		Revision: 1
Approved: Airside Standards Manager		Design Ref: Project Ref: Client: Airport Operator: Sub-Number: 006
Datum for Levels: Australian Height Datum Coordinates: MGA		Doc No: BAC / 241147 / 0 / 00 / 0006