



24 July 2026

Our Ref: 16699

TENDER NUMBER TEN16699

ROCKHAMPTON SPORTS PRECINCT – STAGE 1 NETBALL

ADDENDUM NO. 11

Dear Tenderer,

This addendum forms part of, and is to be read in conjunction with, Invitation to Tender No. TEN16699

For all interested parties intending to tender for the ROCKHAMPTON SPORTS PRECINCT – STAGE 1 NETBALL, please find included with this addendum the following clarifications to assist with your tender submission:

- 1. There seems to be discrepancies with the trees required to be removed/retained in the Vegetation & Fauna Management Plan, sheet VFMP05, and the Landscapes plans, sheet LD-0101. Please clarify.**

Please refer to attached revision of LD 0101 (LD-0101 TREE RETENTION PLAN_v2) with updated wording to reflect that LD-0101 is correct in that it shows the latest up to date information. The discrepancy is because the VFPM05 was completed early in the project and hadn't been updated to reflect the finalised design.

The reason for the note on the drawing is that the information shown references another disciplines expertise. Any work associated with existing trees should be undertaken in accordance with the Ecological Report as there is a lot of other information pertinent to existing trees within development / construction sites.

- 2. Are there any photos, soil reports and geo information for the 10,000m3 stockpile at Gomersall Road site?**

Please find attached Geotech results:

- R16-140A-121 Issue 1
- R16-140A-122 Issue 1
- R26-0206 Issue 1

R26-0206 contains photos of all material and a mud map of the stockpile.

- 3. Please refer to attached revised schedule of rates to include a provisional sum for item 3.4 Netball Courts Electrical – Sports Lighting. Tenderers are requested to include the Revised Schedule of Rates with their submission.**

Refer attached 16699_Tender Schedule 3 - Schedule of Prices and Rates – Revised.xlsx.

- 4. Can council please provide that standard drawing CMDG-L-12 as this reference cannot be found on the official website.**

The reference to CMDG-L-012 has been made in error and can be ignored

- 5. With reference to the hydraulic drawings, can council please provide the drawing plan H004.**

The reference to Plan 004 is a sheet that forms part of the whole of site design (not Stage 1) – for the purposes of responding to Tenders, the reference to this sheet can be ignored as it does not form part of the scope of this project.

- 6. The Electrical Spec Appendix O calls for an Arc Flash Study requirement. Currently this is not a mandatory requirement so is this really required to engage an REPQ engineer to provide this.**

The Arc flash study is stated as a recommendation to be conducted to review the proposed arrangement and potentially increase the safety of the proposed new switchboards. However, the contractors are correct that this is not a mandatory requirement under the Australian standards.

- 7. Electrical drawing E-SITE-201 shows the indicative locations for 2x substations. Are we to include the civil & culvert nominated for the future high performance centre in our scope?**

Scope includes Civil works for Stage 1 only

- 8. Electrical specification section 1.1 scope of works lists CCTV & intruder detection, however none of these services are shown on the drawings. Please clarify what is required**

CCTV and intruder detection are not required

- 9. Can Council please provide the design drawings required for the erosion and sediment control measures for the site including sediment basins, autodose and flocculent, dirty, and clean water berms and any binder requirements please, generally undertaken CPESC engineers such as TOPO?**

Design drawings are not required. As per Tech spec 17.5 it is the contractor's responsibility to implement robust erosion and sediment control measures to prevent soil loss, protect adjoining properties, and safeguard the environment.

- 10. Drawing 25015-H003 indicates drawing H004, however there is no H004 within the tender set, can you confirm if this is required?**

The reference to Plan 004 is a sheet that forms part of the whole of site design (not Stage 1). The reference to this sheet can be ignored as it does not form part of the scope of this project.

Please note that receipt of this Addendum must be acknowledged when submitting your tender. For this purpose, acknowledgment of Addendum No. 11 is also attached for completion and return with your Tender Submission.

Yours faithfully

A handwritten signature in black ink, appearing to read 'mg', is positioned above the printed name.

Marie Grund
Contracts & Tenders Supervisor

INVITATION TO TENDER NO.: 16699

ROCKHAMPTON SPORTS PRECINCT – STAGE 1 NETBALL

ACKNOWLEDGEMENT OF ADDENDUM

This page is to be inserted in the Tender Submission Document directly in front of the Tender Form if applicable or in front of any other Acknowledgment of Addenda which has previously been issued.

ADDENDUM NO.11

Receipt of the above addendum is acknowledged.

NAME OF TENDERER:

SIGNATURE: _____ FOR AND ON BEHALF OF

TENDERER: _____

DATE: _____