

Stanwell

Stanwell New Projects Office
Switchyard Road,
Stanwell, QLD, 4702

25010 / cd Spec F / T1

Appendix F - Acoustic Sliding Door Specification

Revision	Date	Description	Issued by
T1	11/03/2026	For Tender	JB

PRELIMINARY
NOT FOR CONSTRUCTION



Beautiful in form. Reliable in function.

ABN 38 072 558 500
Phone: 1300 0GLYDE
Email: sales@glydearch.com.au

glydearchitectural.com.au

19/12/2025

Specification Document – Stanwell NPO

- **GLYDE Sereine Bottom-rolling Acoustic Sliding Doors**

Glyde® is a brand of Aluminium Industries of Australia Pty Ltd.

Contact: Carlos Siliezar, QLD Specification Manager

E: sales@glydearch.com.au

M: 0436 692 058

Performance Requirements:

- Sliders will have a certified acoustic performance as noted in Specification below.
- Doors to include GASS – Glyde Anti Slam System – safety braking system on closing action of lead module.
- Doors to include GLYDE Anti-Jump Safety System.
- Supply and Installation by representative of GLYDE™ Architectural Acoustic Systems.

Product Specifications:

Sereine Triple Solid Acoustic Sliders.

Opening Size(s):	3000mm H x 6410mm W
Product:	Glyde Acoustic Solid Sliders – Rw35
Series:	BRB50 / R30 / 2MR / A35
Configuration:	Bottom-rolling Triple Sliders
Frame:	50mm thick x 120mm wide perimeter frame finished in Dulux Duralloy 'White Satin' Powdercoat
Midrails:	Two transom midrails located below 895mm AFFL and above 2055mm AFFL
Panel finish:	Autex Cube to the upper and lower panel zones, with Porcelain Enamel Whiteboard to the central panel zone between midrails
Hardware:	Lockwood FP1 Flush pull stainless steel 120x50mm, with snib/snib locks
Safety Features:	Braking – “GASS” safety braking system on closing action of lead panel Anti-Jump – GLYDE Anti-jump safety system
Tracks:	Recessed floor tracks to suit slider configuration

Tolerances:

- Floor should be level within +/- 3mm across the opening for satisfactory acoustic performance
- Jambs to be plumb +/- 5mm
- Overhead member for head work lateral support fixing to GLYDE requirements.

Exclusions – Works by Others:

- Overhead structural support
- Making good of chase cut or leveling slab to floor track
- Relocation of obstructions within the ceiling hindering track fixing method
- Making good of ceilings or provision of bulkheads / ceiling baffles (if required)
- Adjacent fixed glazing (unless noted otherwise) or construction of nib walls / pockets for cavity sliders
- Levelling of floor across the opening