

1

2

3

4

5

6

7

A

B

C

D

E

F

G

H

I

J

PERMIT APPLICATION REF: _____

DESIGNER: HARRISON RALPH
QBCC Lic No. 15125080
SOIL CLASSIFICATION: H1

NORTH

All dimensions to be verified on site/s prior to commencement of on-site work and/ or off-site prefabrication. Figured dimension to be taken in preference to scaled dimensions. This drawing is copyright and remains the property of JHA Consulting Engineers. Reproduction in whole or part of these drawings without written consent constitutes an infringement of copyright.

REVISIONS / AMENDMENTS

Rev	Date	Description	Verified
A	18.12.2025	TENDER ISSUE	H.R.
B	14.01.2026	ISSUE FOR COUNCIL APPROVAL	H.R.

PIPE MATERIAL SCHEDULE SCHEDULE

SERVICES	LOCATION	MATERIAL	JOINTING	NOMINAL PIPE SIZE
SANITARY DRAINAGE	IN GROUND (UP TO 3METRES DEEP)	PVC-U DWV CLASS SN4 & SN6	SOLVENT WELDED	40-225
	IN GROUND (OVER 3METRES DEEP)	PVC-U DWV CLASS SN8 & SN10	SOLVENT WELDED	100-225
SANITARY PLUMBING & DRAINAGE	ABOVE GROUND (SUSPENDED WITHIN BASEMENT CARPARK)	PVC-U DWV CLASS SN4 & SN6	SOLVENT WELDED	40-225
	ABOVE GROUND	PVC-U DWV CLASS SN4 & SN6 WRAPPED IN 25mm WALL THERMOTEC NUWRAP 5	SOLVENT WELDED	40-225
STORMWATER DRAINAGE	IN GROUND (UP TO 3METRES DEEP)	PVC-U DWV CLASS SN4 & SN6	SOLVENT WELDED	100-300
	IN GROUND (OVER 3METRES DEEP)	PVC-U DWV CLASS SN8 & SN10	SOLVENT WELDED	100-300
	IN GROUND	STORMPRO SN8 OR EQUAL	RUBBER RING JOINTS	>300
	ABOVE GROUND (SUSPENDED WITHIN BASEMENT CARPARK)	PVC-U DWV CLASS SN4 & SN6	SOLVENT WELDED	100-300
	ABOVE GROUND	PVC-U DWV CLASS SN4 & SN6 WRAPPED IN 25mm WALL THERMOTEC NUWRAP 5	SOLVENT WELDED	100-300
DOWNPIPES	EXPOSED (EXTERNAL TO BUILDING)	PVC-U DWV CLASS SN8 & SN10	SOLVENT WELDED	100-150
	CONCEALED	PVC-U DWV CLASS SN4 & SN6 WRAPPED IN 25mm WALL THERMOTEC NUWRAP 5	SOLVENT WELDED	100-150
COLD WATER SERVICE	IN GROUND	HDPE TYPE PE100 SDR 11 PN16	BUTT WELDED OR ELECTRO-FUSION FITTINGS	15-150
	ABOVE GROUND	COPPER TYPE B	PRESS-FIT	15-100
			SILVER SOLDERED 5% SILVER	>100
	ROUGH INS	REHAU RAUTITIAN WATER PE-Xa PN16 OR AUSPEX WATER PE-X PN20	RAUTITIAN ONE DZR BRASS OR AUSPEX DZR BRASS FITTINGS	15-20
HOT WATER SERVICE	ABOVE GROUND	COPPER TYPE B WRAPPED IN 25mm WALL THERMOTEC 4-ZERO	PRESS-FIT	15-100
			SILVER SOLDERED 5% SILVER	>100
	ROUGH INS	REHAU RAUTITIAN WATER PE-Xa PN16 OR AUSPEX WATER PE-X PN20 WRAPPED IN 15mm WALL THERMOTEC 4-ZERO	RAUTITIAN ONE DZR BRASS OR AUSPEX DZR BRASS FITTINGS	15-20
	ROUGH INS (IN CONDUIT SUPPLY TO ISLAND BENCHES)	REHAU RAUTITIAN WATER PE-Xa PN16 OR AUSPEX WATER PE-X PN20 WRAPPED IN 15mm WALL THERMOTEC 4-ZERO	RAUTITIAN ONE DZR BRASS OR AUSPEX DZR BRASS FITTINGS	15-20
FIRE HYDRANT SERVICE	IN GROUND	PVC-M PN18 EQUAL TO BLUE RHINO SERIES 2 OR PE100 SDR 11 PN16	DUCTILE IRON EPOXY COATED FITTING WITH RUBBER RING JOINTS OR BUTT WELDED OR ELECTRO-FUSION FITTINGS	100-150 (MIN. INTERNAL DIAMETER)
	ABOVE GROUND	GALVANISED MILD STEEL MEDIUM GAUGE	ROLL GROOVED JOINTS WITH VICTAULIC COUPLING	65-150

FIXTURE UNIT TABLE

FIXTURE	QTY	FU'S EACH	TOTAL
WC	10	4	40
B	9	1	9
SHR	1	2	2
BTH	0	4	0
UR	1	1	1
SK	8	3	24
DWM	0	0	0
WM	0	0	0
DF	0	1	0
DT	0	1	0
AT	0	3	0
TD	3	0	0
TTD	0	0	0
CSK	0	1	0
ASK	0	1	0
LT	0	5	0
FWGBT	0	0	0
FHR	0	0	0
HYD	0	0	0
BACKFLOW (TESTABLE)	1	0	0
AUTO. CHANGEOVER DEVICE	0	0	0
HWU	4	0	0
PUMP	0	0	0
TRADEWASTE APPARATUS	0	0	0
TOTAL QTY :	37	TOTAL FU'S :	76

HOT WATER UNIT SCHEDULE

SERVICE AREA	LOCATION	DESCRIPTION	MAKE / MODEL
MALE, FEMALE & FIRST AID ROOM	SERVICE CUPBOARD	WALL MOUNTED WITHIN SERVICE CUPBOARD UNIT TO OUTPUT 50°C MAX. TEMP	STIEBEL ELTRON DHB-E 18
PWD & SHOWER	SERVICE CUPBOARD	WALL MOUNTED WITHIN SERVICE CUPBOARD UNIT TO OUTPUT 60°C MIN. TEMP	STIEBEL ELTRON DHB-E 18
COVERED OUTDOOR AREA	SERVICE CUPBOARD	WALL MOUNTED WITHIN SERVICE CUPBOARD UNIT TO OUTPUT 50°C MAX. TEMP	STIEBEL ELTRON DHB-E 13
KITCHEN	UNDER BENCH	WALL MOUNTED WITHIN KITCHEN JOINERY UNIT TO OUTPUT 50°C MAX. TEMP	STIEBEL ELTRON DHB-E 18

VALVE SELECTION SCHEDULE

ITEM	MODEL NUMBER	LOCATION	SUPPLIER
Thermostatic Mixing Valves	FM MATTSON	AS SHOWN ON THE DRAWINGS AND AS REQUIRED UNDER AS3500	MA GRIFFIN
ISOLATION VALVES	BALL VALVES	AS SHOWN ON THE DRAWINGS AND AS REQUIRED UNDER AS3500	ALL VALVES
	GATES VALVES		
	SLUICE VALVES		
PRESSURE LIMITING VALVES	CALEFFI	AS SHOWN ON THE DRAWINGS AND AS REQUIRED UNDER AS3500	ALL VALVES
BACKFLOW PREVENTION	CONBRACO APOLLO	AS SHOWN ON THE DRAWINGS AND AS REQUIRED UNDER AS3500	ALL VALVES
APPLIANCE PROTECTION VALVE	AQUA-STOP	ALL FIXTURES	AUSTRAL AQUA FLOW CONTROLS

TESTABLE BACKFLOW PREVENTION SCHEDULE

NO.	MAKE	TYPE	LOCATION AND REASON FOR INSTALL	SIZE	SERIAL NO.
1	CONBRACO APOLLO	RP2D	PLANTROOM TO SERVE IRRIGATION SYSTEM	25	

MISCELLANEOUS ITEMS SCHEDULE

ITEM	LOCATION	MODEL NUMBER	MANUFACTURER
Thermal Insulation	ALL WARM/HOT WATER PIPES	4-ZERO THERMAL PIPE INSULATION	THERMOTEC
Acoustic LAGGING	ALL ABOVE GROUND DRAINAGE SERVICES	NUWRAP 5 ACOUSTIC PIPE LAGGING	THERMOTEC
Protective Pipe Wrapping Tape & Priming Paste	ALL IN GROUND METAL PIPES	TAKI WRAP 5 TAPE & TAKI PRIMING PASTE	EXPANDITE
Detectable Warning Tape	ALL IN GROUND SERVICES	SERVICE SPECIFIC DETECTABLE WARNING TAPE	BODDINGTONS
Roof Penetration Flashing	ROOF	DEKTITE	DEKS INDUSTRIES

ASSOCIATED WORKS SCHEDULE

MECHANICAL SERVICES		
Item	Work By	Extent of work
Water Supply	Hydraulics	Provide non-potable water supply to plant rooms for connection of Mechanical plant as required and generally were indicated on the relevant drawings.
	Mechanical	Connect to water supply provided.
Tundish	Hydraulics	Provide tundish in locations nominated by the Mechanical Contractor.
	Mechanical	Provide condensate drain to tundish.
ELECTRICAL SERVICES		
Item	Work By	Extent of work
Hot water units	Hydraulics	Supply and install hot water units
	Electrical	Power Supply to hot water units
LANDSCAPE SERVICES		
Item	Work By	Extent of work
Water Supply (Landscape)	Hydraulics	Provide a non-potable water supply point to the podium level, and each tower for connection of Landscape System as generally indicated on the relevant drawings including provision of backflow device.
	Landscape	Connect to non-potable water supply provided.

REAL PROPERTY DESCRIPTION:

LOT/PLAN 44SP140243

OWNERS NAME:
STANWELL CORPORATION LIMITED; BRENTON JENSON

CLIENT


ARCHITECT


CONSULTANT


Level 1, 100 Brunswick St
Fortitude Valley
QLD 4006
Australia
+61 (07) 3257 4890
general@jhaengineers.com.au
www.jhaservices.com

PROJECT
STANWELL NEW PROJECTS OFFICE

397 POWER STATION ROAD,
STANWELL, QLD 4702

TITLE
HYDRAULIC SERVICES SCHEDULES

APPROVAL ISSUE
NOT TO BE USED FOR CONSTRUCTION

DRAWN	J.P.	SCALE @ A1 NTS
CHECKED	H.R.	
APPROVED	H.R.	
CREATED	DEC 25	
JOB No.	DRAWING No.	REV
Q250128	H0003	B

Autodesk Docs://Q250128 Stanwell Office/Q250128_R24_SO_MEH.rvt

09/03/2026 1:21:14 pm