

RFI response

Project: Stanwell New projects Office (NPO)	RFI Reference: 03.06.26
Project No: 24010	
Proprietor: Stanwell Corporation	Date: 05.06.2026

The following is in response to Request for Information from Tenderer dated 03.06.26

Query 1 RF-1 Timber Battens

*Could you please confirm the specification of the timber battens supporting the RF-1 roof build-up?
The T-Sheet references Ashgrid spacers mounted on timber battens, however, we have been unable to locate a specification for the battens themselves. We note that the battens appear to be shown as 50mm top hats within the valley gutter detail section on drawing A-720007 [T1], but would expect these to be a timber batten. Could you please confirm the intended batten type, size, material?*

Response:

Please refer to revised Structural documentation (attached) for roof batten specification i.e. 50mm x 0.75BMT galvanised top hat roof batten in lieu of timber battens scheduled in Architectural T-Sheet. Proprietary Batten type to provide suitable width for seating and fixing of Ashgrid spacer;

- Dwg S1.02 [B] Spec Notes (*Timber Incl Prefabricated Elements Note 10*),
- Dwg S4.02 [B] Roof Framing Plan (*Member Schedule + Notes*)
- Dwg S6.03 [B] Roof Framing Details (*Typical Roof Build Up Details*),

Note: Architectural T-Sheet code RF-1 & RF-2 will be updated to reflect this tender clarification for IFC issue

Query 2 RF-1 and RF-2 Plywood Substrate

The T-Sheet references 17.5mm plywood in both RF-1 and RF-2 roof build-ups. Could you please confirm:

- *Plywood grade/specification.*
- *Treatment requirements (if any).*

Response:

Refer to Structural engineer's documents for Plywood (structural roof diaphragm) sheeting specification

Query 3 Roof Membrane – Parapet Flashing Detail

The parapet flashing detail shown on drawing A-72001 [T1] appears to indicate a roof membrane, however, we have been unable to locate a spec for this product.

Could you please confirm:

- *The required membrane product/system.*
- *Whether the membrane is required to both RF-1 & RF-2.*

Response:

Please refer to Architectural **Spec A[T2]-Appendix A - T-Sheet dated 21.05.26** for clarification of specified roof sarking to underside of metal roof sheeting (Reference codes RF-1 & RF-2).

Tender Document Clarification – Architectural Spec A[T2]-Appendix A - T-Sheet Supplier / Contact details

Please update supplier details for the following G3 Items

T-Sheet Reference: G3-MUB-1 / G3-CHR-6 / G3-CHR-1

Supplier / Contact

OKM Qld <https://okmqld.com.au/>

Nick Scriggins

0417 200 005

Correct/New email: nick.scriggins@okmqld.com.au

m3architecture and brian hooper architect

distribution

☐ All tenderers

☐ proprietor

☐ architect's file

☐

☐