

DIRECTORATE OF FACILITIES MANAGEMENT

ADDENDUM #11 TO:

Request for quotation

**Project: ROK TAFE Consolidation Stg.2
- Design and Construct**

**Number: CQURFQ-26-4-DFM
Addendum Issue Date:
08/04/2026**

Note: This Addendum, the Original Request for Quotation and any other documentation issued in relation to this Invitation should be retained by the Respondent for future reference.

1) Purpose of Addendum

The purpose of this Addendum is to provide additional information for intended Respondents with regard to CQUniversity RFQ, Reference: CQURFQ-26-4-DFM. The information has either become available post-issuance of the RFQ document or as a result of enquiries to date.

Note: The information provided under this Addendum must be interpreted in the context of the original RFQ document.

2) Clarifications

Question 1:

Could you please confirm which drawings show the correct extent of the external footpaths. Architectural drawing ARC-10-00-A and Landscape drawing L-00-DR300_3 appear to show different areas.

Answer 1:

Refer to new drawing CQU-ROK-092-GN-ARC-10-01 Revision A showing correct extent of external works & which drawing references further information can be found on.

Question 2:

Could you please provide a revised C110 Siteworks drawing with greater transparency for the proposed works, so that existing services and contours can be viewed more clearly.

Answer 2:

Refer to revision P3 of requested C110 drawing.

Site works plan C110 Existing Services are shown in colour to identify what is impacted – refer to legend. However we have grey scaled all existing services now for clarity – see attached Rev P3 of C110.

Question 3:

B92: The civil documents to not provide bulk earthworks quantities. Please provide earthworks quantities.

Answer 3:

There is a 200mm topsoil strip and Bulk Earthworks Vol (solid vols) Viol below taken from underside of slab and pavement box to below topsoil strip level

Cut – 518M3

Fill – 2735M3

Question 4:

Please confirm what floor finish type is for Outdoor Car Storage & External Driveway Areas. Architectural Drawings say to refer to the civil drawings, and the civil drawings say to refer to the architectural.

Answer 4:

Refer to new drawing CQU-ROK-092-GN-ARC-10-01 Revision A for details.

Question 5:

Could you please provide a revised C110 Siteworks drawing with greater transparency for the proposed works, so that existing services and contours can be viewed more clearly.

Answer 5:

Refer to revision P3 of requested C110 drawing.

Site works plan C110 Existing Services are shown in colour to identify what is impacted – refer to legend. However we have grey scaled all existing services now for clarity – see attached Rev P3 of C110.

Question 6:

WSP Struc & Civil: Following conversations with WSP their Struc and Civil teams have advised they are not in a position to

provide pricing for SP2 works. Could you please advise if we can use other non-nominated Struc/Civil consultants for the SP2 design.

Answer 6:

Yes, contractors can nominate alternative consultants for the SP2 design if the nominated subcontractor refuses or is unable to complete the work. Please refer clause 9.3 of the Contract.

Question 7:

Could you provide a luminaire schedule as nominated on the electrical drawings 'INDICATES TYPE. REFER TO THE SCHEDULE OF LUMINAIRES IN FOR DETAILS.'

Answer 7:

As a D&C project that was documented to 60% completion a luminaire schedule has not yet been selected. It is intended that the lighting is to be selected in the next project phase.

Below is the legend of symbols nominating the type of lighting:

LUMINAIRES	
Bx	BATTEN LIGHT SURFACE MOUNTED/SUSPENDED, SINGLE LAMP LUMINAIRE
Tx	RECESSED/SUSPENDED RECTANGULAR LUMINAIRE Dimensions: 1200x300 600x300
Dx	DOWNLIGHT
HB	HIGHBAY LIGHTING
FL	FLOODLIGHT
EMERGENCY LUMINAIRES & EXIT SIGNS	
EM	EMERGENCY LUMINAIRE
EX	EXIT SIGN
ES	SINGLE SIDED EXIT SIGN WITH DIRECTIONAL ARROW
ED	DOUBLE SIDED EXIT SIGN WITH DIRECTIONAL ARROW
B1E	BATTEN LIGHT WITH EMERGENCY LUMINAIRE INCORPORATED IN SURFACE MOUNTED/SUSPENDED, SINGLE LAMP LUMINAIRE

LUMINAIRES	
An	INDICATES TYPE. REFER TO THE SCHEDULE OF LUMINAIRES IN FOR DETAILS.
—	SURFACE MOUNTED/SUSPENDED, SINGLE LAMP LUMINAIRE
==	SURFACE MOUNTED/SUSPENDED, TWIN LAMP LUMINAIRE
□	RECESSED RECTANGULAR LUMINAIRE
⊙	RECESSED WALL MOUNTED LUMINAIRE
○	SURFACE MOUNTED WALL LUMINAIRE
○	DOWNLIGHT
○→	WALL MOUNTED DIRECTIONAL
FL	FLOODLIGHT
—○	POLE MOUNTED LUMINAIRE
—	LED STRP
—○—○—○	TRACK LIGHTING

Is the responsibility of the contractor to select luminaires and provide the relevant lighting calculation to AS1680. Refer to CQU Design Standards Manual section on Lighting. All lighting is to include Daylight Harvesting sensors.

Question 8:

We have approached the Selected Consultants regarding fee proposals for the remaining stages of work. One of the consultants has declined providing services to complete the documentation. To complete the project, we will be required to engage/select other consultants outside the Selected Consultants nominated in AS4902. Can you please confirm a new select consultant in replacement for WSP for all engineering services. Note with the change in consultant there will be a period of project initiation and learning, which will alter the design programme for the project.

Answer 8:

If a nominated subcontractor refuses or is unable to perform the work, contractors can nominate alternative consultants.. Please refer clause 9.3 of the Contract.

Question 9:

The WSP Electrical Spec notes that UPS battery systems should support 30min backup in 3.5.8 Cl 1 and 4.4 table, but 15min in 16.1 Cl 2. Could you please clarify whether UPS systems are to have 30min or 15min backup autonomy.

Answer 9:

30 Minutes.

Question 10:

Does only the new building ROK092 require a lightning protection system?

Answer 10:

Yes, only new ROK092 New Trades Building.

Question 11:

Some of the milestone completion dates stated in the document "Appendix A - Scope" are different from the completion dates stated in Contract (Appendix B). Could you please confirm the correct completion dates for the various portions?

Eg.

- Bldg 92 is 13 Dec 2027 in Appendix A and 28 April 2028 in the contract
- Bldg 36 is 28 April 2028 in Appendix A and 05 May 2028 in the contract

Answer 11:

Portion	Building	Date for completion
1.1	New Trades building ROK092	13 December 2027
1.2	Engineering Workshop ROK21A	25 September 2026
2.1	Building ROK033	7 May 2027
2.2	Building ROK019	16 July 2027
2.3	Building ROK034	28 August 2026
2.4	Building ROK036	28 April 2028
2.5	New Horticulture Workshop – Building ROK076	20 Nov 2026

Question 12:

Appendix A Scope documents notes "the contractor is to allow for the relocation of staff items" from existing buildings to the new building. Could you please clarify the extent of this requirement - does this include all office equipment, computers, printers etc, and does this include staff personal effects etc, and is there a requirement for reinstallation / reconnection etc.

Answer 12:

- Staff will relocate and setup their own computers, phones and personal items.
- CQU will relocate printers.
- Contractors will be required to relocate some teaching materials and other sundry items from each area (such as stationery, dry store food items from the Training Kitchen). However, these items will be boxed by staff and labelled with new location. Contractor is to simply lift and shift. Staff will unpack and place in new space.