

DIRECTORATE OF FACILITIES MANAGEMENT

ADDENDUM #3 TO:

Request for quotation

**Project: ROK TAFE Consolidation Stg.2
- Design and Construct**

**Number: CQURFQ-26-4-DFM
Addendum Issue Date:
11/03/2026**

Note: This Addendum, the Original Request for Quotation and any other documentation issued in relation to this Invitation should be retained by the Respondent for future reference.

1) Purpose of Addendum

The purpose of this Addendum is to provide additional information for intended Respondents with regard to CQUniversity RFQ, Reference: CQURFQ-26-4-DFM. The information has either become available post-issuance of the RFQ document or as a result of enquiries to date.

Note: The information provided under this Addendum must be interpreted in the context of the original RFQ document.

2) Clarifications

Item 1:

Please refer to **Attachment 1 – Technical Advice Note** regarding the three-phase power allowance for ROK092 (New Trades) and Building 21A (Engineering).

Please ensure that pricing for this equipment is included in your tender response, in the format provided in Attachment 1.

Item 2:

ROK092 - CAD classroom requires high-spec desktop PC's (supplied by CQU). These workstations require a double GPO and single data run for each station. Contractor to allow for this in pricing.