

INFORMATION REFLECTED ON THIS DRAWING REPRESENTS FIRE SERVICES DESIGN DEVELOPED FOR D&C TENDER ADVISE ONLY, AND SHOULD NOT BE REGARDED AS COMPLETE. THE D&C CONTRACTOR SHOULD REFER TO ALL ASSOCIATED ARCHITECTURAL AND OTHER DISCIPLINE DRAWINGS, PROJECT BRIEFS AND CLIENT REQUIREMENTS AND MAKE ADEQUATE ALLOWANCES FOR ALL NECESSARY FIRE SERVICES WORKS TO MEET THESE REQUIREMENTS, EQUIPMENT SCHEDULES AND COMPLIANCE WITH THE NCC & APPROPRIATE AUSTRALIAN STANDARDS

LEGEND OF SYMBOLS

PIPEWORK

	NEW FHR PIPEWORK (HYDRANT SYSTEM SUPPLY)
	NEW FHR SYSTEM PIPEWORK (POTABLE WATER SUPPLY)
	ASD SAMPLING PIPEWORK
	≤40 PIPEWORK
	≥80 PIPEWORK
	PIPE CROSSING
	PIPEWORK RISE OR FALL
	RISER
	PIPEWORK CONTINUATION
	BLANK FLANGE
	FLANGE CONNECTION
	CAPPED END

VALVES AND FITTINGS

	ISOLATION VALVE
	PRESSURE REDUCTION STATION
	MONITORED ISOLATION VALVE
	CHECK VALVE
	PRESSURE RELIEF VALVE
	ALARM VALVE
	PRE-ACTION VALVE
	STRAINER
	FLOW SWITCH
	PRESSURE SWITCH
	PRESSURE GAUGE WITH BALL VALVE GAUGE COCK
	WATER MOTOR ALARM GONG
	ANNUBAR
	ORIFICE PLATE
	REMOTE TEST FACILITY
	DUAL HEAD BOOSTER CONNECTION
	QUADRANT HEAD BOOSTER CONNECTION
	WATER METER
	PIPE TO DRAIN
	PRESSURE REDUCTION STATION
	SPRINKLER CONTROL ASSEMBLY
	SPRINKLER CONTROL VALVE
	TANK SUCTION BRIGADE CONNECTION

SPRINKLERS

	BELOW CEILING SEMI-RECESSED PENDENT
	BELOW CEILING SEMI-RECESSED PENDENT WITH BAFFLE
	EXPOSED PENDENT
	CONCEALED SPACE PENDENT
	INSIDE DUCT/AHU PENDENT
	EXPOSED PENDENT UNDER-DUCTWORK
	EXPOSED PENDENT WITH BAFFLE
	DELUGE / OPEN PENDENT
	DRY PENDENT
	ESFR PENDENT
	FLUSH PENDENT
	INSTITUTIONAL PENDENT
	SIDEWALL VERTICAL / HORIZONTAL
	SIDEWALL TYCO WINDOW SPRINKLER
	SIDEWALL WITH BAFFLE
	EXPOSED UPRIGHT
	CONCEALED SPACE UPRIGHT

HYDRANT, HOSE REEL & PORTABLE EQUIPMENT

	FIRE HOSE REEL
	FIRE HYDRANT
	EXTERNAL DUAL PILLAR FIRE HYDRANT
	PUMP
	DE - DIESEL
	EL - ELECTRIC
	J - JACKING
	FIRE EXTINGUISHER
	A - WET CHEMICAL
	C - CARBON DIOXIDE
	D - DRY POWDER
	F - FOAM
	W - WATER
	FIRE BLANKET

GAS SUPPRESSION

	SPECIAL HAZARDS CONTROL AND INDICATING EQUIPMENT
	LOCAL CONTROL STATION (WITH STOP AND RELEASE GAS CONTROLS)
	ACOUSTIC GAS NOZZLE
	NOVEC GAS STORAGE CYLINDER
	INERT GAS STORAGE CYLINDER
	EXTINGUISHING SYSTEM INOPERATIVE VISUAL WARNING DEVICE
	FIRE ALARM DO NOT ENTER VISUAL WARNING DEVICE
	FIRE ALARM EVACUATE AREA VISUAL WARNING DEVICE

FIRE DETECTION

	HEAT DETECTOR EXPOSED
	HEAT DETECTOR CONCEALED SPACE
	HEAT DETECTOR SUB-FLOOR
	HEAT ALARM
	HEAT DETECTOR WITHIN DUCTWORK
	WIRELESS HEAT DETECTOR CONCEALED SPACE
	WIRELESS HEAT DETECTOR EXPOSED
	HEAT DETECTOR EXPOSED WITH GUARD
	SMOKE DETECTOR EXPOSED
	SMOKE DETECTOR CONCEALED SPACE
	SMOKE DETECTOR SUB-FLOOR
	SMOKE ALARM
	SMOKE DETECTOR DUCTWORK SAMPLING
	WIRELESS SMOKE DETECTOR EXPOSED
	WIRELESS SMOKE DETECTOR CONCEALED SPACE
	MULTI-SENSOR DETECTOR
	SMOKE DETECTOR EXPOSED WITH GUARD
	LINEAR BEAM SMOKE DETECTOR TRANSMITTER
	LINEAR BEAM SMOKE DETECTOR REFLECTOR
	FLAME DETECTOR EXPOSED
	REMOTE INDICATOR
	WIRELESS DETECTION TRANSLATOR MODULE
	FAMCO BRACKET CW REMOTE INDICATOR (SMOKE DETECTOR)
	FAMCO BRACKET CW REMOTE INDICATOR (HEAT DETECTOR)
	ASPIRATING SMOKE DETECTOR
	ASD SAMPLE POINT EXPOSED/BELOW CEILING
	ASD SAMPLE POINT CONCEALED SPACE

COLOUR SCHEDULE

	NEW DETECTION & ALARM SYSTEM DEVICES
	NEW PORTABLE FIRE EQUIPMENT
	NEW ASD SYSTEM
	NEW HYDRANT & HOSE REEL SYSTEM
	NEW HOSE REEL SYSTEM
	NEW GAS SUPPRESSION SYSTEM
	NEW DELUGE SPRINKLER SYSTEM
	NEW FREEZER SPRINKLER SYSTEM
	NEW PRE-ACTION SPRINKLER SYSTEM
	NEW WET PIPE SPRINKLER SYSTEM
	SERVICES TO BE DEMOLISHED
	EXISTING SERVICES

FIRE SYSTEM DEVICES

	ELECTROMAGNETIC DOOR HOLD OPEN DEVICE
	MIMIC PANEL
	EMERGENCY WARNING CONTROL AND INDICATING EQUIPMENT
	FIRE DETECTION CONTROL AND INDICATING EQUIPMENT
	FIRE FAN CONTROL PANEL
	PANEL SPATIAL PLACEHOLDER
	WARDEN INTERCOM POINT PHONE
	24V SUPERVISED DOOR CONTROLLER INTERFACE
	MSSB INTERFACE
	ADDRESSABLE DEVICE RELAY MODULE
	DISTRIBUTION BOARD INTERFACE
	AUDIO VISUAL SYSTEM GFA INTERFACE
	MONITORED VALVE INTERFACE
	SECURITY SYSTEM INTERFACE
	PRESSURE SWITCH INTERFACE
	FLOW SWITCH INTERFACE
	FUME CUPBOARD INTERFACE
	GAS SOLENOID VALVE FIRE TRIP INTERFACE
	FIRE PUMP PANEL INTERFACE
	CONE SPEAKER SURFACE MOUNTED
	CONE SPEAKER RECESSED
	HORN SPEAKER
	DUAL STROBE VISUAL ALARM DEVICE
	INTERNAL VISUAL ALARM DEVICE
	EXTERNAL VISUAL ALARM DEVICE
	EMERGENCY MANUAL CALL POINT (WHITE)
	MANUAL CALL POINT (RED)
	FIRE ALARM EVACUATE AREA VISUAL WARNING DEVICE
	END OF LINE DEVICE
	EMERGENCY PHONE JACKING POINT
	INCOMING 24V SUPPLY (BY OTHERS)

LINE-TYPE SCHEDULE

	NEW / EXISTING
	EXISTING SERVICES TO BE DEMOLISHED
	RELOCATE SERVICES

NOMENCLATURE

AHU	AIR HANDLING UNIT
ASD	ASPIRATING SMOKE DETECTION
ASE	ALARM SIGNALING EQUIPMENT
BMS	BUILDING MANAGEMENT SYSTEM
BOMS	BUILDING OCCUPANT WARNING SYSTEM
CIE	CONTROL AND INDICATING EQUIPMENT
CW	COMPLETE WITH
CV	CHECK VALVE
D	DEMOLISH / DECOMMISSION
DA	DUCT / AHU
DB	DISTRIBUTION BOARD
DOW	DOMESTIC POTABLE WATER
DN	DIMENSION NOMINAL
DPICE	DISTRIBUTED PART OF CIE
DPFH	DOUBLE PILLAR FIRE HYDRANT
DR	DRAIN
DSP	DELUGE SPRINKLER SYSTEM
E	EXISTING
ECP	EMERGENCY CONTROL PANEL
EICE	EMERGENCY INTERCOM CIE
ESFR	EARLY SUPPRESSION, FAST RESPONSE
EWICE	EMERGENCY WARNING CIE
FA	FROM ABOVE
FB	FROM BELOW
FC	FUME CUPBOARD
FDICE	FIRE DETECTION CIE
FI	FIRE HYDRANT
FHR	FIRE HOSE REEL
FP	FIRE INDICATOR PANEL
FS	FIRE SPRINKLER
FSSB	FIRE SERVICE BASE BUILD SUPPLY
FSSR	FIRE SERVICE BRIGADE RELAY SUPPLY
FSF	FREEZER SPRINKLER SYSTEM
FSPRA	PRE-ACTION SPRINKLER SYSTEM
FTD	FIRE TEST DRAIN
G	GUARD
GFA	GENERAL FIRE ALARM
GS	GASEOUS SUPPRESSION
GV	GATE VALVE
H	KITCHEN EXHAUST HOOD
HJL	HIGH-LEVEL INTERFACE
IGFH	INGROUND SPRING FIRE HYDRANT
IO	INPUT / OUTPUT
IP	INGRESS PROTECTION
IV	ISOLATION VALVE
KE	KITCHEN EXHAUST
LED	LIGHT EMITTING DIODE
LO	LOOKED OPEN
LS	LOOKED SHUT
M	MONITORED IN DEVICE
MEICE	MASTER EVICE
MEICE	MASTER EVICE
MFDICE	MAIN FIRE DETECTION CIE
MSSB	MECHANICAL SERVICES SWITCHBOARD
N	NEW
NC	NORMALLY CLOSED
NO	NORMALLY OPEN
R	RELOCATE
RA	RETURN AIR
RE	REPLACE
SA	SUPPLY AIR
SEWICE	SECONDARY EWICE
SEICE	SECONDARY EICE
SFDICE	SUB FIRE DETECTION CIE
SHDICE	SPECIAL HAZARDS CIE
TA	TO ABOVE
TB	TO BELOW
UD	UNDER DUCT
UG	UNDERGROUND

B	12/02/2024	JO	ISSUED FOR D&C TENDER	JS	SM
A	16/02/2024	JO	DRAWINGS TO BE SUBMITTED FOR REVIEW	JS	SM
REV	DATE	BY	DESCRIPTION	CHK	APP

DESIGN DEVELOPMENT



900 Ann Street, Level 12, Fortitude Valley 4006
Tel: +61-7-3854-6200 Fax: +61-7-3854-6500
<http://www.wsp.com>

CLIENT: CQU

ARCHITECT: THOMSON ADSETT / PEDDLE THORP

PROJECT: CQU ROCKHAMPTON TAFE CONSOLIDATION

TITLE: FIRE PROTECTION SERVICES
GENERAL NOTES, LEGENDS & SYMBOLS

SCALE @ A1	N.T.S	CHECKED	JS	APPROVED	SM
PROJECT NUMBER	PS229618	DRAWN	JO	DATE	JAN 2026

DRAWING No	00-FP-DR-010-A00-00-00	REV	B
------------	------------------------	-----	---

© WSP Australia Pty Ltd