



DESIGN CRITERIA & GENERAL NOTES:

1. DRAWINGS TO BE READ IN CONJUNCTION WITH THE FIRE ENGINEERING BRIEF (FEB) AND CERTIFIER'S ICA ASSESSMENT REPORT.
2. DRAWINGS TO BE READ IN CONJUNCTION WITH THE FIRE PROTECTION SERVICES REPORT, ARCHITECTURAL, STRUCTURAL, CIVIL AND ALL OTHER BUILDING SERVICES DOCUMENTATION.
3. FIRE SERVICES TO BE PROVIDED IN ACCORDANCE WITH NCC 2022 AND FIRE SAFETY ENGINEERING BRIEF.
4. DETECTION SYSTEM NETWORK AND CABLING TO BE DESIGNED AND INSTALLED IN ACCORDANCE WITH AS 1670.1-2018.

INFORMATION REFLECTED ON THIS DRAWING REPRESENTS FIRE SERVICES DESIGN DEVELOPED FOR D&C TENDER ADVISE ONLY, AND SHOULD NOT BE REGARDED AS COMPLETE. THE D&C CONTRACTOR SHOULD REFER TO ALL ASSOCIATED ARCHITECTURAL AND OTHER DISCIPLINE DRAWINGS, PROJECT BRIEFS AND CLIENT REQUIREMENTS AND MAKE ADEQUATE ALLOWANCES FOR ALL NECESSARY FIRE SERVICES WORKS TO MEET THESE REQUIREMENTS, EQUIPMENT SCHEDULES AND COMPLIANCE WITH THE NCC & APPROPRIATE AUSTRALIAN STANDARDS

CONNECT NEW UNDERGROUND FIBRE NETWORK CABLING CONDUIT INTO EXISTING COMMS PIT.

PROVIDE NEW UNDERGROUND DEDICATED FIRE CONDUIT AND FIBRE CABLING FROM NEW COMMS ROOM TO EXISTING COMMS PIT.

NEW FIBOT (FIBRE OPTIC BREAK OUT TRAY) AND FIRE RATED ENCLOSURE IN NEW COMMS ROOM.

FIRE RATED FIBRE NETWORK CABLING TO RETICULATE FROM SFDOE TO FIBOT IN NEW COMMS ROOM.

NEW SFDOE TO BE NETWORKED WITH EXISTING CAMPUS DETECTION SYSTEM IN BUILDING ROOF.

PROVIDE NEW FIBRE NETWORK CABLING AND 025 CORRUGATED CONDUIT INSIDE EXISTING UNDERGROUND COMMS CONDUIT AND PIT SYSTEM.

EXISTING CONDUIT RUN INDICATIVE ONLY. EXACT ROUTE TO BE CONFIRMED ON SITE BY FIRE CONTRACTOR.

NEW FIBOT AND FIRE RATED ENCLOSURE WHERE UNDERGROUND CONDUIT RISES INTO THE BUILDING.

EXISTING MFDOE TO BE NETWORKED WITH NEW SFDOE TO FACILITATE CONNECTION INTO CAMPUS DETECTION SYSTEM AND ASE.

B	12/02/2026	JO	ISSUED FOR D&C TENDER	JS	SM
A	16/02/2026	JO	DRAWINGS TO BE ISSUED FOR REVIEW	JS	SM
REV	DATE	BY	DESCRIPTION	CHK	APP

DESIGN DEVELOPMENT



900 Ann Street, Level 12, Fortitude Valley 4006
Tel: +61-7-3854-6200 Fax: +61-7-3854-6500
<http://www.wsp.com>

CLIENT:

CQU

ARCHITECT:

THOMSON ADSETT / PEDDLE THORP

PROJECT:

CQU ROCKHAMPTON TAFE CONSOLIDATION

TITLE:

FIRE PROTECTION SERVICES
FIRE PROTECTION SERVICES - PROPOSED SITE PLAN

SCALE @ A1:

1:400

DRAWN:

JO

APPROVED:

SM

PROJECT NUMBER:

PS229518

DATE:

JAN 2026

DRAWING NO:

00-FP-DR-300-A00-00-00

REV:

B

© WSP Australia Pty Ltd