



DRAINAGE NOTES:

1. ALLOW ALL COSTS TO CONNECT SANITARY DRAINAGE TO ALL FIXTURES AS REQUIRED.
2. CO-ORDINATE WITH FLOOR SLAB LOCATIONS WITH ARCHITECT AND IN COMPLIANCE WITH THE NCC (AS3500.2, AS3542.1).
3. ALLOW FOR PROVISION OF AN INLET IN COMPLIANCE WITH AS/NZS3502.1 TO ALLOW COMPLETE DRAIN ACCESS TO ALL DRAIN LINES CONNECTING MULTIPLE FIXTURES.
4. DOCUMENTATION MAY NOT INDICATE ALL VENTING REQUIREMENTS AND SHALL BE DETERMINED DURING FLOOR CONSTRUCTION DEVELOPMENT. VENTING REQUIREMENTS TO BE IN ACCORDANCE WITH AS/NZS3502.1.
5. ALL PENETRATIONS OR CAST THROUGH CONCRETE STRUCTURE ARE TO BE APPROVED BY THE STRUCTURAL ENGINEER.
6. ALL REDUNDANT PENETRATIONS THROUGH STRUCTURAL ELEMENTS ARE TO BE MADE GOOD TO THE SATISFACTION OF THE STRUCTURAL ENGINEER.
7. SERVICES PASSING THROUGH A FIRE RATED STRUCTURE SHALL HAVE FIRE STOPPING (OR OTHER APPROVED FIRE PROTECTION METHOD) RATED TO THE MINIMUM RFL OF THE STRUCTURE IT IS PENETRATING.
8. WHERE PLASTIC SLEEVES AND PIPEWORK PASS THROUGH STRUCTURE WHICH IS TO BE FIRE RATED, PROVIDE APPROVED FIRE COLLARS INSTALLED TO THE NCC CODES AND THE MANUFACTURERS REQUIREMENTS TO ENSURE OBTAINING COMPLETELY CLOSED JOINTS AT POINT OF PENETRATION.
9. VERIFY THAT ALL MECHANICAL DISCHARGE TEMPERATURES DO NOT EXCEED THE MAXIMUM ASSOCIATED WITH THE PIPEWORK MATERIAL. MECHANICAL CONTRACTOR TO PROVIDE DRAIN TEMPERING VALVE PRIOR TO DISCHARGE AS REQUIRED.
10. CO-ORDINATE WITH ARCHITECT, AND PROVIDE THRESHOLD PROTECTION AT ALL ENTRY POINTS TO THE BUILDING AS REQUIRED TO PREVENT THE INGRESS OF WIND DRIVEN RAIN.