

LEGEND OF SYMBOLS

LUMINAIRES

At	INDICATES TYPE. REFER TO THE SCHEDULE OF LUMINAIRES IN FOR DETAILS.
	SURFACE MOUNTED/SUSPENDED, SINGLE LAMP LUMINAIRE
	SURFACE MOUNTED/SUSPENDED, TWIN LAMP LUMINAIRE
	RECESSED RECTANGULAR LUMINAIRE
	RECESSED WALL MOUNTED LUMINAIRE
	SURFACE MOUNTED WALL LUMINAIRE
	DOWNLIGHT
	WALL MOUNTED DIRECTIONAL TWIN LAMP LUMINAIRE
	FLOODLIGHT
	POLE MOUNTED LUMINAIRE
	LED STRP
	TRACK LIGHTING

LIGHTING/SWITCHING CONTROL

	ONE-WAY SWITCH, SINGLE POLE 10A FLUORESCENT RATED
	TWO WAY SWITCH, 10A FLUORESCENT RATED
	SWITCHING SHOWN CONNECTED
	SWITCHING SHOWN UNCONNECTED
	SWITCHING ARROW
LCP	LIGHTING CONTROL PANEL
RIU	REFRACTIVE INDEX UNIT
	MOTION DETECTOR
DL	DAYLIGHT

SYMBOLIC REPRESENTATION OF WORKSTATION REQUIREMENTS

	OFFICE WORKSTATION - 4 OFF 10A 240V SINGLE SWITCHED SOCKET OUTLETS - 2 OFF R4S CATEGORY 6A COMMUNICATIONS OUTLETS MOUNTED ABOVE BENCH POWER OUTLETS SORT WIRED (CONNECT TO ADJACENT STARTER SOCKET)
--	---

EMERGENCY LUMINAIRES & EXIT SIGNS

n	INDICATES TYPE. REFER SCHEDULE OF LUMINAIRES FOR DETAILS AND AS 2293 CLASSIFICATIONS
	EMERGENCY LUMINAIRE
	EXIT SIGN
	SINGLE SIDED EXIT SIGN WITH DIRECTIONAL ARROW
	DOUBLE SIDED EXIT SIGN WITH DIRECTIONAL ARROW
	EMERGENCY LUMINAIRE INCORPORATED IN SURFACE MOUNTED/SUSPENDED, SINGLE LAMP LUMINAIRE
	EMERGENCY LUMINAIRE INCORPORATED IN SURFACE MOUNTED/SUSPENDED, TWIN LAMP LUMINAIRE
	EMERGENCY LUMINAIRE INCORPORATED IN RECESSED LUMINAIRE

POWER

n	INDICATES RATING IN AMPS. 10 AMPS UNLESS OTHERWISE NOTED
	10A 240V SINGLE SWITCHED SOCKET OUTLET (GPO)
	10A 240V MULTIPLE SWITCHED SOCKET OUTLET (GPO)
y - NUMBER OF OUTLETS	
	MULTI-PHASE SWITCHED SOCKET OUTLET
x - NUMBER OF PHASES	
	10A 240V DOUBLE SWITCHED SOCKET OUTLET (DGPO)
	10A 240V DOUBLE SWITCHED SOCKET OUTLET (DGPO) COMPLETE WITH TWO USB CHARGING PORT

	ON-LOAD ISOLATOR (M PROVISION TO LOCK IN OPEN POSITION
x - NUMBER OF PHASES	
	FLOOR BOX TYPE ONE, COMPLETE WITH 4 OFF 10A 240V SINGLE SWITCHED SOCKET OUTLETS
- 2 OFF R4S CATEGORY 6A COMMUNICATIONS OUTLETS	

	FLOOR BOX TYPE TWO, COMPLETE WITH 4 OFF 10A 240V SINGLE SWITCHED SOCKET OUTLETS
- 3 OFF R4S CATEGORY 6A COMMUNICATIONS OUTLETS	

	SERVICE POLE
	MAIN SWITCHBOARD (MSB)
	DISTRIBUTION BOARD
	DISTRIBUTION BOARD BY OTHERS
	MSSB MECHANICAL SERVICES SWITCHBOARD

	JUNCTION BOX
	SKIRTING DUCT, DIVISIONS INDICATE NO. OF CHANNELS
	DB ZONE BOUNDARY

x Øn eg PC Ø100	
PC Ønx	CONDUIT TAGS
Ex PC Ønx	x - DENOTES SERVICE TYPE
	n - DENOTES DIAMETER (mm)
	Ex - DENOTES EXISTING

HVC Ønx	LV POWER CONDUIT
Ex HVC Ønx	
HVC Ønx	HV POWER CONDUIT
Ex HVC Ønx	
CC Ønx	COMMUNICATIONS CONDUIT
Ex CC Ønx	

x	CABLE LADDER/TRAY TAGS
x -	x - DENOTES SERVICE TYPE
n	n - DENOTES WIDTH (mm)
m	m - DENOTES FINISH FLOOR LEVEL (mm)
Ex -	Ex - DENOTES EXISTING

FT	LV POWER CABLE LADDER/TRAY
n	
m	
Ex -	

CT	COMMUNICATIONS CABLE LADDER/TRAY
n	
m	
Ex -	

COMMUNICATIONS

	RJ45 TELECOMMUNICATIONS OUTLET CATEGORY 6A
n	n INDICATES NUMBER OF POINTS
	DUAL RJ45 TELECOMMUNICATIONS OUTLET CATEGORY 6A
	TRIPLE RJ45 TELECOMMUNICATIONS OUTLET CATEGORY 6A
	MATV SIGNAL OUTLET
TV	MATV

SECURITY

	DOOR MONITOR (REED RELAY)
	ELECTRIC LOCK
EM	ELECTROMAGNETIC
ES	ELECTRIC STRIKE
	REQUEST TO EXIT BUTTON
	PUSH BUTTON (DOORBELL)
	CARD READER
	ELECTROMAGNETIC DOOR HOLD OPEN DEVICE
B	INDICATES WITH BUZZER
OFM	FIRE MODE OPEN
	CLOSED CIRCUIT TELEVISION CAMERA

LIGHTNING PROTECTION AND EARTHING

	EARTH
	DOWN CONDUCTOR
	EARTH STAKE AND CABLE PIT
	LIGHTNING PROTECTION CONDUCTOR
	FINAL
n -	n - LENGTH IN METRES

TENANCY LINE-TYPE SCHEDULE

	NEW
	EXISTING TO REMAIN
	EXISTING EQUIPMENT TO BE REMOVED AND DISPOSED
	RELOCATE EQUIPMENT

NOMENCLATURE

AB	ABOVE BENCH
ATC	AUTO CLAVE
AV	SUPPLIED FROM AUDIO VISUAL DISTRIBUTION BOARD
BM	BAIN MARIE
BWU	BOILING WATER UNIT
CFM	COFFEE MACHINE
CL	CLEANERS OUTLET
CM	CEILING MOUNTED
CO	COMBI OVEN
CP	COINMITS PIT
CR	CRANE
DM	DRILLING MACHINE
DW	DISHWASHER
EP	ELECTRICAL PIT
F	FRIDGE
FP	FIRE INDICATION PANEL
FRY	FRYER
FW	FOOD WARMER
GD	GRODLE
HL	HIGH LEVEL
HP	HOT PLATE
HV	HIGH VOLTAGE
HWU	HOT WATER UNIT
IC	ICE MACHINE
LC	LOW VOLTAGE
MB	MOBILE BEER
MM	MIX MACHINE
MW	MICROWAVE
OV	OVEN
P	PRINTER/PHOTOCOPIER
POS	POINT OF SALE
PW	PIE WARMER
PCD	PCD PROTECTED
REF	REFRIGERATOR
SAL	ELECTRIC SALAMANDER
SL	STRIP LED LIGHTING
SM	STOCK MAKER
ST	STARTER SOCKET
STV	STONE
UB	UNDER BENCH
UPS	SUPPLIED FROM UPS DISTRIBUTION BOARD
UG	UNDERGROUND
VM	VENDING MACHINE
WAN	WIRELESS ACCESS NETWORK
WAP	WIRELESS ACCESS POINT
WP	WEATHER PROTECTED (P56)

E	EXISTING TO REMAIN
R	RELOCATED
D	DELETED
N	NEW

ELECTRICAL SCHEMATICS

	SINGLE PHASE
	TWO PHASE
	THREE PHASE
	BUSBAR
n	n INDICATES BUSBAR RATING IN AMPS
IsC	INDICATES AVAILABLE SYMMETRICAL FAULT LEVELS
	CIRCUIT LINE (SCHEMATICS)
	CONTROL WIRING (SCHEMATICS)
	JOINED
	JUMPED
	HRC FUSE
n	n FUSE RATING IN AMPS
m	m HOLDER RATING IN AMPS
FCL	FAULT CURRENT LIMITER
	COMBINATION FUSE SWITCH UNIT
n	n FUSE RATING IN AMPS
m	m MAXIMUM FUSE RATING IN AMPS
HRC	HIGH RUPTURE CAPACITY
	ISOLATOR SWITCH
n	n RATING IN AMPS
	ON-LOAD ISOLATOR
n	n RATING IN AMPS
	CIRCUIT BREAKER
n	n RATING IN AMPS
m	m MAXIMUM RATING IN AMPS
ACB	AIR CIRCUIT BREAKER
	SPACE FOR FUTURE CIRCUIT BREAKER
n	n RATING IN AMPS
	CURRENT TRANSFORMER
xy	xy INDICATES TRANSFORMER CURRENT RATIO
	TRANSFORMER
	MULTI-FUNCTION METER
	SHUNT SURGE DIVERTER
	INVERTER/RECTIFIER

INFORMATION REFLECTED ON THIS DRAWING REPRESENTS ELECTRICAL SERVICES DESIGN DEVELOPED FOR D&C TENDER ADVISE ONLY, AND SHOULD NOT BE REGARDED AS COMPLETE. THE D&C CONTRACTOR SHOULD REFER TO ALL ASSOCIATED ARCHITECTURAL AND OTHER DISCIPLINE DRAWINGS, PROJECT BRIEFS AND CLIENT REQUIREMENTS AND MAKE ADEQUATE ALLOWANCES FOR ALL NECESSARY ELECTRICAL SERVICES WORKS TO MEET THESE REQUIREMENTS, EQUIPMENT SCHEDULES AND COMPLIANCE WITH THE NCC & APPROPRIATE AUSTRALIAN STANDARDS

B	12.02.2020	MM	ISSUED FOR D&C TENDER	TP	SM
A	10.02.2020	MM	ISSUED FOR D&C TENDER	TP	SM
REV	DATE	BY	DESCRIPTION	CHK	APP

DESIGN DEVELOPMENT



900 Ann Street, Level 12, Fortitude Valley 4006
Tel: +61-7-3854-6200 Fax: +61-7-3854-6500
<http://www.wsp.com>

CLIENT: CQU

ARCHITECT: THOMSON ADSETT / PEDDLE THORP

PROJECT: CQU ROCKHAMPTON TAFE CONSOLIDATION

TITLE: ELECTRICAL SERVICES
GENERAL NOTES, LEGENDS & SYMBOLS

SCALE @ A1	N.T.S	CHECKED	TP	APPROVED	SM
PROJECT NUMBER	PS229518	DRAWN	MM	DATE	JAN 2020

DRAWING NO.	00-EL-DR-010-A00-00-00	REV.	B
-------------	------------------------	------	---

© WSP Australia Pty Ltd