AL RASD LAND SURVEYING OFFICE
Licensed land surveyors, Riyadh (fictional)


SITE SURVEY NOTE
Ref. SS-03

Project: Najd Gate Mixed-Use Tower
Location: Plot 7, Al Malqa District, Riyadh
Prepared for: Dune Line Engineering Consultants (the Engineer)
Date of survey: 18 February 2026
Surveyed by: Eng. Hamad Al-Subaie

OBSERVATIONS

1. Existing water main at 2.4 m depth along the northern boundary. 600 mm ductile iron pipe, located by trial pits TP-1 and TP-2. Keep shoring and ground anchors at least 3 m clear of it.
2. Temporary benchmark TBM-02 set on the north-east boundary wall: level 612.450 m above mean sea level.
3. Overhead 13.8 kV power line along the eastern boundary, 9.5 m above ground. To be diverted before piling starts.
4. Two existing date palms near the south-west corner, to be relocated by the Employer.
5. Ground level falls about 1.2 m from south to north across the plot.

SKETCH (NOT TO SCALE)



REMARKS

Confirm the water main position with the water authority records before any excavation near the north side.

Surveyed by: Eng. Hamad Al-Subaie

AL RASD CHECKED

Fictional sample document generated for testing Atlas.