


Corona effect in transmission line



Notes:

* CORONA *

On high voltage transmission line in Rainy day a faint luminous glow of bluish colour appears along the length of conductor & hissing sound is heard.

The bluish discharge is known as Corona and ozone (O_3) gas released.

* Critical Disruptive Voltage (V_d) :-

Lowest Voltage at which ionization starts.

* Critical Visual Voltage (V_c) :-

Lowest voltage at which corona appears.

Corona occurs when electrostatic stress in the air around conductor exceeds :-

21.1 kV/cm	— rms
30 kV/cm	— maximum

Factor Affecting Corona :-

* Corona \propto Voltage

* Corona $\propto \frac{1}{\text{distance between conductor (d)}}$

Reduction of Corona :-

- * Distance b/w conductor increased \uparrow
- * Large diameter conductor using
- * By using ACSR conductor

$$\text{Corona} \propto \frac{1}{\text{Radius of Conductor (r)}}$$

Corona in stranded conductor $>$ Corona in plain conductor

Corona in rough surface $>$ smooth surface

Corona in rainy day $>$ Summer day

Advantage :-

- * Reduction in transient effect.

- * High voltage wave energy loss in form of corona.
- * Effective size of conductor increased.
- * Current carrying capacity of conductor increased

Disadvantage :-

- * Power loss increased \uparrow
- * Transmission efficiency decreases \downarrow
- * Third harmonic wave generated & interrupts nearest communication line.
- * It makes conductor surface rough & conductor becomes weak by corona

Amit Kumar Pandey