

Non Domestic Gas Safety Record



Registered Business Details:

GAS SAFE NO: **184160**
Gas Operative : George Hogg 2 **5912081**
Name : Guardian Environmental Services Limited
Address : 117 Clophill Road, Maulden
Bedfordshire
PostCode : MK45 2AE Telephone : 01525 862208

Form Serial Number: FRM/PM0004510/001

Job Address:
Name : HFS Hillside House
Address : 86 Winter Street, Sheffield
PostCode : S3 7EL
URN :

Contact : Sophie Gillott
Telephone : +447729077416

Client Landlord's Details:
Name : Homes For Students Limited
Address : Hornbeam House, Hornbeam Park, Hookstone Road
Harrogate,
PostCode : HG2 8QT Telephone : +441423740683
Rented Accommodation : No No of appliance tested : 4
Visual check to ensure burner pressure + FGAS test points have been replaced? Yes

Additional Work Carried Out:
PRV Lift Pressure Recored at: N/A
Visual check to ensure burner pressure + FGAS test points have been replaced:
New burner gaskets and ignition and flame rectification probes are needed for next service

Appliance Details										Inspection Details									
Location	Type	Make	Model	Landlords Appliance	Appliance Inspected	Flue Type	Operating Pressure	Device Correct Operation	Ventilation Provision Satisfactory	Visual Condition of Flue	Termination Satisfactory	Flue Performance Check	CO PPM	CO2%	CO/ CO2 Ratio	Spillage Test	Appliance Serviced	Safe To Use	
1	Plant Room	Gas fired water heater no1 High fire	AO Smith Cyclone BFC 120	Yes	Yes	OF	21.2 Mbars	Yes	Yes	Pass	Pass	N/A	3	9.0	00000	N/A	Yes	Yes	
2	Plant Room	Gas fired water heater no 1 low fire	AO Smith Cyclone BFC 120	Yes	Yes	OF	24.1 Mbars	Yes	Yes	Pass	Pass	N/A	0	8.8	00000	N/A	Yes	Yes	
3	Plant Room	Gas fired water heater no2 High fire	AO Smith Cyclone BFC 120	Yes	Yes	OF	20.8 Mbars	Yes	Yes	Pass	Pass	N/A	3	9.1	00000	N/A	Yes	Yes	
4	Plant Room	Gas fired water heater no 2 low fire	AO Smith Cyclone BFC 120	Yes	Yes	OF	24.3 Mbars	Yes	Yes	Pass	Pass	N/A	0	8.9	00000	N/A	Yes	Yes	

Defect Details					
Appliance #	Defect Identified		Remedial Action		Warning Label Fitted
1					
2					
3					

Smoke/ CO Alarm Details						
	Location	Type	Approved Alarm Fitted	Alarm Expiry	Testing of Alarm Satisfactory	Battery/ Hard wired
1	Plant room	CO	Yes	N/A	N/A	Hard wired
2						

Gas installation pipework satisfactory visual inspection	Yes
Emergency control accessible	Yes
Satisfactory gas tightness test	Yes
Equipotential bonding satisfactory	Yes

This safety record is issued by: Signed			Printed name	George Hogg 2
Received by: Sophie gillott				
Date:		06-Oct-2025	Certificate Expiry 06/10/2026	