



Electrical Workers Registration Board

SAFETY | COMPETENCY | COMPLIANCE

Electrical Certificate of Compliance and Electrical Safety Certificate

Reference/Certificate ID No: New RCD's.



This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under **Part 1 or Part 2 of AS/NZS 3000** are safe to be connected to the **specified** system of electrical supply.

LOCATION AND CONTACT

Location Details	<u>8 Hague Place Birkenhead</u>	Contact Address	
Contact Name	<u>Eddie Alison</u>	Postcode	
Name of Electrical worker:	<u>Brent Ruijne</u>	Registration/Practising licence number:	<u>E250044</u>
Organisation/ company:	<u>Blue Light Electrical Ltd</u>		
Phone:	<u>027 572 7000</u>	Email:	<u>brentruijne@gmail.com</u>
Name of person(s) supervised:	<u>Eddie Eddie</u>		

CoC

Type of work:	<input type="radio"/> Additions	<input checked="" type="radio"/> Alterations	<input type="radio"/> New work
The prescribed electrical work is:	<input type="radio"/> Low risk	<input type="radio"/> General	<input checked="" type="radio"/> High risk (specify):
Reference Standards:	<input type="radio"/> Part 1 of AS/NZS 3000	<input checked="" type="radio"/> Part 2 of AS/NZS 3000	
	<input type="radio"/> Additional Standards:		

Description of work: (including date/s of work and type of supply system)

Inspected new RCD's on switchboard. Time to trip 30msec and 28 msec.
Resistance of main earthing conductor 0.1Ω
Tested power points and new light fittings.

I certify that the completed prescribed electrical work to which this Certificate of Compliance applies has been done lawfully and safely, and the information in the certificate is correct in that the installation, or part of the installation:

Select those that apply:

- ☐ Has been installed in accordance with the specified certified design¹
- ☒ Has an earthing system that is correctly rated (where applicable)
- ☒ Contains fittings that are safe to connect to a power supply
- ☐ Relies on a supplier Declaration of Conformity¹
- ☒ Has been satisfactorily tested in accordance with the Electricity (Safety) Regulations 2010
- ☒ Is safe to connect

Electronic/Other reference: New RCD's

Certifier's signature: Brent Ruijne

Test Results	
Polarity (independent earth):	
Insulation resistance:	
Earth Continuity:	
Bonding:	
Fault Loop impedance:	
Other (specify):	

Date: 2 / 7 / 2025

¹ Attach or reference. If it is impractical to attach a copy of a particular manufacturer's instructions, or of any certified design or supplier declaration of conformity, provide a reference to where the documents can be found, in a readily accessible format, by electronic means.

ESC

I certify that the installation, or part of the installation, to which this Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's name:	<u>Brent Ruijne</u>	Registration/Practising licence number:	<u>E250044</u>
Certifier's signature:	<u>Brent Ruijne</u>	Certificate Issue Date:	<u>2</u> / <u>7</u> / <u>2025</u>
		Connection Date:	<u>2</u> / <u>7</u> / <u>2025</u>

CUSTOMER COPY - THIS IS AN IMPORTANT DOCUMENT AND SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS

This certificate also confirms that the electrical work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.