TRANSMITTAL TR-ELM-0457

Project: El Mahsama WWTP Expansion (ELM)

Document: ELM-ME-CAL-0012 Rev B Hydraulic Calculation - RAS Pumps

Review Code: 3 - Revise and Resubmit

Purpose of issue: For Approval

Consultant comments

C-01: NPSH available calculation shall consider minimum wet well level 2.35 m.

C-02: Provide pump curve for duty point 410 m3/h at 14.5 m TDH.

Resubmission required within 10 days from the date of this transmittal.