

!

WARNING

ELECTRICAL SHOCK HAZARD

TERMINALS ON BOTH LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION

LABEL LOCATION:
WHERE ALL TERMINALS OF THE DISCONNECTING MEANS MAY BE ENERGIZED IN THE OPEN POSITION, A WARNING SIGN SHALL BE MOUNTED ON OR ADJACENT TO THE DISCONNECTING MEANS.
PER CODE(S): NEC 2020:
NEC 706.15(C)(4) and NEC 690.13(B)

!

WARNING

THIS EQUIPMENT FED BY MULTIPLE SOURCES, TOTAL RATING OF ALL OVERCURRENT DEVICES, EXCLUDING MAIN SUPPLY OVERCURRENT DEVICE, SHALL NOT EXCEED AMPACITY OF BUSBAR.

LABEL LOCATION:
PERMANENT WARNING LABELS SHALL BE APPLIED TO DISTRIBUTION EQUIPMENT, AC DISCONNECT
NEC: 2020
PER CODE: 705.12(B)(3)(3)

PHOTOVOLTAIC

AC DISCONNECT

LABEL LOCATION:
AC DISCONNECT
NEC: 2020
(NEC 690.13(B))


!

WARNING

PHOTOVOLTAIC SYSTEM COMBINER PANEL

DO NOT ADD LOADS

LABEL LOCATION:
UTILITY SERVICE ENTRANCE/METER, INVERTER/DC DISCONNECT IF REQUIRED BY LOCAL AHJ, OR OTHER LOCATIONS AS REQUIRED BY LOCAL AHJ.
PER CODE(S): NEC 2020: ARTICLE 690.56(C)




!

WARNING

PHOTOVOLTAIC POWER SOURCE

LABEL LOCATION :
EXPOSED RACEWAY, CABLE TRAYS, JUNCTION BOX
NEC: 2020, PER CODE: NEC 690.31(D)(2)



!

WARNING

POWER SOURCE OUTPUT CONNECTION. DO NOT RELOCATE THIS OVERCURRENT DEVICE.

LABEL LOCATION:
MAIN SERVICE DISCONNECT
NEC: 2020, 705.12(B)(3)(2)

MAIN PHOTOVOLTAIC SYSTEM DISCONNECT

LABEL LOCATION: MAIN SERVICE DISCONNECT, NEC 2020, 690.13(B)


PV SOLAR BREAKER

DO NOT RELOCATE THIS OVERCURRENT DEVICE

LABEL LOCATION: MAIN SERVICE PANEL, NEC 2020, 690.13(B)

SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN

TURN RAPID SHUTDOWN SWITCH TO THE "OFF" POSITION TO SHUTDOWN PV SYSTEM AND REDUCE SHOCK HAZARD IN THE ARRAY



AT INVERTER [IFC 605.11.3.1(1) & 690.56(C)]
PER CODE: NEC 2020

SOLAR PHOTOVOLTAIC SYSTEMS

(PER CODE: NEC 690)

SOLAR PHOTOVOLTAIC SYSTEMS

(PER CODE: NEC 690)

!

WARNING

DUAL POWER SUPPLY

SOURCES: UTILITY GRID AND PV SOLAR ELECTRIC SYSTEM


LABEL LOCATION:
PRODUCTION / NET METER (BI-DIRECTIONAL)
NEC: 2020
NEC 690.59, 705.12(D)(3)

PHOTOVOLTAIC AC DISCONNECT

MAXIMUM AC OPERATING CURRENT 19.20 AMPS

NOMINAL OPERATING VOLTAGE 240 VOLTS

LABEL LOCATION:
AC DISCONNECT, POINT OF INTERCONNECTION
NEC: 2020
(PER CODE: NEC 690.54)



infinitysolar

INFINITY HOME SOLUTIONS

6405 E MILL PLAIN

VANCOUVER WA 98661

PHONE: 1-800-818-0598

INFINITY SOLAR.COM

REVISIONS		
Description	Date	Rev
Initial Design	6/16/26	00

Signature with Seal

Project Name & Address

KEVIN GONZALEZ RESIDENCE

925 N GRANT ST

LAFAYETTE, OR 97127

PHONE:- N/A

EMAIL:- N/A

Sheet Name

WARNING LABELS

Sheet Size

ANSI B

11" X 17"

Sheet Number

E 1.3