


Smart Conveyor Sorting System / PLC_1 [CPU 1211C AC/DC/Rly] / Program blocks

Main [OB1]

Main Properties							
General							
Name	Main	Number	1	Type	OB	Language	LAD
Numbering	automatic						
Information							
Title	"Main Program Sweep (Cycle)"	Author		Comment		Family	
Version	0.1	User-defined ID					


Main			
Name	Data type	Default value	Comment
▼ Input			
Initial_Call	Bool		Initial call of this OB
Remanence	Bool		=True, if remanent data are available
Temp			
Constant			

Network 1:



Symbol	Address	Type	Comment
"ALARM BUZZER"	%Q0.2	Bool	
"MAIN_HMI"	%M0.0	Bool	
"START"	%I0.2	Bool	
"STOP"	%I0.3	Bool	
"TOTAL PRODUCTS".CV		Int	

Network 2:




Symbol	Address	Type	Comment
"ALARM BUZZER"	%Q0.2	Bool	
"I_E_STOP"	%I0.0	Bool	
"I_OVERLOAD_TRIP"	%I0.1	Bool	

Network 3:




Symbol	Address	Type	Comment
"I_E_STOP"	%I0.0	Bool	
"I_OVERLOAD_TRIP"	%I0.1	Bool	
"READY LAMP"	%Q0.0	Bool	

Network 4:




Symbol	Address	Type	Comment
"CONVEYOR TO PISTON ON".Q		Bool	
"MAIN BELT"	%Q0.3	Bool	
"MAIN_HMI"	%M0.0	Bool	
"PISTON LIMIT"	%I0.7	Bool	
"READY LAMP"	%Q0.0	Bool	
"RUN LAMP"	%Q0.1	Bool	
"SORTING PISTON"	%Q0.4	Bool	
"Tag_3"	%M1.0	Bool	

Network 5:




Symbol	Address	Type	Comment
"PRODUCT SENS"	%I0.4	Bool	
"Tag_1"	%M20.0	Bool	
"TOTAL PRODUCTS".CV		Int	

Network 6:




Symbol	Address	Type	Comment
"SORTING PISTON"	%Q0.4	Bool	
"Tag_3"	%M1.0	Bool	

Network 7:




Symbol	Address	Type	Comment
"METAL SENS"	%I0.5	Bool	
"Tag_3"	%M1.0	Bool	

Network 8:



Symbol	Address	Type	Comment
"PISTON LIMIT"	%I0.7	Bool	
"Tag_3"	%M1.0	Bool	
"Tag_5"	%M20.3	Bool	

Network 9:



Symbol	Address	Type	Comment
"PISTON LIMIT"	%I0.7	Bool	
"Tag_4"	%M20.2	Bool	
"TOTAL PRODUCTS".CV		Int	