

Buildings

Search Folders

Cabinets

Download required

Not assigned to a room

Buildings

Main Building

Ground floor

Classroom 1

1.1.1 KNX Push Button Dynamic Lab...

Cabinet

1.1.0 Coupler REG-K

1.1.2 Switch actuator REG-K/4x230...

1.1.3 SpaceLogic KNX Universal Di...

1.1.4 SpaceLogic KNX Switch/Blin...

Trades

Channels 1

Group Objects 7

Parameters

Search

Number ^	Name	Object Function	Linked with	Group Addresses
31	Master Output 1+2	Movement in manua...	shutter move	0/2/0
32	Master Output 1+2	Stop in manual mode	shutter stop	0/2/1
33	Master Output 1+2	Height position in m...		
43	Master Output 1+2	Scene	scene1	0/0/1, 0/0/2
46	Master Output 1+2	Feedback for height		
51	Master Output 1+2	Feedback for moving		
52	Master Output 1+2	Feedback for last dir...	shutter feedback	0/2/2

Group Address...

Search

Search Folders

Addresses marked...

Addresses not assi...

Group Addresses

0 Ground floor

0/0 scenes

0/0/1 scene1

0/0/2 scene2

0/1 Switching

0/1/0 Switch on/off

0/1/1 Switch feedba...

0/2 Shutter

0/2/0 shutter move

0/2/1 shutter stop

0/2/2 shutter feedb...

0/3 Dimming

0/3/0 dim on/off

0/3/1 dim relative v...

0/3/2 dim feedback

Bus Interfaces 0

Associations 4

Object ^

43: Master Output 1+2 - Scene

82: Master Output 2 - Scene

103: Function 6 scene2 - Scene o...

105: Scene object - Scenes of all...