



Prologue


These fire protection regulations contain rules for fire prevention.
The following regulations serve to prevent fire protection in the
the obligation to observe and comply with other occupational safety

The fire protection regulations consist of 3 parts:

Part A (notice) is aimed at all people who are (even temporarily)

Part B (for people without special fire protection tasks) is aimed at
contents of Part B of the fire protection regulations are the operating
instructions on the correct behavior in the event of danger. Part B is
documented.

Part C (for people with special fire protection tasks) is aimed at
addition to their general duties.



*Various events such as fires, leakage of hazardous substances, and
affected persons must then be evacuated immediately and safely.*

The scope and time interval of the evacuation drill were determined
signal to employees must be determined through periodic testing

signal to employees must be determined through periodic testing

An evacuation drill is an exercise in which participants learn how to
fire or other hazard that requires them to leave the building. The exercise
usually involves performing evacuation procedures and training in

Conducting evacuation drills is important to ensure that everyone in
the building or areas have been inspected, the exercise leader declared
recorded. The employees are to be informed promptly about the fire



Inhalt

| | |
|---------------------------------|---------|
| PROLOGUE | _____ |
| 1) ALLGEMEIN | _____ |
| 2) ABLAUF | _____ 4 |
| 3) RÄUMUNGSABLAUF UND / -ZEITEN | _____ |
| 4) ERGEBNISSE UND BEWERTUNG | _____ |



1) General

| | |
|------------------------------|-----------------------------------------|
| Date: | 2023-09-14 |
| Start of the exercise | 10:08 Uhr |
| Assumed situation | Ausländerseines Dr BAG |
| Location | Am Cargolift 24 54863 Füssen |
| Employees | |
| Evacuation helper | Ausgebildet (2023 |
| Fire alarm system | Ja |
| Evacuation drill | Unangekündigt |
| Exercise smoke | Nein |
| Exercise Observer | 3 Herr Gagliardi, Ro |
| Competences | Herr Belz, Rolf - S Herr Goldschmidt |
| fffff | fffff |

2) Procedure

| | |
|----------------------------------------------|-------------------------------------------------------------|
| Employees in building | Nein |
| Fire department | Ja |
| Police | Nein |
| Meeting of the operational task force | In accordance with the evac received from the evacuation |



3) Evacuation procedure and / times

Evacuation time

| | |
|----------------------------------------------|------------|
| Start der Räumung | 10:08 Uhr |
| Entdeckung / Detektion | 10:08 Uhr |
| Schadensereignis | |
| Erste Alarmmeldung Brandschutz Helfer | 10:09 Uhr |
| Eintreffen am Sammelplatz bis | 10:12 Uhr |
| Räumungsende | 10:15 Uhr |
| Weg zum Sammelplatz | 2 Minuten |
| Gesamtzeitbedarf | 7 Minuten* |

*The building was 4 min completely cleared after the alarm.



4) Ergebnisse und Bewertung

Info: After the exercise, a debriefing was held with all persons involved.

Summary of deficiencies:

1. Lautstärke Alarmierungssignal

2. Sammelplatz nicht auf der anderen Stra enseite

Description:

Zu 1: Lautst rke Alarmierungssignal

Die Lautst rken gesamten Lager- / und Produktionsbereichs

Empfehlung:

Der Schalldruckpegel der Alarmgeber muss mindestens 65 dB

Weiter muss das Signal der Alarmierungseinrichtung sich von
10 dB(A)  bersteigen, jedoch nach DIN 7731 nicht  ber 118 dB(A)

Die Lautst rke des Alarmierungssignals ist durch die Fachfirma
DIN VDE 0833, anzupassen

Regarding 2: Assembly point not on the other side of the street

Most of the employees crossed Pfaffenstrasse and gathered on

Recommendation:

Crossing the street during an evacuation poses an unnecessary
management and employees is not possible. The official assembly

road must be kept clear as a movement area for the fire department.

This point must be included in the annual safety briefing.