

METHOD STATEMENT / RISK ASSESSMENT DETAILS

Name of company:	CA Drillers Ltd	Account:	Waitrose
Site	Newport - 81978	Submitted by:	
Title:	Core Holes / Diamond Drilling		
Date submitted to Uplands for review:	July 2026		

UPLANDS REVIEW

Uplands Review Details			
Name:	M. Singlehurst	Position:	Project Manager
Signed:		Date:	11.08.2026
A	No Comments, Satisfactory		✓
B	Minor Comments. Satisfactory Subject to Incorporation of Comments Below		
C	Unsatisfactory, please revise and Re submit to include comments below:		
Date sent for amendments to be added:		Date received back with amendment added:	
General Comments:			

All Hazards identified MUST have the appropriate CONTROLS MEASURES identified and explained in the RAMs.

Demolition	Yes ☐ No ☒	Licensed Asbestos Removal	Yes ☐ No ☒
Hot Works	Yes ☐ No ☒	Non-Licensed Asbestos Removal	Yes ☐ No ☒
Steel Erection	Yes ☐ No ☒	Dust	Yes ☒ No ☐
Work At Height	Yes ☒ No ☐	Noise	Yes ☒ No ☐
Roof Work / Work Near Fragile Materials	Yes ☐ No ☒	Vibration	Yes ☒ No ☐
Temporary Works including Scaffolding	Yes ☐ No ☒	Manual Handling	Yes ☒ No ☐
Breaking Ground / Digging	Yes ☐ No ☒	Epoxy Resins	Yes ☐ No ☒
Working in Excavations	Yes ☐ No ☒	Methyl methacrylate (MMA)	Yes ☐ No ☒
Confined Space Work	Yes ☒ No ☐	UV (Solar) Radiation	Yes ☐ No ☐
Lifting Operations	Yes ☐ No ☒	Leptospirosis	Yes ☐ No ☒
Overhead Services	Yes ☐ No ☒	Psittacosis	Yes ☐ No ☒
Electrical Work	Yes ☒ No ☐	Needle Stick Injury	Yes ☐ No ☒
Use of Plant and Equipment	Yes ☒ No ☐	Hazardous Substances	Yes ☒ No ☐
PAT Testing	Yes ☐ No ☒	Falls of materials	Yes ☒ No ☐
Restricted Access and Egress	Yes ☒ No ☐	Working on / adjacent to water	Yes ☐ No ☒
Vehicle / Plant Movements	Yes ☒ No ☐	Adverse weather	Yes ☒ No ☐
Segregation	Yes ☒ No ☐		
Fire / Explosion	Yes ☒ No ☐	Other Hazards: Please Specify:	
Sharp Objects	Yes ☒ No ☐	COVID-19	Yes ☒ No ☐
Poor Ground Conditions	Yes ☒ No ☐		
Non English Speaking Operatives	Yes ☐ No ☒		
Flying Particles	Yes ☒ No ☐		

Pressure Systems	Yes ☐	No ☒	
QUESTION	YES	NO	COMMENTS
1. Are appropriate controls contained in the RAMs to mitigate the risks arising from the hazards identified overleaf?	☒	☐	Controls included for drilling, WAH/MEWP, services, dust, noise, vibration, manual handling, access, segregation, emergencies and PPE.
2. Do they cover all the likely significant hazards that will be encountered in the work?	☒	☐	Significant hazards covered. COSHH mentions confined space - confirm if applicable.
2. Are Uplands Permits to Work required? If so state which ones in the comments section.	☒	☐	WAH / MEWP permit required by Uplands. Permit also required for live services/isolation if applicable.
3. Is the area of work and scope of works clearly defined?	☒	☐	Area and scope defined: Waitrose Newport rear service yard, high-level core drilling through external brick/internal block wall.
4. Are supervisory and communications arrangements clearly defined? State the name of the Contractors Supervisor in the comments section.	☒	☐	Works Supervisor: Matty Singlehurst, Uplands Site Manager. CAD operatives TBC.
5. Has the responsibility for monitoring the operations, to which the method statement relates, been clearly defined?	☒	☐	Monitoring covered by supervision, stop-work/reassessment process and site manager notification.
6. Does the document identify the training requirements for personnel engaged on the work?	☒	☐	Training listed: NVQ diamond drilling/sawing, CSCS, SSSTS/SMSTS, IPAF, manual handling, abrasive wheels, asbestos awareness, face-fit and HAVS.
7. HAS EITHER OF THE FOLLOWING BEEN CARRIED OUT IN RELATION TO NON ENGLISH SPEAKING OPERATIVES: A. A Bi-lingual Supervisor has translated the RAMs to the Non English speaking Operatives in the presence of an Uplands Manager B. RAMs have been provided in the Non English speaking operative's native language.	☐	☐	N/A - no non-English speaking operatives identified.
8. Has the impact of the work on other contractors, visitors, and public areas been assessed? & if so have controls been proposed to protect them?	☒	☐	Others/public assessed. Barriers, signage, exclusion zones, pedestrian segregation and traffic controls included.
9. Are arrangements for emergencies adequately addressed?	☒	☐	Emergency procedures, first aid, nearest A&E, out-of-hours communication and COSHH emergency response included.
10. Has the appropriate personal protective equipment been identified?	☒	☐	PPE identified: head, eye, ear, gloves, safety footwear, hi-vis and FFP3 RPE.
11. Are environmental aspects such as waste disposal, contaminated spoil, water pollution etc., adequately addressed?	☒	☐	Waste, slurry/water control, dust suppression, spillages, COSHH disposal and correct waste streams addressed.
12. Is there anything else that the RAMs needs to address?	☐	☒	No further comments.

Note: By accepting this method statement Uplands do not assume responsibility for any errors or omissions by the author. The contractor is not relieved of statutory obligation to provide, monitor and revise their safe system of work during progress with the activity. All revisions to the document or the system of work must be agreed with Uplands prior to execution of the work.