

Document Reference: UHSF20.1	RAMS REVIEW FORM	 CONSTRUCTING CHANGE
--	-------------------------	---

METHOD STATEMENT / RISK ASSESSMENT DETAILS

Name of company:	Rapid Chiller Hire	Account:	Waitrose
Site	Newport - 81978	Submitted by:	
Title:	Temporary boiler hire installation		
Date submitted to Uplands for review:	August 2026		

UPLANDS REVIEW

Uplands Review Details			
Name:	M. Singlehurst	Position:	Project Manager
Signed:		Date:	27.08.2026
A	No Comments, Satisfactory		
B	Minor Comments. Satisfactory Subject to Incorporation of Comments Below		
C	Unsatisfactory, please revise and Re submit to include comments below:		✓
Date sent for amendments to be added:		Date received back with amendment added:	
General Comments:	Not acceptable as a complete RAMS pack. It gives useful controls, but lacks site address, named responsible persons, issue/revision control, detailed task risk assessments, permit requirements, welfare/first aid detail, training records and site-specific emergency arrangements.		

All Hazards identified MUST have the appropriate CONTROLS MEASURES identified and explained in the RAMs.

Demolition	Yes ☐ No ☒	Licensed Asbestos Removal	Yes ☐ No ☒
Hot Works	Yes ☐ No ☒	Non-Licensed Asbestos Removal	Yes ☐ No ☒
Steel Erection	Yes ☐ No ☒	Dust	Yes ☐ No ☒
Work At Height	Yes ☐ No ☒	Noise	Yes ☐ No ☒
Roof Work / Work Near Fragile Materials	Yes ☐ No ☒	Vibration	Yes ☐ No ☒
Temporary Works including Scaffolding	Yes ☐ No ☒	Manual Handling	Yes ☐ No ☒
Breaking Ground / Digging	Yes ☐ No ☒	Epoxy Resins	Yes ☐ No ☒
Working in Excavations	Yes ☐ No ☒	Methyl methacrylate (MMA)	Yes ☐ No ☒
Confined Space Work	Yes ☐ No ☒	UV (Solar) Radiation	Yes ☐ No ☒
Lifting Operations	Yes ☒ No ☐	Leptospirosis	Yes ☐ No ☒
Overhead Services	Yes ☐ No ☒	Psittacosis	Yes ☐ No ☒
Electrical Work	Yes ☒ No ☐	Needle Stick Injury	Yes ☐ No ☒
Use of Plant and Equipment	Yes ☒ No ☐	Hazardous Substances	Yes ☒ No ☐
PAT Testing	Yes ☐ No ☒	Falls of materials	Yes ☒ No ☐
Restricted Access and Egress	Yes ☒ No ☐	Working on / adjacent to water	Yes ☐ No ☒
Vehicle / Plant Movements	Yes ☒ No ☐	Adverse weather	Yes ☐ No ☒
Segregation	Yes ☒ No ☐	Other Hazards: Please Specify:	
Fire / Explosion	Yes ☒ No ☐	COVID-19	Yes ☐ No ☒
Sharp Objects	Yes ☐ No ☒		
Poor Ground Conditions	Yes ☒ No ☐		
Non English Speaking Operatives	Yes ☐ No ☒		
Flying Particles	Yes ☐ No ☒		

Document Reference: UHSF20.1	Title: RAMS REVIEW FORM	 CONSTRUCTING CHANGE
--	-----------------------------------	---

Pressure Systems	Yes ☒	No ☐	
QUESTION	YES	NO	COMMENTS
1. Are appropriate controls contained in the RAMs to mitigate the risks arising from the hazards identified overleaf?	☐	☒	Controls are listed for lifting, transport, gas, electrical hook-up, fuel, flues, commissioning and emergency response, but they are too high-level for a complete RAMS.
2. Do they cover all the likely significant hazards that will be encountered in the work?	☐	☒	Major hazards are identified, but there is no full site-specific risk assessment for WAH, public interface, welfare, first aid, COSHH/SDS, noise, manual handling or weather impacts.
2. Are Uplands Permits to Work required? If so state which ones in the comments section.	☒	☐	Permits likely required for lifting/HIAB, gas connection/isolation, electrical isolation/energisation, pressure testing/commissioning, hot water/steam operation and fuel storage if applicable.
3. Is the area of work and scope of works clearly defined?	☐	☒	Scope is temporary boiler hire, but site address, exact location/pad, work dates and installation constraints are missing.
4. Are supervisory and communications arrangements clearly defined? State the name of the Contractors Supervisor in the comments section.	☐	☒	Roles are generic. Named Rapid supervisor, appointed lifting/traffic person, Gas Safe/OFTEC engineer and site contacts must be stated.
5. Has the responsibility for monitoring the operations, to which the method statement relates, been clearly defined?	☐	☒	Daily checks/logbook are referenced, but responsibility for monitoring during installation, commissioning and operation is not clearly assigned to named persons.
6. Does the document identify the training requirements for personnel engaged on the work?	☐	☒	Gas Safe/OFTEC standards are referenced, but training/competency evidence for lifting, gas, electrical and commissioning personnel is not provided.
7. HAS EITHER OF THE FOLLOWING BEEN CARRIED OUT IN RELATION TO NON ENGLISH SPEAKING OPERATIVES: A. A Bi-lingual Supervisor has translated the RAMs to the Non English speaking Operatives in the presence of an Uplands Manager B. RAMs have been provided in the Non English speaking operative's native language.	☐	☒	No non-English speaking operatives are identified and no translation arrangements are stated.
8. Has the impact of the work on other contractors, visitors, and public areas been assessed? & if so have controls been proposed to protect them?	☒	☐	Exclusion zones, traffic restrictions, barriers and locked plant access are included.
9. Are arrangements for emergencies adequately addressed?	☐	☒	Emergency response workflow is included, but site-specific first aid, assembly point, emergency contacts and gas/fuel escalation details are incomplete.
10. Has the appropriate personal protective equipment been identified?	☒	☐	Hard hats, hi-vis and mandatory PPE signage are referenced, but task-specific PPE should be expanded.
11. Are environmental aspects such as waste disposal, contaminated spoil, water pollution etc., adequately addressed?	☐	☒	Fuel bunding/spill kits and flue emissions are mentioned, but wider environmental, water pollution and waste controls are incomplete.
12. Is there anything else that the RAMs needs to address?	☒	☐	Revise/resubmit as a complete site-specific RAMS pack with named personnel, permits, detailed risk assessments, emergency plan, training evidence and environmental controls.

Note: By accepting this method statement Uplands do not assume responsibility for any errors or omissions by the author. The contractor is not relieved of statutory obligation to provide, monitor and revise their safe system of work during progress with the activity. All revisions to the document or the system of work must be agreed with Uplands prior to execution of the work.