

METHOD STATEMENT – FLOORING INSTALLATION

Description of Activity	Flooring Installation	Revision no:	01
Project name	Waitrose Newport	Project ref	Flooring
Prepared for		Package ref	5281
Site address	Audley Road	Start date	02/09/26
	Newport	Finish date	23/09/26
	TF10 7DS	Prepared by	Luke Witham
		Review date	20/08/26

Personnel involved	Name	Contact Number	Role/Trade
Works Supervisor			

Key plant & tools required	
Key materials required	
Other essential equipment	(ie: access platforms/winches/ladders/etc:)
Specific identified residual hazards: (or refer to the task specific risk assessments)	Please refer to material data sheet
Specific Staff Training Requirements	(ie: Confined Spaces/Adhesives/wheels/Working at Height/Plant Operations etc)

METHOD STATEMENT – FLOORING INSTALLATION

Method of Working	Manual Handling Method Statement
	MS All operatives involved in the manual lifting of materials and plant will be conversant with the Amphill Flooring Plans of Action with regards to lifting, in order to prevent any pain and injury.
	The operative is to examine the object and make sure: • The weight is stable and won't shift. • There are no sharp edges or points sticking out. • There is the correct number of people, based on the size, shape and weight of the load. • You can clearly see over it. • The operative is to ensure that: • The easiest route is chosen, not necessarily the shortest. • That they have a clear path – moving any objects that could be a trip hazard or bumping obstacle. • Identify places to stop and rest. • Ensure a designated clear unloading zone is achieved.
	Manual Handling Methods All operatives to adopt the following safe lifting position: 1. Assume the safe lifting position – squat by bending at the hips and knees. Your ears, shoulders and hips form nearly a straight line. Keep your feet shoulder-width apart and your feet turned out. 2. Maintain your back's natural curves – do not bend your back 3. Let your legs do the lifting.
	When physically lifting, operatives must: 1. Stand close to the object and keep a wide stance. 2. Tighten stomach muscles 3. Assume the above safe lifting position 4. Pull the load close to the body. 5. Let the legs not the back power the lift.
	Whilst carrying DO NOT TWIST, move your feet to turn.
	When unloading, operatives must adopt the following procedures pending on size and weight of loads: 1. Face the spot you have chosen and lower the load slowly by using your legs, not your back. 2. Bend knees. 3. Keep fingers away from bottom of load.
	With oversized or Heavy Loads the following procedure is to be adopted 1. Work as a team – use a two-person lift. 2. Designate one person to direct the lift. 3. Lift at the same time.

METHOD STATEMENT – FLOORING INSTALLATION

	4.	Keep the load level when carrying		
	5.	Move smoothly together and unload at the same time.		
	With bags & Sacks:			
	1.	Assume the safe lifting position.		
	2.	Grasp load at opposite top and bottom corners		
	3.	Power your body up with your legs and use your arms to raise the load to rest on your hip.		
	4.	Fully stand and move the load to rest on your shoulder.		
	With Carts and Hand-trucks (for awkward sized and heavy loads)			
1.	Select the right equipment. Do not use “skates” to move rolls of carpet as this encourages bad grip & posture.			
2.	Place heavy objects on the bottom, with load over the axles. Stack lighter objects on top, but don't block your view.			
3.	Secure bulky, loose or delicate objects.			
4.	Push the load forward with legs and upper body.			
5.	Maintain a firm grip with buttocks out, back in its natural curves and knees bent.			
6.	Hand position should be between upper thigh and chest position when pushing.			
7.	Avoid pulling the load.			
UNLOADING FROM DELIVERY VEHICLES				
1.	Materials will be delivered on a rigid vehicle, with tail lift facility whenever possible.			
Personnel involved: Sign to confirm this document has been understood and will be adhered to.	Name	Sign	Date	

METHOD STATEMENT – FLOORING INSTALLATION

Method of Working	Latex Smoothing Compound Application - Method Statement	
	MS	
	1.	Materials will be delivered directly to site and following off loading the quantity and condition of bags will be checked and any discrepancy recorded and the appropriate action taken.
	2.	The materials will be distributed by mechanical and/or human resources.
	3.	Prior to installation, the appropriate dampness and climatic tests will be conducted to ensure conditions in working areas are in accordance with the respective manufacturer recommendations and the relevant British Standard (BS 8203 requires the relative humidity of the subfloor not to exceed 75% RH) with the general work area temperature being no less than 12 degrees centigrade.
	4.	In all areas prepared to receive smoothing compound, all operatives will be conversant with relevant information and personal protection to enable the use of any material safely and without risk to health.
	The material will be installed using the following method:	
	1.	The subfloor will be vacuumed thoroughly to ensure it is clean and free of any barrier materials such as dust, oil, grease etc. and primed according to the manufacturers recommendations.
	2.	Latex powder and latex liquid will be blended in the appropriate quantities (as recommended by the manufacturer) until a smooth lump free mortar is achieved.
	3.	Starting from a corner of the specified area the mortar will be poured into position and spread with a trowel/rake/spikey roller to the required thickness with a smooth finish.
	If any trowel marks remain, the surface will either be;	
		Smoothed once again with a wet trowel when the latex has stiffened but not fully hardened. Or Using an STR sanding machine/carborundum block to sand down, once the surface has hardened.
	1.	Working to a grid of bays this procedure will be repeated, until the whole area has been covered.
	2.	On completion, the floor should be protected from foot traffic until the compound has hardened and dried.

METHOD STATEMENT – FLOORING INSTALLATION

	3.	All waste and debris will be removed on a daily basis to ensure all working areas are clean and free from hazards.						
Temporary Supports and Props Needed to Facilitate the works	(If none, state none). None							
Methods of Access & Egress to the work area	(ie: Ladders/MEWPS/Scaffolds/Trestles/Step ladders etc). Forklift provided by the main contractor							
Fall protection measures (Where work at height cannot be eliminated:- consider both personnel & materials)	(ie: Guard rails/Toe boards/Brick Guards/Safety Harnesses/Exclusion Zones etc). None required.							
Hazardous Substances	(ie: Lubricants/Solvents/Flammable Material/Refrigerants/Welding Gasses etc.).							
Attach COSHH assessments and MSDS	GHS06 Acute Toxic 	GHS07 Harmful / Irritant / sensitiser 	GHS05 Corrosive 	GHS09 Hazardous to the aquatic environment 	GHS03 Oxidising 	GHS02 Flammable 	GHS01 Explosive 	
	Very Toxic	Harmful / Irritant	Corrosive	Dangerous for the Environment	Oxidising	Highly Flammable	Explosive	Other
SWL's: (Site Working Load)	Detail any limits on the loadings applicable to temporary plant/equipment or fixed elements Not applicable							
Required Personnel Protective Equipment:								
Other :	Safety Gloves	Hard Hats	Safety Boots	Hearing Protection	Respiratory Protection	Eye Protection	Other	Other
Hi Visibility Vest	✓	✓	✓	✗	✓	✓		
EN471	EN374-9	EN397	EN345	EN352:3	EN143	EN166		
	EN388			Helmet	EN149	EN172		
Respirator while mixing				Mounted	(FFP3)			
Emergency Procedures	The works undertaken do not have inherent risk that would require emergency procedures. Operatives will follow the emergency procedures identified at the site induction with regard to on site evacuation.							
	Name of On-site First Aider				Main Contractors Site First Aider			

METHOD STATEMENT – FLOORING INSTALLATION

	First Aid Box Location	As indicated at site induction
	Location of nearest Hospital	As indicated at site induction
Other information & Comments:	CSCS cards must be shown at the induction. Prior to commencement of the installation works, the working areas will be safe zoned adopting the appropriate methodology to prevent or minimise through traffic or other trades operatives.	
	All generated waste to be placed into segregated bins provided the principle contractor ie: wood, plastic, textile and dust.	
Environmental Control		

DECLARATION OF WORKING METHODS

All Subcontract works will be executed to the Clients satisfaction and in compliance with the requirements of the contract specification. Methods employed will be in accordance with Amphill Flooring Health & Safety Programme, good practice and with those recommended by the manufacturer.

QUALITY CONTROL

All site operations will be carried out in accordance with procedures detailed within the relevant sections of the Company Quality Manual, a copy of which is available. Our Contracts Manager will have full responsibility for implementation of all systems in this respect.

All work will be undertaken by qualified competent persons with experience of the type of work described above, and in all cases in full accordance with safety procedures specified in the company's Health & Safety Policy. Where working environments or activities are deemed unsafe, subcontractors can refuse to undertake the works and raise the issues with Management without fear of recrimination.

Personnel involved:	Name	Sign	Date
Sign to confirm this document has been understood and will be adhered to.			

METHOD STATEMENT – FLOORING INSTALLATION

Method of Working	Edge Trim Installation Method Statement	
	MS	
	1.	Upon delivery to site, the quantity, type and condition of the materials will be checked and any discrepancy recorded and the appropriate action taken.
	2.	The materials will be distributed to the working areas by mechanical and/or human resources.
	3.	The working area will be inspected and checked for surface suitability and dimensional consistency. Any defects found will be reported to the relevant authority, such that the defects can be rectified before installation commences
	4.	Each trim will be accurately measured and cut to fit accordingly using a hacksaw.
	5.	The trim will be offered up to its position and fixed according to the manufacturers instructions.
	6.	The areas concerned should be isolated and free from traffic to allow the adhesive to cure, ideally for a period of 12 hours.

METHOD STATEMENT – FLOORING INSTALLATION

Temporary Supports and Props Needed to Facilitate the works	(If none, state none). None						
Methods of Access & Egress to the work area	(ie: Ladders/MEWPS/Scaffolds/Trestles/Step ladders etc). Forklift provided by the main contractor						
Fall protection measures (Where work at height cannot be eliminated:- consider both personnel & materials)	(ie: Guard rails/Toe boards/Brick Guards/Safety Harnesses/Exclusion Zones etc). None required.						
Hazardous Substances	(ie: Lubricants/Solvents/Flammable Material/Refrigerants/Welding Gasses etc.).						
Attach COSHH assessments and MSDS	GHS06 Acute Toxic 	GHS07 Harmful / Irritant / sensitiser 	GHS05 Corrosive 	GHS09 Hazardous to the aquatic environment 	GHS03 Oxidising 	GHS02 Flammable 	GHS01 Explosive 
	Very Toxic	Harmful / Irritant	Corrosive	Dangerous for the Environment	Oxidising	Highly Flammable	Explosive
	x	x	x	x	x	x	x
SWL's: (Site Working Load)	Detail any limits on the loadings applicable to temporary plant/equipment or fixed elements Not applicable						
Required Personnel Protective Equipment:							
Other :	Safety Gloves	Hard Hats	Safety Boots	Hearing Protection	Respiratory Protection	Eye Protection	Other
Hi Visibility Vest	✓	✓	✓	x	x	✓	
EN471	EN374-9	EN397	EN345	EN352:3	EN143	EN166	
	EN388			Helmet	EN149	EN172	
Knee Pads				Mounted	(FFP3)		
Emergency Procedures	The works undertaken do not have inherent risk that would require emergency procedures. Operatives will follow the emergency procedures identified at the site induction with regard to on site evacuation.						
	Name of On-site First Aider				Main Contractors Site First Aider		
	First Aid Box Location				As indicated at site induction		
	Location of nearest Hospital				As indicated at site induction		

METHOD STATEMENT – FLOORING INSTALLATION

Description of Activity	Edging Trim Installation	Revision no:	01
Other information & Comments:	CSCS cards must be shown at the induction. Prior to commencement of the installation works, the working areas will be safe zoned adopting the appropriate methodology to prevent or minimise through traffic or other trades operatives.		
Environmental Control	All generated waste to be placed into segregated bins provided the principle contractor ie: wood, plastic, textile and dust.		
<u>DECLARATION OF WORKING METHODS</u> All Subcontract works will be executed to the Clients satisfaction and in compliance with the requirements of the contract specification. Methods employed will be in accordance with Amphill Flooring Health & Safety Programme, good practice and with those recommended by the manufacturer.			
<u>QUALITY CONTROL</u> All site operations will be carried out in accordance with procedures detailed within the relevant sections of the Company Quality Manual, a copy of which is available. Our Contracts Manager will have full responsibility for implementation of all systems in this respect. All work will be undertaken by qualified competent persons with experience of the type of work described above, and in all cases in full accordance with safety procedures specified in the company's Health & Safety Policy. Where working environments or activities are deemed unsafe, subcontractors can refuse to undertake the works and raise the issues with Management without fear of recrimination.			
Personnel involved:	Name	Sign	Date
Sign to confirm this document has been understood and will be adhered to.			

METHOD STATEMENT – FLOORING INSTALLATION

Method of Working	Vinyl Sheet Installation Method Statement
	1. Vinyl sheet will be delivered directly to site, generally in full rolls comprising approximately 40m² of product per roll. The quantity and condition of each roll will be checked and any discrepancy recorded and the appropriate action taken. The materials will be distributed to the working areas by mechanical and/or human resources.
	ON SCREED
	a. Prior to installation, the appropriate subfloor dampness and climatic tests will be conducted to ensure conditions in each working area are in accordance with the respective manufacturers recommendations and the relevant British Standard (BS 8203 requires the Relative Humidity of the subfloor not to exceed 75% RH).
	b. The subfloor will be vacuumed clean of any loose debris and/or other contaminants and checked for suitability to receive sheet vinyl.
	c. A full inspection of the subfloor will be undertaken to identify areas where making good is required. Once approved by the PM, sub-floor preparation will be undertaken by the installation of plywood and/or a self-levelling smoothing underlayment, dependent upon the construction of the subfloor and the extent of the preparation required.
	ON RAISED ACCESS FLOOR
	a. On raised access floors, any uneven access panels and panels showing movement will be identified and the necessary remedial action taken. Any damage evident upon inspection of working areas prior to installation will be reported accordingly.
	2. At least twenty-four hours before laying, the materials will be transported to working areas and allowed to acclimatise to the atmospheric conditions that will prevail during and after installation. The general room temperature throughout this period must be a minimum of 18 degrees centigrade and Air Relative Humidity must not exceed 65% RH.
	3. The rolls of vinyl will be unwrapped, rolled out and checked for quality and left flat for 12 hours to fully acclimatise. The sheet will then be cut to the required lengths and neatly scribed to perimeter profiles. It will then be folded back and an approved adhesive applied to the prepared subfloor with a serrated trowel.
	4. The sheet will then be laid on to adhesive and all air that may be trapped underneath, expelled by rolling the material with a 150 lb roller in both directions. The butt joints between each sheet will then be cut and surplus material removed.
	5. Joints will then be routered and welded with matching weld rod. No welding will take place until at least 12 hours after the material has been laid.
	6. Upon completion, newly installed areas will be inspected to ensure materials have been fitted correctly and in accordance with the relevant specification, finishes schedule and/or drawing. Any discrepancies may be rectified prior to hand over to the Client.
	7. Where protection of floor coverings is required, this will be installed to suit the type of material used

METHOD STATEMENT – FLOORING INSTALLATION

	8.	All waste/rubbish generated during installation will be removed daily to bins provided on each floor.						
Temporary Supports and Props Needed to Facilitate the works	(If none, state none). None							
Methods of Access & Egress to the work area	(i.e.: Ladders/MEWPS/Scaffolds/Trestles/Step ladders etc). Forklift provided by the main contractor							
Fall protection measures (Where work at height cannot be eliminated:- consider both personnel & materials)	(i.e.: Guard rails/Toe boards/Brick Guards/Safety Harnesses/Exclusion Zones etc). None required.							
Hazardous Substances	(i.e.: Lubricants/Solvents/Flammable Material/Refrigerants/Welding Gasses etc.).							
Attach COSHH assessments and MSDS	GHS06 Acute Toxic 	GHS07 Harmful / Irritant / Skin sensitiser 	GHS05 Corrosive 	GHS09 Hazardous to the aquatic environment 	GHS03 Oxidising 	GHS02 Flammable 	GHS01 Explosive 	
	Very Toxic	Harmful / Irritant	Corrosive	Dangerous for the Environment	Oxidising	Highly Flammable	Explosive	Other
SWL's: (Site Working Load)	Detail any limits on the loadings applicable to temporary plant/equipment or fixed elements Not applicable							
Required Personnel Protective Equipment:								
Other :	Safety Gloves	Hard Hats	Safety Boots	Hearing Protection	Respiratory Protection	Eye Protection	Other	Other
Hi Visibility Vest	✓	✓	✓	✗	✗	✓		
EN471	EN374-9	EN397	EN345	EN352:3	EN143	EN166		
	EN388			Helmet	EN149	EN172		
Knee Pads				Mounted	(FFP3)			
Emergency Procedures	The works undertaken do not have inherent risk that would require emergency procedures. Operatives will follow the emergency procedures identified at the site induction with regard to on site evacuation.							

METHOD STATEMENT – FLOORING INSTALLATION

Description of Activity	Vinyl Tile Installation		Revision no:	01
	Name of On-site First Aider		Main Contractors Site First Aider	
	First Aid Box Location		As indicated at site induction	
	Location of nearest Hospital		As indicated at site induction	
Other information & Comments:	CSCS cards must be shown at the induction. Prior to commencement of the installation works, the working areas will be safe zoned adopting the appropriate methodology to prevent or minimise through traffic or other trades operatives.			
Environmental Control	All generated waste to be placed into segregated bins provided the principle contractor i.e.: wood, plastic, textile and dust.			

DECLARATION OF WORKING METHODS

All Subcontract works will be executed to the Clients satisfaction and in compliance with the requirements of the contract specification. Methods employed will be in accordance with Amphill Flooring Health & Safety Programme, good practice and with those recommended by the manufacturer.

QUALITY CONTROL

All site operations will be carried out in accordance with procedures detailed within the relevant sections of the Company Quality Manual, a copy of which is available. Our Contracts Manager will have full responsibility for implementation of all systems in this respect.

All work will be undertaken by qualified competent persons with experience of the type of work described above, and in all cases in full accordance with safety procedures specified in the company's Health & Safety Policy. Where working environments or activities are deemed unsafe, subcontractors can refuse to undertake the works and raise the issues with Management without fear of recrimination.

Personnel involved:	Name	Sign	Date
Sign to confirm this document has been understood and will be adhered to.			

METHOD STATEMENT – FLOORING INSTALLATION

Method of Working	Vinyl Tile Installation Method Statement
	1. Materials will be delivered direct to site and following off-loading will be stored with tiles being stacked to a height not exceeding 5 boxes. The quantity, condition and colour batch will be checked against the delivery note and any discrepancy recorded. Delivery quantities will be phased according to the working areas currently in progress and the programmed sequence of site operations.
	2. All materials will be distributed by mechanical and/or human resources as required and previously agreed
	3. Material quantities will be checked daily.
	4. Prior to installation, the appropriate subfloor dampness and climatic tests will be conducted to ensure conditions in each working area are in accordance with the respective manufacturer recommendations and the relevant British Standard (BS 8203 requires the Relative Humidity of the subfloor not to exceed 75% RH).
	5. The subfloor will be vacuumed clean of any loose debris and/or other contaminants and checked for suitability to receive the specified floor covering. A full inspection of the subfloor will be undertaken to identify areas where making good is required. Once approved by the relevant authority, making good will be undertaken by the installation of plywood and/or a self-levelling smoothing underlayment, dependent upon the construction of the subfloor and the extent of the making good involved. Any damage to interior finishes evident upon inspection of working areas prior to installation will be reported accordingly.
	6. At least twenty-four hours before laying, the materials will be transported to working areas and allowed to acclimatise to the atmospheric conditions that will prevail during and after installation. The general room temperature throughout this period must be a minimum of 18 degrees centigrade.
	7. Accurate measurements will be taken to determine the correct starting point or datum, ordinarily the centre line of the working area, after identifying the longest external wall as a bench mark and setting out from this to obtain equal perimeter cuts to all walls. However, all walls must be checked for squareness and consideration must be given to areas where the vinyl tiles may need to follow round the core of the building and meet up again.
8. To ensure tile joints do not fall in the centre of doorways or other similar heavy traffic areas, it may prove necessary to offset the centre line/datum. Such areas will be identifiable from the setting out plans upon which the tender bid was based and any variation to these plans, particularly where cost implications result, will be submitted for comment by the Client/Main Contractor prior to installation. Specific installation design requirements eg. border/feature details must also be taken into account when setting	

METHOD STATEMENT – FLOORING INSTALLATION

		out and marking/striking datum lines.
		The materials will be installed in accordance with the respective manufacturer instructions, which will generally involve one of the following methods:
		Note: Adhesives will be applied to the subfloor using a V-notched trowel with a 60-degree included angle. The depth and spacing of the notches will be in accordance with both the manufacturer's recommendations and BS 8203. Some contact adhesives can also be applied by smooth spreader or brush. A primer will be used where recommended.
	a.	Laying into wet adhesive - this method will be used for water borne and gum/spirit adhesives and the floor covering will be laid into the adhesive while it is still wet.
	b.	Laying into dry adhesive - this method will be mainly used in conjunction with vinyl tiles and bitumen-based adhesives, particularly when laying over non-absorbent subfloors. The adhesive will be spread onto the subfloor and allowed to dry to a firm tack ensuring all water/solvent has evaporated (30 minutes to 3 hours) before the flooring is laid. Only as much adhesive will be applied as can be covered while the adhesive remains receptive.
	c.	Laying into contact adhesive - contact adhesives will be applied to both the subfloor and the underside of the floor covering and both films of adhesive will be allowed to dry before the flooring is laid. The flooring must be carefully positioned as a strong bond is formed on contact. The area spread with adhesive at any one time will be such that it can be covered with flooring within the time that the adhesive remains receptive, generally about 30 minutes from the time that the adhesive films become touch dry.
	1.	For areas to receive tile products, the correct adhesive will be applied to the subfloor (as at a, b or c above) in sections about two centrelines.
	2.	The first tile will be positioned at the cross-section of the two lines when the adhesive is ready to accept the flooring.
	3.	The tile will be pressed firmly into place making certain all air has been expelled from beneath the tile.
	4.	The remainder of the main field tiles will then be installed in the same manner and rolled as previously detailed.
	5.	Care will be taken to tightly butt adjoining tiles, eliminate gaps and maintain bond throughout the installation.
	6.	Any directional requirements of tile products will also be taken into consideration when laying adjacent tiles.

METHOD STATEMENT – FLOORING INSTALLATION

	7.	The perimeter tiles will then be scribed/templated and cut using the correct tools.					
	8.	These tiles will be installed once the adhesive is ready to accept the covering and will be similarly rolled as already described.					
Temporary Supports and Props Needed to Facilitate the works	(If none, state none). None						
Methods of Access & Egress to the work area	(i.e.: Ladders/MEWPS/Scaffolds/Trestles/Step ladders etc). Forklift provided by the main contractor						
Fall protection measures (Where work at height cannot be eliminated:- consider both personnel & materials)	(i.e.: Guard rails/Toe boards/Brick Guards/Safety Harnesses/Exclusion Zones etc). None required.						
Hazardous Substances	(i.e.: Lubricants/Solvents/Flammable Material/Refrigerants/Welding Gasses etc.).						
Attach COSHH assessments and MSDS	GHS06 Acute Toxic 	GHS07 Harmful / Irritant / sensitiser 	GHS05 Corrosive 	GHS09 Hazardous to the aquatic environment 	GHS03 Oxidising 	GHS02 Flammable 	GHS01 Explosive 
	Very Toxic	Harmful / Irritant	Corrosive	Dangerous for the Environment	Oxidising	Highly Flammable	Explosive
							Other
SWL's: (Site Working Load)	Detail any limits on the loadings applicable to temporary plant/equipment or fixed elements Not applicable						
Required Personnel Protective Equipment:							
Other :	Safety Gloves	Hard Hats	Safety Boots	Hearing Protection	Respiratory Protection	Eye Protection	Other
Hi Visibility Vest	✓	✓	✓	✗	✗	✓	
EN471	EN374-9	EN397	EN345	EN352:3	EN143	EN166	
	EN388			Helmet	EN149	EN172	

METHOD STATEMENT – FLOORING INSTALLATION

Description of Activity	Stair Nosing Installation				Revision no:		01	
Knee Pads				Mounted	(FFP3)			
Emergency Procedures	The works undertaken do not have inherent risk that would require emergency procedures. Operatives will follow the emergency procedures identified at the site induction with regard to on site evacuation.							
	Name of On-site First Aider				Main Contractors Site First Aider			
	First Aid Box Location				As indicated at site induction			
	Location of nearest Hospital				As indicated at site induction			
Other information & Comments:	CSCS cards must be shown at the induction. Prior to commencement of the installation works, the working areas will be safe zoned adopting the appropriate methodology to prevent or minimise through traffic or other trades operatives.							
	All generated waste to be placed into segregated bins provided the principle contractor i.e.: wood, plastic, textile and dust.							
Environmental Control								

DECLARATION OF WORKING METHODS

All Subcontract works will be executed to the Clients satisfaction and in compliance with the requirements of the contract specification. Methods employed will be in accordance with Amphill Flooring Health & Safety Programme, good practice and with those recommended by the manufacturer.

QUALITY CONTROL

All site operations will be carried out in accordance with procedures detailed within the relevant sections of the Company Quality Manual, a copy of which is available. Our Contracts Manager will have full responsibility for implementation of all systems in this respect.

All work will be undertaken by qualified competent persons with experience of the type of work described above, and in all cases in full accordance with safety procedures specified in the company's Health & Safety Policy. Where working environments or activities are deemed unsafe, subcontractors can refuse to undertake the works and raise the issues with Management without fear of recrimination.

Personnel involved:	Name	Sign	Date
Sign to confirm this document has been understood and will be adhered to.			

METHOD STATEMENT – ENTRANCE MATTING INSTALLATION

Description of Activity	Entrance Matting Installation	Revision no:	1
Project name	Waitrose Newport	Project ref	Matting
Prepared for		Package ref	5281
Site address	Audley Road	Start date	02/09/26
	Newport	Finish date	23/09/26
	TF10 7DS	Prepared by	Luke Witham
		Review date	20/08/26

Personnel involved	Name	Contact Number	Role/Trade
Works Supervisor			

Key plant & tool required	
Key materials required	
Other essential equipment	(i.e.: access platforms/winches/ladders/etc)
Specific identified residual hazards: (or refer to the task specific risk assessments)	Please refer to material data sheet
Specific Staff Training Requirements	(i.e.: Confined Spaces/Adhesives/wheels/Working at Height/Plant Operations etc)
	All site operatives to attend the site induction and abide by the site rules as indicated in induction. Toolbox talks as and when required
	Daily briefing meetings held each morning.
	Safety committee meetings attended as required

METHOD STATEMENT – ENTRANCE MATTING INSTALLATION

Method of Working	Entrance Matting Installation Method Statement
	1. Matting will be delivered directly to site. The quantity and condition of the material will be checked and any discrepancy recorded and the appropriate action taken. The materials will be distributed to the working areas by mechanical and/or human resources carefully observing the manual handling procedures not exceeding safe lifting weight.
	2. The subfloor will be vacuumed clean of any loose debris and/or other contaminants and checked for suitability to receive the matting. A full inspection of the subfloor will be undertaken to identify areas where making good is required.
	3. Once approved by the relevant authority, making good will be undertaken by the installation of a self-levelling smoothing underlayment.
	4. The matting will be neatly cut to fit and pressed firmly into place using a jig-saw or chopsaw. No adhesive is required.
	5. Upon completion, newly installed areas will be inspected to ensure materials have been fitted correctly and in accordance with the relevant specification, finish schedule and/or drawing. Any discrepancies may be rectified prior to hand over to the Client.

METHOD STATEMENT – ENTRANCE MATTING INSTALLATION

Temporary Supports and Props Needed to Facilitate the works	(If none, state none). None						
Methods of Access & Egress to the work area	(i.e.: Ladders/MEWPS/Scaffolds/Trestles/Step ladders etc). Forklift provided by the main contractor						
Fall protection measures (Where work at height cannot be eliminated:- consider both personnel & materials)	(i.e.: Guard rails/Toe boards/Brick Guards/Safety Harnesses/Exclusion Zones etc). None required.						
Hazardous Substances	(i.e.: Lubricants/Solvents/Flammable Material/Refrigerants/Welding Gasses etc.).						
Attach COSHH assessments and MSDS	GHS06 Acute Toxic 	GHS07 Harmful / Irritant / Skin sensitiser 	GHS05 Corrosive 	GHS09 Hazardous to the aquatic environment 	GHS03 Oxidising 	GHS02 Flammable 	GHS01 Explosive 
	Very Toxic	Harmful / Irritant	Corrosive	Dangerous for the Environment	Oxidising	Highly Flammable	Explosive
SWL's: (Site Working Load)	Detail any limits on the loadings applicable to temporary plant/equipment or fixed elements Not applicable						
Required Personnel Protective Equipment:							
Other :	Safety Gloves	Hard Hats	Safety Boots	Hearing Protection	Respiratory Protection	Eye Protection	Other
Hi Visibility Vest	✓	✓	✓	✗	✗	✗	
EN471	EN374-9	EN397	EN345	EN352:3	EN143	EN166	
	EN388			Helmet	EN149	EN172	
Knee Pads				Mounted	(FFP3)		
Emergency Procedures	The works undertaken do not have inherent risk that would require emergency procedures. Operatives will follow the emergency procedures identified at the site induction with regard to on site evacuation.						
	Name of On-site First Aider				Main Contractors Site First Aider		
	First Aid Box Location				As indicated at site induction		
	Location of nearest Hospital				As indicated at site induction		

METHOD STATEMENT – ENTRANCE MATTING INSTALLATION

Method of Working	Manual Handling Method Statement
	MS
	All operatives involved in the manual lifting of materials and plant will be conversant with the Ampt Hill Flooring Plans of Action with regards to lifting, in order to prevent any pain and injury.
	The operative is to examine the object and make sure:
	• The weight is stable and won't shift. • There are no sharp edges or points sticking out. • There is the correct number of people, based on the size, shape and weight of the load. • You can clearly see over it. • The operative is to ensure that: • The easiest route is chosen, not necessarily the shortest. • That they have a clear path – moving any objects that could be a trip hazard or bumping obstacle. • Identify places to stop and rest. • Ensure a designated clear unloading zone is achieved.
	Manual Handling Methods
	All operatives to adopt the following safe lifting position:
	1. Assume the safe lifting position – squat by bending at the hips and knees. Your ears, shoulders and hips form nearly a straight line. Keep your feet shoulder-width apart and your feet turned out.
	2. Maintain your back's natural curves – do not bend your back
	3. Let your legs do the lifting.
	When physically lifting, operatives must:
	1. Stand close to the object and keep a wide stance.
	2. Tighten stomach muscles
	3. Assume the above safe lifting position
	4. Pull the load close to the body.
	5. Let the legs not the back power the lift.
	Whilst carrying DO NOT TWIST, move your feet to turn.
	When unloading, operatives must adopt the following procedures pending on size and weight of loads:
	1. Face the spot you have chosen and lower the load slowly by using your legs, not your back.
	2. Bend knees.
	3. Keep fingers away from bottom of load.
	With oversized or Heavy Loads the following procedure is to be adopted
	1. Work as a team – use a two-person lift.
	2. Designate one person to direct the lift.
	3. Lift at the same time.
	4. Keep the load level when carrying

METHOD STATEMENT – ENTRANCE MATTING INSTALLATION

	5.	Move smoothly together and unload at the same time.
	With bags & Sacks:	
	1.	Assume the safe lifting position.
	2.	Grasp load at opposite top and bottom corners
	3.	Power your body up with your legs and use your arms to raise the load to rest on your hip.
	4.	Fully stand and move the load to rest on your shoulder.
	With Carts and Hand-trucks (for awkward sized and heavy loads)	
	1.	Select the right equipment. Do not use “skates” to move rolls of carpet as this encourages bad grip & posture.
	2.	Place heavy objects on the bottom, with load over the axles. Stack lighter objects on top, but don't block your view.
	3.	Secure bulky, loose or delicate objects.
	4.	Push the load forward with legs and upper body.
	5.	Maintain a firm grip with buttocks out, back in its natural curves and knees bent.
	6.	Hand position should be between upper thigh and chest position when pushing.
	7.	Avoid pulling the load.
	UNLOADING FROM DELIVERY VEHICLES	
	1.	Materials will be delivered on a rigid vehicle, with tail lift facility whenever possible.

METHOD STATEMENT – ENTRANCE MATTING INSTALLATION

Method of Working	Latex Smoothing Compound Application - Method Statement	
	MS	
	1.	Materials will be delivered directly to site and following off loading the quantity and condition of bags will be checked and any discrepancy recorded and the appropriate action taken.
	2.	The materials will be distributed by mechanical and/or human resources.
	3.	Prior to installation, the appropriate dampness and climatic tests will be conducted to ensure conditions in working areas are in accordance with the respective manufacturer recommendations and the relevant British Standard (BS 8203 requires the relative humidity of the subfloor not to exceed 75% RH) with the general work area temperature being no less than 12 degrees centigrade.
	4.	In all areas prepared to receive smoothing compound, all operatives will be conversant with relevant information and personal protection to enable the use of any material safely and without risk to health.
	The material will be installed using the following method:	
	1.	The subfloor will be vacuumed thoroughly to ensure it is clean and free of any barrier materials such as dust, oil, grease etc. and primed according to the manufacturers recommendations.
	2.	Latex powder and latex liquid will be blended in the appropriate quantities (as recommended by the manufacturer) until a smooth lump free mortar is achieved.
	3.	Starting from a corner of the specified area the mortar will be poured into position and spread with a trowel/rake/spikey roller to the required thickness with a smooth finish.
	If any trowel marks remain, the surface will either be;	
		Smoothed once again with a wet trowel when the latex has stiffened but not fully hardened. Or Using an STR sanding machine/carborundum block to sand down, once the surface has hardened.
	1.	Working to a grid of bays this procedure will be repeated, until the whole area has been covered.
	2.	On completion, the floor should be protected from foot traffic until the compound has hardened and dried.
	3.	All waste and debris will be removed on a daily basis to ensure all working areas are

METHOD STATEMENT – ENTRANCE MATTING INSTALLATION

		clean and free from hazards.						
Temporary Supports and Props Needed to Facilitate the works	(If none, state none). None							
Methods of Access & Egress to the work area	(ie: Ladders/MEWPS/Scaffolds/Trestles/Step ladders etc). Forklift provided by the main contractor							
Fall protection measures (Where work at height cannot be eliminated:- consider both personnel & materials)	(ie: Guard rails/Toe boards/Brick Guards/Safety Harnesses/Exclusion Zones etc). None required.							
Hazardous Substances	(ie: Lubricants/Solvents/Flammable Material/Refrigerants/Welding Gasses etc.).							
Attach COSHH assessments and MSDS	GHS06 Acute Toxic 	GHS07 Harmful / Irritant / sensitiser 	GHS05 Corrosive 	GHS09 Hazardous to the aquatic environment 	GHS03 Oxidising 	GHS02 Flammable 	GHS01 Explosive 	
	Very Toxic	Harmful / Irritant	Corrosive	Dangerous for the Environment	Oxidising	Highly Flammable	Explosive	Other
SWL's: (Site Working Load)	Detail any limits on the loadings applicable to temporary plant/equipment or fixed elements Not applicable							
Required Personnel Protective Equipment:								
Other :	Safety Gloves	Hard Hats	Safety Boots	Hearing Protection	Respiratory Protection	Eye Protection	Other	Other
Hi Visibility Vest	✓	✓	✓	✗	✓	✓		
EN471	EN374-9	EN397	EN345	EN352:3	EN143	EN166		
	EN388			Helmet	EN149	EN172		
Respirator while mixing				Mounted	(FFP3)			
Emergency Procedures	The works undertaken do not have inherent risk that would require emergency procedures. Operatives will follow the emergency procedures identified at the site induction with regard to on site evacuation.							
	Name of On-site First Aider				Main Contractors Site First Aider			

METHOD STATEMENT – ENTRANCE MATTING INSTALLATION

[illegible]

METHOD STATEMENT – ENTRANCE MATTING INSTALLATION

Temporary Supports and Props Needed to Facilitate the works	(If none, state none). None																																																
Methods of Access & Egress to the work area	(ie: Ladders/MEWPS/Scaffolds/Trestles/Step ladders etc). Forklift provided by the main contractor																																																
Fall protection measures (Where work at height cannot be eliminated:- consider both personnel & materials)	(ie: Guard rails/Toe boards/Brick Guards/Safety Harnesses/Exclusion Zones etc). None required.																																																
Hazardous Substances	(ie: Lubricants/Solvents/Flammable Material/Refrigerants/Welding Gasses etc.).																																																
Attach COSHH assessments and MSDS	<table border="1"> <tr> <td>GHS06 Acute Toxic</td><td>GHS07 Harmful / Irritant / sensitiser</td><td>GHS05 Corrosive</td><td>GHS09 Hazardous to the aquatic environment</td><td>GHS03 Oxidising</td><td>GHS02 Flammable</td><td>GHS01 Explosive</td><td></td></tr> <tr> <td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>Very Toxic</td><td>Harmful / Irritant</td><td>Corrosive</td><td>Dangerous for the Environment</td><td>Oxidising</td><td>Highly Flammable</td><td>Explosive</td><td>Other</td></tr> <tr> <td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td></td></tr> <tr> <td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr> <td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>	GHS06 Acute Toxic	GHS07 Harmful / Irritant / sensitiser	GHS05 Corrosive	GHS09 Hazardous to the aquatic environment	GHS03 Oxidising	GHS02 Flammable	GHS01 Explosive										Very Toxic	Harmful / Irritant	Corrosive	Dangerous for the Environment	Oxidising	Highly Flammable	Explosive	Other	x	x	x	x	x	x	x																	
GHS06 Acute Toxic	GHS07 Harmful / Irritant / sensitiser	GHS05 Corrosive	GHS09 Hazardous to the aquatic environment	GHS03 Oxidising	GHS02 Flammable	GHS01 Explosive																																											
																																																	
Very Toxic	Harmful / Irritant	Corrosive	Dangerous for the Environment	Oxidising	Highly Flammable	Explosive	Other																																										
x	x	x	x	x	x	x																																											
SWL's: (Site Working Load)	Detail any limits on the loadings applicable to temporary plant/equipment or fixed elements Not applicable																																																
Required Personnel Protective Equipment:	<table border="1"> <tr> <td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>Safety Gloves</td><td>Hard Hats</td><td>Safety Boots</td><td>Hearing Protection</td><td>Respiratory Protection</td><td>Eye Protection</td><td>Other</td><td>Other</td></tr> <tr> <td>Hi Visibility Vest</td><td>✓</td><td>✓</td><td>✓</td><td>x</td><td>x</td><td>✓</td><td></td></tr> <tr> <td>EN471</td><td>EN374-9</td><td>EN397</td><td>EN345</td><td>EN352:3</td><td>EN143</td><td>EN166</td><td></td></tr> <tr> <td></td><td>EN388</td><td></td><td></td><td>Helmet</td><td>EN149</td><td>EN172</td><td></td></tr> <tr> <td>Knee Pads</td><td></td><td></td><td></td><td>Mounted</td><td>(FFP3)</td><td></td><td></td></tr> </table>									Safety Gloves	Hard Hats	Safety Boots	Hearing Protection	Respiratory Protection	Eye Protection	Other	Other	Hi Visibility Vest	✓	✓	✓	x	x	✓		EN471	EN374-9	EN397	EN345	EN352:3	EN143	EN166			EN388			Helmet	EN149	EN172		Knee Pads				Mounted	(FFP3)		
																																																	
Safety Gloves	Hard Hats	Safety Boots	Hearing Protection	Respiratory Protection	Eye Protection	Other	Other																																										
Hi Visibility Vest	✓	✓	✓	x	x	✓																																											
EN471	EN374-9	EN397	EN345	EN352:3	EN143	EN166																																											
	EN388			Helmet	EN149	EN172																																											
Knee Pads				Mounted	(FFP3)																																												
Emergency Procedures	The works undertaken do not have inherent risk that would require emergency procedures. Operatives will follow the emergency procedures identified at the site induction with regard to on site evacuation. <table border="1"> <tr> <td>Name of On-site First Aider</td><td>Main Contractors Site First Aider</td></tr> <tr> <td>First Aid Box Location</td><td>As indicated at site induction</td></tr> <tr> <td>Location of nearest Hospital</td><td>As indicated at site induction</td></tr> </table>	Name of On-site First Aider	Main Contractors Site First Aider	First Aid Box Location	As indicated at site induction	Location of nearest Hospital	As indicated at site induction																																										
Name of On-site First Aider	Main Contractors Site First Aider																																																
First Aid Box Location	As indicated at site induction																																																
Location of nearest Hospital	As indicated at site induction																																																

METHOD STATEMENT – ENTRANCE MATTING INSTALLATION

Other information & Comments:	CSCS cards must be shown at the induction. Prior to commencement of the installation works, the working areas will be safe zoned adopting the appropriate methodology to prevent or minimise through traffic or other trades operatives.
Environmental Control	All generated waste to be placed into segregated bins provided the principle contractor ie: wood, plastic, textile and dust.

DECLARATION OF WORKING METHODS

All Subcontract works will be executed to the Clients satisfaction and in compliance with the requirements of the contract specification. Methods employed will be in accordance with Amphill Flooring Health & Safety Programme, good practice and with those recommended by the manufacturer.

QUALITY CONTROL

All site operations will be carried out in accordance with procedures detailed within the relevant sections of the Company Quality Manual, a copy of which is available. Our Contracts Manager will have full responsibility for implementation of all systems in this respect.

All work will be undertaken by qualified competent persons with experience of the type of work described above, and in all cases in full accordance with safety procedures specified in the company's Health & Safety Policy. Where working environments or activities are deemed unsafe, subcontractors can refuse to undertake the works and raise the issues with Management without fear of recrimination.

Personnel involved:	Name	Sign	Date
Sign to confirm this document has been understood and will be adhered to.			

Activity			Persons At Risk			Assessor			Assessment No.		
Manual Handling			Employees, Subcontractors, Other Trades						1		
Health & Safety Director			Signature			Issue Date			Review Date		
Mark Mulchinock						20/08/2026			12 Months		
		Risk Level Without Control Measures			Waitrose Newport			Risk Level With Existing Control Measures			
Hazards Identified	Persons At Risk	Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Control Measures			Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Further Action
Distribution of Material Around Site	Employees, Subcontractors Risk of injury due to poor manual handling techniques, crushing fingers	3	3	9	- Visual risk assessments to be carried out before any manual handling activities commence and to ensure there is adequate room available and all walkways are clear from obstructions - Delivery vehicles to be positioned as close to the storage area as possible - Where possible, use mechanical aids i.e. pallet truck, hoist, crane etc. Do not use “skates” to move rolls of carpet as this encourages bad grip & posture. - Ensure materials are securely braced where required - Operatives to receive training on the correct Manual Handling techniques - Operatives are provided with information on the correct way to manually materials, tools etc. - Operatives are only permitted to carry materials within their own capabilities - Operatives will wear protective footwear and safety gloves			1	3	3	Team Leader to assess safe method of lifting before allowing any operations to commence, and to communicate the required actions to operatives

Distribution of Material Around Site	Employees, Subcontractors. Risk of tripping, stepping on sharp objects i.e. Nails	3	3	9	- Visual risk assessments to be carried out before any manual handling activities commence and to ensure there is adequate room available and all walkways are clear from obstructions - Operatives will wear protective footwear and safety gloves	1	3	3	None
Distribution of Material Around Site	Employees, Subcontractors. Object falling from scaffolding	3	3	9	- Operatives will wear protective footwear, hard hat and safety gloves - Operatives to remain vigilant when accessing site, in particular when walking underneath / below scaffolding - Operatives to report to Site Manager any areas where scaffolding is unprotected i.e. missing toeboards	1	3	3	None
Offloading Materials from Vehicles	Employees, Subcontractors. Objects falling from vehicle	3	2	6	- Operatives will wear protective footwear, hard hat and safety gloves - Delivery vehicles to be positioned as close to the storage area as possible - Where possible, use mechanical aids i.e. pallet truck, hoist, crane etc. - Operatives to receive training on the correct Manual Handling techniques - Operatives are provided with information on the correct way to manually materials, tools etc. - Operatives are only permitted to carry materials within their own capabilities	1	2	2	None
Offloading Materials from Vehicles	Employees, Subcontractors. Crush of feet by tail lift or pallet truck	3	2	6	- Operatives will wear protective footwear and safety gloves - Delivery vehicles to be positioned as close to the storage area as possible - Only trained and competent operatives are permitted to use pallet trucks - Operatives to ensure they are standing clear of the tail lift before it is lowered	1	2	2	None



RISK ASSESSMENT

FLOORING INSTALLATION

Activity		Persons At Risk			Assessor	Assessment No.		
Latex Smoothing Compound Application		Employees, Subcontractors, Other Trades				1		
Health & Safety Director		Signature			Issue Date	Review Date		
Mark Mulchinock					20/08/2026	12 Months		
		Risk Level Without Control Measures			Waitrose Newport			Risk Level With Existing Control Measures
Hazards Identified	Persons At Risk	Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Control Measures			Further Action
Distribution of Latex Units on Floor Area	Employees, Subcontractors Risk of injury due to poor manual handling techniques	3	2	6	- Visual risk assessments to be carried out before any manual handling activities commence and to ensure there is adequate room available - Delivery vehicles to be positioned as close to the storage area as possible - Where possible, use mechanical aids i.e. pallet truck - Ensure materials are securely braced where required - Operatives to receive training on the correct Manual Handling techniques - Operatives are provided with information on the correct way to manually materials, tools etc. - Operatives will wear protective footwear and safety gloves			1 2 2 Team Leader to assess safe method of lifting before allowing any operations to commence, and to communicate the required actions to operatives

Vacuum or Sweeping Subfloor	Employees, Subcontractors, Other Trades. Ill health caused by inhalation of dust; protruding sharp objects i.e. nails, tripping hazards	3	3	9	- Vacuuming is preferential to sweeping as it extracts the dust. If vacuuming is not possible, the risk of creating airborne dust through sweeping can be reduced by damping the area first. - Operatives should use water sparingly to avoid any additional risk that this creates such as slippery floors and ensure controls are in place. - Visual risk assessments to be carried out before any vacuum / sweeping activities commence and to ensure it is safe to proceed - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - All operations that generate significant quantities of dust are undertaken in well-ventilated areas whenever possible. - All personnel wear disposable dust masks conforming to EN 149 FFP3. - Operatives will wear S3 safety boots and protective glasses	1	3	3	None
Mixing of Smoothing Compound Units	Employees, Subcontractors, Other Trades. Burns to hands, irritation to eyes, irritation to nasal and respiratory system	3	3	9	- Only trained and competent operatives are permitted to use smoothing compounds - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - Operatives will refer to relevant COSHH Assessment prior to using smoothing compounds - All operations will be carried out in in well-ventilated areas. - All personnel wear disposable face masks conforming to EN 149 FFP3. - Operatives will wear protective gloves when using smoothing compounds and barrier creams; they will also wear protective goggles - Spillages will be cleaned away immediately	1	3	3	None

Carbide Grinding of Installed Latex	Employees, Subcontractors. Injury to knees and back due to excessive kneeling, bad posture, irritation to nasal and respiratory system	3	3	9	- Operatives are required to take regular breaks when carrying out activities that require operatives to kneel for excessive period. - Operatives will wear knee pads to protect their knees. - Operatives will ensure they have the correct posture and do not over stretch - Operatives will wear S3 Safety Boots and disposable face masks conforming to EN 149 FFP3.	1	3	3	None
Waste Disposal	Employees, Subcontractors. Ill health caused by inhalation of dust; fire, cuts to hands and arms	3	3	9	- All waste materials will be disposed of in the correct skips provided - Operatives will wear S3 safety boots and protective gloves when disposing of waste - Operatives will regularly dispose of waste ensuring quantities are kept to a minimum and are not stored next to any sources of heat - Where dusts are generated, operatives will wear disposable dust masks conforming to EN 149 FFP3	1	3	3	None
Using 110 Volt Equipment	Employees, Subcontractors. Risk of electrocution / electric shock	3	3	9	- Only trained and competent operatives undertake activities involving the use of 110v electrical equipment. - The equipment is used and maintained in accordance with the manufacturer's instructions and is inspected for obvious defects and not used. - All electrical equipment is electrically tested and inspected by a trained and competent person, on a quarterly basis. - Where a risk of developing Hand Arm Vibration exists, exposure should be evaluated and controls applied. - Eye protection, protective gloves and S3 safety boots are to be worn at all times when using electrical tools. - Team Leaders to ensure electrical equipment is by operatives in accordance with their training.	1	3	3	Operatives to visually check 110v equipment before use. Any defect equipment to be removed from site immediately. Operatives to ensure all electrical equipment is PAT tested on a 3 monthly basis.
Slips, Trips & Falls	Employees, Subcontractors and Others working in the vicinity. Risk of tripping over objects, slipping on	3	2	6	All equipment / materials are to be stored in a designated area	1	2	2	Team Leader to monitor working area to ensure there are no hazards

	spillages or wet surfaces, or falling				- Operatives to ensure all waste materials are cleared away as soon as possible and disposed of in the skips provided. - Cables are not to be left trailing across walkways and should be visible. All cables will be suspended from above using sky hooks.				
Using Hand Tools	Employees, Subcontractors. Injuries to hands	3	2	6	- All hand tools are inspected for obvious defects prior to use. Any equipment found to be defective is not to be used. - Only competent and trained operatives undertake activities that involve the use of hand tools. - Gloves are to be worn to protect hands against cuts and impact injuries.	1	2	2	None

Activity			Persons At Risk			Assessor			Assessment No.		
Edge Trim Installation			Employees, Subcontractors, Other Trades						1		
Health & Safety Director			Signature			Issue Date			Review Date		
						20/08/2026			12 Months		
		Risk Level Without Control Measures			Waitrose Newport			Risk Level With Existing Control Measures			
Hazards Identified	Persons At Risk	Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Control Measures			Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Further Action
Cutting Edge Trims	Employee, Subcontractors. Cuts to hands, arms, body.	3	3	9	- Only trained and competent operatives are authorised to use hacksaws / bandsaws. - Operatives will carry out a visual inspection of the hacksaws / bandsaws prior to use - Operatives will wear protective gloves when using hacksaws / bandsaws to protect their hands. - Any hacksaws / bandsaws found to be defective are not to be used. - All bandsaws will be fitted with hand guards 110v Bandsaws will be PAT Tested every 3 months			1	3	3	None
Applying adhesive to Subfloor base	Employees, Subcontractors, Other Trades. Skin dermatitis to hands and arms, slip hazard, asphyxiation	3	3	9	- Only trained and competent operatives are permitted to use adhesives - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - Operatives will ensure the area is well-ventilated - Operatives will wear disposable face masks conforming to EN 149 FFFP2. - Operatives will refer to relevant COSHH Assessment prior to using adhesives			1	3	3	None

					- Operatives will wear protective gloves when using adhesives and barrier creams - Spillages will be cleaned away immediately				
Applying adhesive to Stair Tread / Riser	Employees, Subcontractors, Other Trades. Skin dermatitis to hands and arms, slip hazard	3	3	9	- Only trained and competent operatives are permitted to use adhesives - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - Operatives will refer to relevant COSHH Assessment prior to using adhesives - Operatives will wear impervious protective gloves when using adhesives and barrier creams - Spillages will be cleaned away immediately	1	3	3	None
Applying adhesive to Edge Trim prior to Mechanical Fixing	Employees, Subcontractors, Other Trades. Skin dermatitis to hands and arms, slip hazard	3	3	9	- Only trained and competent operatives are permitted to use adhesives - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - Operatives will refer to relevant COSHH Assessment prior to using adhesives - Operatives will wear impervious protective gloves when using adhesives and barrier creams - Spillages will be cleaned away immediately	1	3	3	None
Installation of Edge Trims	Employees, Subcontractors. Injury to knee due to excessive kneeling.	3	2	6	- Operatives are required to take regular breaks when carrying out activities that require operatives to kneel for excessive period. - Operatives will wear knee pads to protect their knees. - Operatives will ensure they have the correct posture and do not over stretch when installing edge trims - Operatives will wear S3 Safety Boots	1	2	2	None

Distribution of Edge Trims on Floor Area	Employees, Subcontractors Risk of injury due to poor manual handling techniques	3	2	6	- Visual risk assessments to be carried out before any manual handling activities commence and to ensure there is adequate room available - Delivery vehicles to be positioned as close to the storage area as possible - Where possible, use mechanical aids i.e. pallet truck - Ensure materials are securely braced where required - Operatives to receive training on the correct Manual Handling techniques - Operatives are provided with information on the correct way to manually materials, tools etc. - Operatives will wear protective footwear and safety gloves	1	2	2	Team Leader to assess safe method of lifting before allowing any operations to commence, and to communicate the required actions to operatives
Mechanically Fixing Edge Trims	Employees, Subcontractors. Risk of electrocution / electric shock, general injury	3	3	9	- Only trained and competent operatives undertake activities involving the use of 110v drills - The equipment is used and maintained in accordance with the manufacturer's instructions and is inspected for obvious defects and not used. - All electrical equipment is electrically tested and inspected by a trained and competent person, on a quarterly basis. - Where a risk of developing Hand Arm Vibration exists, exposure should be evaluated and controls applied. - Eye protection, protective gloves and S3 Safety boots are to be worn at all times when using electrical tools. - Team Leaders to ensure electrical equipment is by operatives in accordance with their training. - Operatives to ensure the correct drill bit size is used and any loose clothing and long hair to be tied back.	1	3	3	Operatives to visually check 110v equipment before use. Any defect equipment to be removed from site immediately. Operatives to ensure all electrical equipment is PAT tested on a 3 monthly basis.
Vacuum or Sweeping Subfloor	Employees, Subcontractors, Other Trades. Ill health caused by inhalation of dust; protruding sharp objects i.e. nails, tripping hazards	3	3	9	- Visual risk assessments to be carried out before any vacuum / sweeping activities commence and to ensure it is safe to proceed - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access	1	3	3	None

					- All operations that generate significant quantities of dust are undertaken in well-ventilated areas whenever possible. - All personnel wear disposable dust masks conforming to EN 149 FFP3 - Operatives will wear S3 Safet boots and protective glasses				
Waste Disposal	Employees, Subcontractors. Ill health caused by inhalation of dust; fire, cuts to hands and arms	3	3	9	- All waste materials will be disposed of in the correct skips provided - Operatives will wear S3 Safety Boots and protective gloves when disposing of waste - Operatives will regularly dispose of waste ensuring quantities are kept to a minimum and are not stored next to any sources of heat - Where dusts are generated, operatives will wear disposable dust masks conforming to EN 149 FFP3.	1	3	3	None
Slips, Trips & Falls	Employees, Subcontractors and Others working in the vicinity. Risk of tripping over objects, slipping on spillages or wet surfaces, or falling	3	2	6	- All equipment / materials are to be stored in a designated area - Operatives to ensure all waste materials are cleared away as soon as possible and disposed of in the skips provided. - Cables are not to be left trailing across walkways and should be visible. All cables will be suspended from above using sky hooks.	1	2	2	Team Leader to monitor working area to ensure there are no hazards
Using Hand Tools	Employees, Subcontractors. Injuries to hands	3	2	6	- All hand tools are inspected for obvious defects prior to use. Any equipment found to be defective is not to be used. - Only competent and trained operatives undertake activities that involve the use of hand tools. - Gloves are to be worn to protect hands against cuts and impact injuries.	1	2	2	None

Activity			Persons At Risk			Assessor			Assessment No.		
Vinyl Sheet Installation			Employees, Subcontractors, Other Trades						1		
Health & Safety Director			Signature			Issue Date			Review Date		
						20/08/26			12 Months		
		Risk Level Without Control Measures			Waitrose Newport			Risk Level With Existing Control Measures			
Hazards Identified	Persons At Risk Dave Patrick	Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Control Measures			Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Further Action
Cutting Vinyl Sheets	Employee, Subcontractors. Cuts to hands, arms, body.	3	3	9	- Only trained and competent operatives are authorised to use knives. - Operatives will wear protective gloves when using knives to protect their hands. - Any knives found to be defective are not to be used. - All knives will be fitted fixed bladed knives and placed in a holster when not in use. Operatives will ensure the blade is not exposed when not in use.			1	3	3	None
Installation of Vinyl Sheets	Employees, Subcontractors. Injury to knee due to excessive kneeling.	3	2	6	- Operatives are required to take regular breaks when carrying out activities that require operatives to kneel for excessive period. - Operatives will wear knee pads to protect their knees. - Operatives will ensure they have the correct posture and do not over stretch when installing vinyl sheets - Operatives will wear suitable S3 safety boots			1	2	2	None

Distribution of Vinyl Sheets or Rolls on Floor Area	Employees, Subcontractors Risk of injury due to poor manual handling techniques	3	2	6	- Visual risk assessments to be carried out before any manual handling activities commence and to ensure there is adequate room available - Delivery vehicles to be positioned as close to the storage area as possible - Where possible, use mechanical aids i.e. pallet truck - Ensure materials are securely braced where required - Operatives to receive training on the correct Manual Handling techniques - Operatives are provided with information on the correct way to manually materials, tools etc. - Full rolls of vinyl will be lifted by teams of operatives - Operatives will wear protective footwear and safety gloves	1	2	2	Team Leader to assess safe method of lifting before allowing any operations to commence, and to communicate the required actions to operatives
Vacuum or Sweeping Subfloor	Employees, Subcontractors, Other Trades. Ill health caused by inhalation of dust; protruding sharp objects i.e. nails, tripping hazards	3	3	9	- Vacuuming is preferential to sweeping as it extracts the dust. If vacuuming is not possible, the risk of creating airborne dust through sweeping can be reduced by damping the area first. - Operatives should use water sparingly to avoid any additional risk that this creates such as slippery floors and ensure controls are in place. - Visual risk assessments to be carried out before any vacuum / sweeping activities commence and to ensure it is safe to proceed - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - All operations that generate significant quantities of dust are undertaken in well-ventilated areas whenever possible. - All personnel wear disposable dust masks conforming to EN 149 FFP3. - Operatives will wear S3 safety boots and protective glasses	1	3	3	None
Hot Welding of Vinyl	Employees, Subcontractors. Burns to skin	3	2	6	Only trained and competent operatives are permitted to use hot weld guns	1	2	2	None

					- Hot weld guns will be inspected prior to use – defective guns will not be used - Hot weld guns will be PAT tested every 3 months - Hot weld guns will be turned off and placed in an isolated position when not in use - Hot weld gun will be kept away from combustible materials				
Applying adhesive to Subfloor	Employees, Subcontractors, Other Trades. Skin dermatitis to hands and arms, slip hazard	3	2	6	- Only trained and competent operatives are permitted to use adhesives - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - Operatives will refer to relevant COSHH Assessment prior to using adhesives - Operatives will wear protective gloves when using adhesives and barrier creams - Spillages will be cleaned away immediately	1	2	2	None
Disposal of Knife Blades	Employees, Subcontractors. Cuts to hands	3	3	9	- Only trained and competent operatives are permitted to use knives and change blades - Blades will be placed in a sealed container	1	3	3	None
Waste Disposal	Employees, Subcontractors. Ill health caused by inhalation of dust; fire, cuts to hands and arms	3	3	9	- All waste materials will be disposed of in the correct skips provided - Operatives will wear S3 safety boots and protective gloves when disposing of waste - Operatives will regularly dispose of waste ensuring quantities are kept to a minimum and are not stored next to any sources of heat - Where dusts are generated, operatives will wear disposable dust masks conforming to EN 149 FFP3	1	3	3	None
Using 110 Volt Equipment	Employees, Subcontractors. Risk of electrocution / electric shock	3	3	9	- Only trained and competent operatives undertake activities involving the use of 110v electrical equipment. - The equipment is used and maintained in accordance with the manufacturer's instructions and is inspected for obvious defects and not used.	1	3	3	Operatives to visually check 110v equipment before use. Any defect equipment to be removed from site immediately. Operatives to ensure all electrical equipment is PAT tested on a 3 monthly basis.

					- All electrical equipment is electrically tested and inspected by a trained and competent person, on a quarterly basis. - Where a risk of developing Hand Arm Vibration exists, exposure should be evaluated and controls applied. - Eye protection, protective gloves and S3 safety boots are to be worn at all times when using electrical tools. - Team Leaders to ensure electrical equipment is by operatives in accordance with their training.				
Slips, Trips & Falls	Employees, Subcontractors and Others working in the vicinity. Risk of tripping over objects, slipping on spillages or wet surfaces, or falling	3	2	6	- All equipment / materials are to be stored in a designated area - Operatives to ensure all waste materials are cleared away as soon as possible and disposed of in the skips provided. - Cables are not to be left trailing across walkways and should be visible. All cables will be suspended from above using sky hooks.	1	2	2	Team Leader to monitor working area to ensure there are no hazards
Using Hand Tools	Employees, Subcontractors. Injuries to hands	3	2	6	- All hand tools are inspected for obvious defects prior to use. Any equipment found to be defective is not to be used. - Only competent and trained operatives undertake activities that involve the use of hand tools. - Gloves are to be worn to protect hands against cuts and impact injuries.	1	2	2	None

Activity			Persons At Risk			Assessor			Assessment No.		
Vinyl Tile Installation			Employees, Subcontractors, Other Trades						1		
Health & Safety Director			Signature			Issue Date			Review Date		
Mark Mulchinock						20/08/26			12 Months		
		Risk Level Without Control Measures			Waitrose Newport			Risk Level With Existing Control Measures			
Hazards Identified	Persons At Risk	Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Control Measures			Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Further Action
Cutting Vinyl Tiles	Employee, Subcontractors. Cuts to hands, arms, body.	3	3	9	- Only trained and competent operatives are authorised to use knives. - Operatives will wear protective gloves when using knives to protect their hands. - Any knives found to be defective are not to be used. - All knives will be fitted fixed bladed knives and placed in a holster when not in use. Operatives will ensure the blade is not exposed when not in use.			1	3	3	None
Installation of Vinyl Tiles	Employees, Subcontractors. Injury to knee due to excessive kneeling.	3	2	6	- Operatives are required to take regular breaks when carrying out activities that require operatives to kneel for excessive period. - Operatives will wear knee pads to protect their knees. - Operatives will ensure they have the correct posture and do not over stretch when installing vinyl tiles - Operatives will wear suitable safety footwear			1	2	2	None

Distribution of Vinyl Tiles or Rolls on Floor Area	Employees, Subcontractors Risk of injury due to poor manual handling techniques	3	2	6	- Visual risk assessments to be carried out before any manual handling activities commence and to ensure there is adequate room available - Delivery vehicles to be positioned as close to the storage area as possible - Where possible, use mechanical aids i.e. pallet truck - Ensure materials are securely braced where required - Operatives to receive training on the correct Manual Handling techniques - Operatives are provided with information on the correct way to manually materials, tools etc. - Full rolls of vinyl will be lifted by teams of operatives - Operatives will wear protective footwear and safety gloves	1	2	2	Team Leader to assess safe method of lifting before allowing any operations to commence, and to communicate the required actions to operatives
Vacuum or Sweeping Subfloor	Employees, Subcontractors, Other Trades. Ill health caused by inhalation of dust; protruding sharp objects i.e. nails, tripping hazards	3	3	9	- Vacuuming is preferential to sweeping as it extracts the dust. If vacuuming is not possible, the risk of creating airborne dust through sweeping can be reduced by damping the area first. - Operatives should use water sparingly to avoid any additional risk that this creates such as slippery floors and ensure controls are in place. - Visual risk assessments to be carried out before any vacuum / sweeping activities commence and to ensure it is safe to proceed - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - All operations that generate significant quantities of dust are undertaken in well-ventilated areas whenever possible. - All personnel wear disposable dust masks conforming to EN 149 FFP3 - Operatives will wear safety footwear and protective glasses	1	3	3	None

Applying adhesive to Subfloor	Employees, Subcontractors, Other Trades. Skin dermatitis to hands and arms, slip hazard	3	2	6	- Only trained and competent operatives are permitted to use adhesives - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - Operatives will refer to relevant COSHH Assessment prior to using adhesives - Operatives will wear protective gloves when using adhesives and barrier creams - Spillages will be cleaned away immediately	1	2	2	None
Disposal of Knife Blades	Employees, Subcontractors. Cuts to hands	3	3	9	- Only trained and competent operatives are permitted to use knives and change blades - Blades will be placed in a sealed container	1	3	3	None
Waste Disposal	Employees, Subcontractors. Ill health caused by inhalation of dust; fire, cuts to hands and arms	3	3	9	- All waste materials will be disposed of in the correct skips provided - Operatives will wear safety footwear and protective gloves when disposing of waste - Operatives will regularly dispose of waste ensuring quantities are kept to a minimum and are not stored next to any sources of heat - Where dusts are generated, operatives will wear disposable dust masks conforming to EN 149 FFP3	1	3	3	None
Using 110 Volt Equipment	Employees, Subcontractors. Risk of electrocution / electric shock	3	3	9	- Only trained and competent operatives undertake activities involving the use of 110v electrical equipment. - The equipment is used and maintained in accordance with the manufacturer's instructions and is inspected for obvious defects and not used. - All electrical equipment is electrically tested and inspected by a trained and competent person, on a quarterly basis. - Where a risk of developing Hand Arm Vibration exists, exposure should be evaluated and controls applied. - Eye protection, protective gloves and safety footwear is to be worn at all times when using electrical tools. - Team Leaders to ensure electrical equipment is by operatives in accordance with their training.	1	3	3	Operatives to visually check 110v equipment before use. Any defect equipment to be removed from site immediately. Operatives to ensure all electrical equipment is PAT tested on a 3 monthly basis.

RISK ASSESSMENT

FLOORING INSTALLATION

Slips, Trips & Falls	Employees, Subcontractors and Others working in the vicinity. Risk of tripping over objects, slipping on spillages or wet surfaces, or falling	3	2	6	- All equipment / materials are to be stored in a designated area - Operatives to ensure all waste materials are cleared away as soon as possible and disposed of in the skips provided. - Cables are not to be left trailing across walkways and should be visible. All cables will be suspended from above using sky hooks.	1	2	2	Team Leader to monitor working area to ensure there are no hazards
Using Hand Tools	Employees, Subcontractors. Injuries to hands	3	2	6	- All hand tools are inspected for obvious defects prior to use. Any equipment found to be defective is not to be used. - Only competent and trained operatives undertake activities that involve the use of hand tools. - Gloves are to be worn to protect hands against cuts and impact injuries.	1	2	2	None



RISK ASSESSMENT

FLOORING INSTALLATION

Activity			Persons At Risk			Assessor			Assessment No.		
Entrance Matting Installation			Employees, Subcontractors, Other Trades						1		
Health & Safety Director			Signature			Issue Date			Review Date		
						20/08/2026			12 Months		
		Risk Level Without Control Measures			Waitrose Newport			Risk Level With Existing Control Measures			
Hazards Identified	Persons At Risk	Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Control Measures			Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Further Action
Cutting Matting	Employee, Subcontractors. Cuts to hands, arms, body.	3	3	9	- Only trained and competent operatives are authorised to use knives jigsaw & chopsaws. - Operatives will wear protective gloves when using knives to protect their hands. - Any equipment found to be defective are not to be used. - All knives will be fitted fixed bladed knives and placed in a holster when not in use. Operatives will ensure the blade is not exposed when not in use.			1	3	3	None
Installation of Matting	Employees, Subcontractors. Injury to knee due to excessive kneeling.	3	2	6	- Operatives are required to take regular breaks when carrying out activities that require operatives to kneel for excessive period. - Operatives will wear knee pads to protect their knees. - Operatives will ensure they have the correct posture and do not over stretch when installing matting - Operatives will wear suitable safety footwear			1	2	2	None

Distribution of Matting	Employees, Subcontractors Risk of injury due to poor manual handling techniques	3	2	6	- Visual risk assessments to be carried out before any manual handling activities commence and to ensure there is adequate room available - Delivery vehicles to be positioned as close to the storage area as possible - Where possible, use mechanical aids i.e. pallet truck - Ensure materials are securely braced where required - Operatives to receive training on the correct Manual Handling techniques - Operatives are provided with information on the correct way to manually materials, tools etc. - Operatives will wear protective footwear and safety gloves	1	2	2	Team Leader to assess safe method of lifting before allowing any operations to commence, and to communicate the required actions to operatives
Vacuum or Sweeping Subfloor	Employees, Subcontractors, Other Trades. Ill health caused by inhalation of dust; protruding sharp objects i.e. nails, tripping hazards	3	3	9	- Vacuuming is preferential to sweeping as it extracts the dust. If vacuuming is not possible, the risk of creating airborne dust through sweeping can be reduced by damping the area first. - Operatives should use water sparingly to avoid any additional risk that this creates such as slippery floors and ensure controls are in place. - Visual risk assessments to be carried out before any vacuum / sweeping activities commence and to ensure it is safe to proceed - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - All operations that generate significant quantities of dust are undertaken in well-ventilated areas whenever possible. - All personnel wear disposable dust masks conforming to EN 149 FFP3 - Operatives will wear safety footwear and protective glasses	1	3	3	None

Applying adhesive to Subfloor	Employees, Subcontractors, Other Trades. Skin dermatitis to hands and arms, slip hazard	3	2	6	- Only trained and competent operatives are permitted to use adhesives - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - Operatives will refer to relevant COSHH Assessment prior to using adhesives - Operatives will wear protective gloves when using adhesives and barrier creams - Spillages will be cleaned away immediately	1	2	2	None
Disposal of Knife Blades	Employees, Subcontractors. Cuts to hands	3	3	9	- Only trained and competent operatives are permitted to use knives and change blades - Blades will be placed in a sealed container	1	3	3	None
Waste Disposal	Employees, Subcontractors. Ill health caused by inhalation of dust; fire, cuts to hands and arms	3	3	9	- All waste materials will be disposed of in the correct skips provided - Operatives will wear safety footwear and protective gloves when disposing of waste - Operatives will regularly dispose of waste ensuring quantities are kept to a minimum and are not stored next to any sources of heat - Where dusts are generated, operatives will wear disposable dust masks conforming to EN 149 FFP3	1	3	3	None
Using 110 Volt Equipment	Employees, Subcontractors. Risk of electrocution / electric shock	3	3	9	- Only trained and competent operatives undertake activities involving the use of 110v electrical equipment. - The equipment is used and maintained in accordance with the manufacturer's instructions and is inspected for obvious defects and not used. - All electrical equipment is electrically tested and inspected by a trained and competent person, on a quarterly basis. - Where a risk of developing Hand Arm Vibration exists, exposure should be evaluated and controls applied. - Eye protection, protective gloves and safety footwear is to be worn at all times when using electrical tools.	1	3	3	Operatives to visually check 110v equipment before use. Any defect equipment to be removed from site immediately. Operatives to ensure all electrical equipment is PAT tested on a 3 monthly basis.

RISK ASSESSMENT

FLOORING INSTALLATION

					Team Leaders to ensure electrical equipment is by operatives in accordance with their training.				
Slips, Trips & Falls	Employees, Subcontractors and Others working in the vicinity. Risk of tripping over objects, slipping on spillages or wet surfaces, or falling	3	2	6	- All equipment / materials are to be stored in a designated area - Operatives to ensure all waste materials are cleared away as soon as possible and disposed of in the skips provided. - Cables are not to be left trailing across walkways and should be visible. All cables will be suspended from above using sky hooks.	1	2	2	Team Leader to monitor working area to ensure there are no hazards
Using Hand Tools	Employees, Subcontractors. Injuries to hands	3	2	6	- All hand tools are inspected for obvious defects prior to use. Any equipment found to be defective is not to be used. - Only competent and trained operatives undertake activities that involve the use of hand tools. - Gloves are to be worn to protect hands against cuts and impact injuries.	1	2	2	None



RISK ASSESSMENT

FLOORING INSTALLATION

Activity		Persons At Risk			Assessor			Assessment No.
Manual Handling		Employees, Subcontractors, Other Trades						1
Health & Safety Director		Signature			Issue Date			Review Date
Mark Mulchinock					20/08/2026			12 Months
		Risk Level Without Control Measures			Waitrose Newport			Risk Level With Existing Control Measures
Hazards Identified	Persons At Risk	Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Control Measures			Further Action
Distribution of Material Around Site	Employees, Subcontractors Risk of injury due to poor manual handling techniques, crushing fingers	3	3	9	- Visual risk assessments to be carried out before any manual handling activities commence and to ensure there is adequate room available and all walkways are clear from obstructions - Delivery vehicles to be positioned as close to the storage area as possible - Where possible, use mechanical aids i.e. pallet truck, hoist, crane etc. Do not use "skates" to move rolls of carpet as this encourages bad grip & posture. - Ensure materials are securely braced where required - Operatives to receive training on the correct Manual Handling techniques - Operatives are provided with information on the correct way to manually materials, tools etc. - Operatives are only permitted to carry materials within their own capabilities - Operatives will wear protective footwear and safety gloves			Team Leader to assess safe method of lifting before allowing any operations to commence, and to communicate the required actions to operatives

RISK ASSESSMENT

FLOORING INSTALLATION

Distribution of Material Around Site	Employees, Subcontractors. Risk of tripping, stepping on sharp objects i.e. Nails	3	3	9	- Visual risk assessments to be carried out before any manual handling activities commence and to ensure there is adequate room available and all walkways are clear from obstructions - Operatives will wear protective footwear and safety gloves	1	3	3	None
Distribution of Material Around Site	Employees, Subcontractors. Object falling from scaffolding	3	3	9	- Operatives will wear protective footwear, hard hat and safety gloves - Operatives to remain vigilant when accessing site, in particular when walking underneath / below scaffolding - Operatives to report to Site Manager any areas where scaffolding is unprotected i.e. missing toeboards	1	3	3	None
Offloading Materials from Vehicles	Employees, Subcontractors. Objects falling from vehicle	3	2	6	- Operatives will wear protective footwear, hard hat and safety gloves - Delivery vehicles to be positioned as close to the storage area as possible - Where possible, use mechanical aids i.e. pallet truck, hoist, crane etc. - Operatives to receive training on the correct Manual Handling techniques - Operatives are provided with information on the correct way to manually materials, tools etc. - Operatives are only permitted to carry materials within their own capabilities	1	2	2	None
Offloading Materials from Vehicles	Employees, Subcontractors. Crush of feet by tail lift or pallet truck	3	2	6	- Operatives will wear protective footwear and safety gloves - Delivery vehicles to be positioned as close to the storage area as possible - Only trained and competent operatives are permitted to use pallet trucks - Operatives to ensure they are standing clear of the tail lift before it is lowered	1	2	2	None



RISK ASSESSMENT

FLOORING INSTALLATION

Activity		Persons At Risk			Assessor			Assessment No.
Latex Smoothing Compound Application		Employees, Subcontractors, Other Trades						1
Health & Safety Director		Signature			Issue Date			Review Date
Mark Mulchinock					20/08/2026			12 Months
		Risk Level Without Control Measures			Waitrose Newport			Risk Level With Existing Control Measures
Hazards Identified	Persons At Risk	Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Control Measures			Further Action
Distribution of Latex Units on Floor Area	Employees, Subcontractors Risk of injury due to poor manual handling techniques	3	2	6	- Visual risk assessments to be carried out before any manual handling activities commence and to ensure there is adequate room available - Delivery vehicles to be positioned as close to the storage area as possible - Where possible, use mechanical aids i.e. pallet truck - Ensure materials are securely braced where required - Operatives to receive training on the correct Manual Handling techniques - Operatives are provided with information on the correct way to manually materials, tools etc. - Operatives will wear protective footwear and safety gloves			Team Leader to assess safe method of lifting before allowing any operations to commence, and to communicate the required actions to operatives

Vacuum or Sweeping Subfloor	Employees, Subcontractors, Other Trades. Ill health caused by inhalation of dust; protruding sharp objects i.e. nails, tripping hazards	3	3	9	- Vacuuming is preferential to sweeping as it extracts the dust. If vacuuming is not possible, the risk of creating airborne dust through sweeping can be reduced by damping the area first. - Operatives should use water sparingly to avoid any additional risk that this creates such as slippery floors and ensure controls are in place. - Visual risk assessments to be carried out before any vacuum / sweeping activities commence and to ensure it is safe to proceed - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - All operations that generate significant quantities of dust are undertaken in well-ventilated areas whenever possible. - All personnel wear disposable dust masks conforming to EN 149 FFP3 - Operatives will wear safety footwear and protective glasses	1	3	3	None
Mixing of Smoothing Compound Units	Employees, Subcontractors, Other Trades. Burns to hands, irritation to eyes, irritation to nasal and respiratory system	3	3	9	- Only trained and competent operatives are permitted to use smoothing compounds - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access	1	3	3	None

					- Operatives will refer to relevant COSHH Assessment prior to using smoothing compounds - All operations will be carried out in well-ventilated areas. - All personnel wear disposable face masks conforming to EN 149 FFFP3. - Operatives will wear protective gloves when using smoothing compounds and barrier creams; they will also wear protective goggles - Spillages will be cleaned away immediately				
Carbide Grinding of Installed Latex	Employees, Subcontractors. Injury to knees and back due to excessive kneeling, bad posture, irritation to nasal and respiratory system	3	3	9	- Operatives are required to take regular breaks when carrying out activities that require operatives to kneel for excessive period. - Operatives will wear knee pads to protect their knees. - Operatives will ensure they have the correct posture and do not over stretch - Operatives will wear suitable safety footwear and disposable face masks conforming to EN 149 FFP3.	1	3	3	None
Waste Disposal	Employees, Subcontractors. Ill health caused by inhalation of dust; fire, cuts to hands and arms	3	3	9	- All waste materials will be disposed of in the correct skips provided - Operatives will wear safety footwear and protective gloves when disposing of waste - Operatives will regularly dispose of waste ensuring quantities are kept to a minimum and are not stored next to any sources of heat - Where dusts are generated, operatives will wear disposable dust masks conforming to EN 149 FFP3	1	3	3	None
Using 110 Volt Equipment	Employees, Subcontractors. Risk of electrocution / electric shock	3	3	9	- Only trained and competent operatives undertake activities involving the use of 110v electrical equipment. - The equipment is used and maintained in accordance with the manufacturer's instructions and is inspected for obvious defects and not used. - All electrical equipment is electrically tested and inspected by a trained and competent person, on a quarterly basis.	1	3	3	Operatives to visually check 110v equipment before use. Any defect equipment to be removed from site immediately. Operatives to ensure all electrical equipment is PAT tested on a 3 monthly basis.

					- Where a risk of developing Hand Arm Vibration exists, exposure should be evaluated and controls applied. - Eye protection, protective gloves and safety footwear is to be worn at all times when using electrical tools. - Team Leaders to ensure electrical equipment is by operatives in accordance with their training.				
Slips, Trips & Falls	Employees, Subcontractors and Others working in the vicinity. Risk of tripping over objects, slipping on spillages or wet surfaces, or falling	3	2	6	- All equipment / materials are to be stored in a designated area - Operatives to ensure all waste materials are cleared away as soon as possible and disposed of in the skips provided. - Cables are not to be left trailing across walkways and should be visible. All cables will be suspended from above using sky hooks.	1	2	2	Team Leader to monitor working area to ensure there are no hazards
Using Hand Tools	Employees, Subcontractors. Injuries to hands	3	2	6	- All hand tools are inspected for obvious defects prior to use. Any equipment found to be defective is not to be used. - Only competent and trained operatives undertake activities that involve the use of hand tools. - Gloves are to be worn to protect hands against cuts and impact injuries.	1	2	2	None

Activity			Persons At Risk			Assessor			Assessment No.		
Edge Trim Installation			Employees, Subcontractors, Other Trades						1		
Health & Safety Director			Signature			Issue Date			Review Date		
						20/08/2026			12 Months		
		Risk Level Without Control Measures			Waitrose Newport			Risk Level With Existing Control Measures			
Hazards Identified	Persons At Risk	Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Control Measures			Likelihood (1-3)	Severity (1-3)	Risk Level (1-9)	Further Action
Cutting Edge Trims	Employee, Subcontractors. Cuts to hands, arms, body.	3	3	9	- Only trained and competent operatives are authorised to use Jigsaw / hacksaws / bandsaws. - Operatives will carry out a visual inspection of the hacksaws / bandsaws prior to use - Operatives will wear protective gloves when using hacksaws / bandsaws to protect their hands. - Any hacksaws / bandsaws found to be defective are not to be used. - All bandsaws will be fitted with hand guards 110v Bandsaws will be PAT Tested every 3 months			1	3	3	None
Applying adhesive to Subfloor base	Employees, Subcontractors, Other Trades. Skin dermatitis to hands and arms, slip hazard, asphyxiation	3	3	9	- Only trained and competent operatives are permitted to use adhesives - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - Operatives will ensure the area is well-ventilated - Operatives will wear disposable face masks conforming to EN 149 FFP3 - Operatives will refer to relevant COSHH Assessment prior to using adhesives			1	3	3	None

					- Operatives will wear protective gloves when using adhesives and barrier creams - Spillages will be cleaned away immediately				
Applying adhesive to Stair Tread / Riser	Employees, Subcontractors, Other Trades. Skin dermatitis to hands and arms, slip hazard	3	3	9	- Only trained and competent operatives are permitted to use adhesives - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - Operatives will refer to relevant COSHH Assessment prior to using adhesives - Operatives will wear impervious protective gloves when using adhesives and barrier creams - Spillages will be cleaned away immediately	1	3	3	None
Applying adhesive to Edge Trim prior to Mechanical Fixing	Employees, Subcontractors, Other Trades. Skin dermatitis to hands and arms, slip hazard	3	3	9	- Only trained and competent operatives are permitted to use adhesives - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access - Operatives will refer to relevant COSHH Assessment prior to using adhesives - Operatives will wear impervious protective gloves when using adhesives and barrier creams - Spillages will be cleaned away immediately	1	3	3	None
Installation of Edge Trims	Employees, Subcontractors. Injury to knee due to excessive kneeling.	3	2	6	- Operatives are required to take regular breaks when carrying out activities that require operatives to kneel for excessive period. - Operatives will wear knee pads to protect their knees. - Operatives will ensure they have the correct posture and do not over stretch when installing edge trims - Operatives will wear suitable safety footwear	1	2	2	None

Distribution of Edge Trims on Floor Area	Employees, Subcontractors Risk of injury due to poor manual handling techniques	3	2	6	- Visual risk assessments to be carried out before any manual handling activities commence and to ensure there is adequate room available - Delivery vehicles to be positioned as close to the storage area as possible - Where possible, use mechanical aids i.e. pallet truck - Ensure materials are securely braced where required - Operatives to receive training on the correct Manual Handling techniques - Operatives are provided with information on the correct way to manually materials, tools etc. - Operatives will wear protective footwear and safety gloves	1	2	2	Team Leader to assess safe method of lifting before allowing any operations to commence, and to communicate the required actions to operatives
Mechanically Fixing Edge Trims	Employees, Subcontractors. Risk of electrocution / electric shock, general injury	3	3	9	- Only trained and competent operatives undertake activities involving the use of 110v drills - The equipment is used and maintained in accordance with the manufacturer's instructions and is inspected for obvious defects and not used. - All electrical equipment is electrically tested and inspected by a trained and competent person, on a quarterly basis. - Where a risk of developing Hand Arm Vibration exists, exposure should be evaluated and controls applied. - Eye protection, protective gloves and safety footwear is to be worn at all times when using electrical tools. - Team Leaders to ensure electrical equipment is by operatives in accordance with their training. - Operatives to ensure the correct drill bit size is used and any loose clothing and long hair to be tied back.	1	3	3	Operatives to visually check 110v equipment before use. Any defect equipment to be removed from site immediately. Operatives to ensure all electrical equipment is PAT tested on a 3 monthly basis.
Vacuum or Sweeping Subfloor	Employees, Subcontractors, Other Trades. Ill health caused by inhalation of dust; protruding sharp objects i.e. nails, tripping hazards	3	3	9	- Visual risk assessments to be carried out before any vacuum / sweeping activities commence and to ensure it is safe to proceed - Operatives will position barriers and warning notices to the access points to the area to prevent unauthorised access	1	3	3	None

					- All operations that generate significant quantities of dust are undertaken in well-ventilated areas whenever possible. - All personnel wear disposable dust masks conforming to EN 149 FFP3 - Operatives will wear safety footwear and protective glasses				
Waste Disposal	Employees, Subcontractors. Ill health caused by inhalation of dust; fire, cuts to hands and arms	3	3	9	- All waste materials will be disposed of in the correct skips provided - Operatives will wear safety footwear and protective gloves when disposing of waste - Operatives will regularly dispose of waste ensuring quantities are kept to a minimum and are not stored next to any sources of heat - Where dusts are generated, operatives will wear disposable dust masks conforming to EN 149 FFP3	1	3	3	None
Slips, Trips & Falls	Employees, Subcontractors and Others working in the vicinity. Risk of tripping over objects, slipping on spillages or wet surfaces, or falling	3	2	6	- All equipment / materials are to be stored in a designated area - Operatives to ensure all waste materials are cleared away as soon as possible and disposed of in the skips provided. - Cables are not to be left trailing across walkways and should be visible. All cables will be suspended from above using sky hooks.	1	2	2	Team Leader to monitor working area to ensure there are no hazards
Using Hand Tools	Employees, Subcontractors. Injuries to hands	3	2	6	- All hand tools are inspected for obvious defects prior to use. Any equipment found to be defective is not to be used. - Only competent and trained operatives undertake activities that involve the use of hand tools. - Gloves are to be worn to protect hands against cuts and impact injuries.	1	2	2	None

Substance Name	F.ball 1200 Pro Latex Screed
Site Name	Waitrose Newport
Supplied by	F.ball & Co Ltd
Assessed By	Amphthill Flooring Ltd

Location	Site Wide Latex Works
Task	Screed
Date	05/08/2026
Review date	05/08/2027

Quantity used		
1	less than 1kg	4
2	less than 10kg	
3	up to 50 kg	
4	up to 100 kg	
5	Over 100 kg	

Always follow the hierarchy of control measures	
1	Can the material/substance be eliminated?
2	Can you substitute the material/substance for something less hazardous?
3	Can engineered containment be applied?
4	Can the operator be isolated through control measures or engineering?
5	As a last resort use relevant personal protective equipment including RPE.

Exposure (time)		
1	Short Periods in Minutes or less than WEL	2
2	Up to 1 hour	
3	1-3 hours	
4	up to 5 hours	
5	All day or WEL exceeded for periods.	

Control Measures		
Score	Risk	Action
0-6	Low	No further action Needed follow basic hygiene measures. Review if change of use or Quantity
7-12	Low to Medium	Continue with existing control measures including hygiene.
13-18	Medium	Avoid prolonged exposure, do not swallow or ingest. Use rubber gloves when handling Use eye protection
19-24	Medium to High	Avoid prolonged exposure, Use rubber gloves when handling Use eye protection & consider RPE if dust or vapour Skin Contact - wash of with soap and water Eye contact - irrigate with water seek medical attention Inhalation - seek medical attention Ingestion - seek medical attention
25-30	High	Avoid prolonged exposure, do not swallow or ingest. Use rubber gloves and apron/chemical suit when handling Use eye protection - goggles or visor Use RPE Skin Contact - wash of with water seek medical attention Eye contact - irrigate with water seek medical attention Inhalation - seek medical attention Ingestion - seek medical attention
31-40	Avoid at All Costs	Evacuate area If exposed seek medical attention immediately Call emergency services

Physical properties		
1	Solid	2
2	Powder	
3	Liquid	
4	Vapour	
5	Gas	

Physio-Chemical properties		
1	Low	1
2	Flammable	
3	Oxidising or corrosive	
4	Highly Flammable	
5	Explosive	

Health Effects		
1	Low	15
5	Harmful	
10	Harmful Irritant/sensitising (toxic) - breathing/eyes	
15	Long term effects/ carcinogen/mutagen	
20	Very Toxic	

Total Score	Risk	24
--------------------	-------------	-----------

Follow guidance for a score of
As shown above

24



STOPGAP 1200 PRO

High Performance Smoothing Underlayment

Screed classification: CT-C16-F6 to EN 13813:2002



Scan to view the product demonstration video




PRODUCT DATA

INTRODUCTION

STOPGAP 1200 is a low odour, fast setting, fast drying, two component smoothing underlayment suitable for preparing sound internal subfloors prior to the installation of new floorcoverings.

STOPGAP 1200 is particularly suitable for use over old adhesive residues (including bitumen and carpet tile tackifiers) without the need for priming. STOPGAP 1200 can be used for patch filling timber floors prior to overlaying with plywood. It is suitable for use in clinical and biologically sensitive areas such as hospitals, laboratories, clean rooms etc.



STOPGAP 1200 mixed with STOPGAP 1200 Liquid has been tested in accordance with IMO 2010 FTPC Part 5 (IMO Res. MSC 307(88)) and Annex 2 item 2.2 and approved for use in marine application. STOPGAP 1200 can be applied to suitably prepared steel decks in light to medium-duty traffic areas. Note: STOPGAP 1200 is not to be used as an integrated part of a horizontal A-Class division. USCG approval No. 164.106/1 I21/WCL MED 0390.

STOPGAP 1200 is unaffected by moisture and is suitable for application over damp, clean, uneven concrete and sand/cement screeds, prior to application of STOPGAP waterproof surface membranes or STOPGAP ISOLATOR MEMBRANE.

STOPGAP 1200 is also suitable for use over a wide range of other subfloor types including STOPGAP waterproof surface membranes, sand/cement screed, concrete, granolithic, terrazzo, asphalt, steel, old vinyl asbestos tiles, epoxy and polyurethane resins, ceramic and quarry tiles.

COVERAGE

A 20kg bag of STOPGAP 1200 Powder mixed with 5.0 litres of STOPGAP 1200 Liquid will cover approximately 5.0m² at a thickness of 2 - 3mm.

TECHNICAL INFORMATION

EN 13813 Class Designation	CT-C16-F6
Working Time @ 20°C	15-20 minutes
Setting Time @ 20°C	60 minutes
At 3mm ready to receive most floorcoverings:	From 4 hours
Compressive Strength N/mm ² (EN 13892-2)	
1 Day	>6.0
7 Days	>10.0
28 Days	>16.0
Flexural Strength N/mm ² (EN 13892-2)	
1 Day	>2.0
7 Days	>4.0
28 Days	>6.0
Consumption per mm thickness	1.98 kg / m ²
Application thickness	Unfilled Filled
	2-10 mm Up to 30mm



FEATURES

- Suitable direct to adhesive residues, carpet tile tackifier and waterproof surface membranes, when applied from 2-10mm.
- Moisture tolerant - can be used under STOPGAP waterproof surface membranes
- Lay floorcoverings from 4 hours
- Can be filled up to 30mm
- Fast setting
- Protein Free
- Excellent self-smoothing properties

EN 13813:2002

The above standard refers to the properties and performance of the product and the specification to which it has been tested. The data shown confirms the minimum compressive and flexural strengths that the product will achieve.

PACKAGES

20kg lined paper sacks.
5 litre bottles.

HOW MUCH MATERIAL?

APPLIED THICKNESS	COVERAGE PER UNIT	CONSUMPTION PER 100m ² AREA	GRADED AGGREGATE
2-3mm	5.0m ²	20 units	n/a
5mm	2.5m ²	40 units	n/a
10mm	1.3m ²	79 units	n/a

Note. Coverage rates are based on 5.0 litre addition and will vary according to the condition of the subfloor.

SURFACE PREPARATION

Floor surfaces must be suitably prepared; sound, dry (<75%RH) and free from contaminants that may prevent adhesion. Use STYCCOCLEAN C140 for removing grease, oil, polish, soap etc. from non-absorbent substrates.

STOPGAP 1200 is moisture tolerant and can be applied direct to damp (>75% RH) concrete or sand/cement screed subfloors to pre-smooth prior to the application of STOPGAP waterproof surface membranes.

Concrete and sand/cement screeds must be fully cured and any laitance or surface treatments must be removed. The temperature of the floor must be maintained above 10°C throughout the application and drying of the underlayment. Underfloor heating must be off for at least 48 hours before, during and after application. Steel surfaces must be grit blasted to SA2½ or rotary disc/wire brushed to ST2, corrosion-free and clean. For detailed information, request the F. Ball Subfloor Preparation Guide.

PRIMING

Absorbent surfaces - Priming is not required.

Very absorbent surfaces can be primed with STOPGAP P131 diluted 1:4 with water to assist in preventing rapid drying, pin holing and to aid the flow and workability.

If using under a DPM onto damp concrete or sand/cement screeds, prime with STOPGAP P131 diluted 1:7 with water, prior to application.

Non-absorbent surfaces – Priming is not required.

Where underfloor heating is present or when laying direct to STOPGAP waterproof surface membranes laid longer than 24 hours prime with neat STOPGAP P131.

Primers should be used in accordance with instructions printed on the bottle and must be allowed to dry before applying the smoothing underlayment.

MIXING

Standard Mix - Add 5.0 litres of STOPGAP 1200 Liquid into a STOPGAP mixing bucket and gradually add all the powder whilst stirring with a power whisk fitted in an electric drill until a smooth creamy lump free consistency is achieved. The material should be mixed for a minimum of 2 minutes.

Filled Mix - Add 12.5kg of STOPGAP GRADED AGGREGATE to the prepared standard mix. It is advisable to reduce the level of liquid to 4.75 litres to prevent separation of the mix.

Mix only with STOPGAP 1200 Liquid.

APPLICATION

Pour the mixed material onto the prepared substrate and allow to flow and attain a smooth finish. Minimal work with a smoothing trowel is required. A spiked roller should be used to eliminate entrapped air and smooth out flow lines to give a more uniform surface appearance. The mixed material should be applied at a thickness between 2mm to 10mm unfilled or up to 30mm filled, but can be taken down to a feather edge if required. For optimum smoothing and levelling characteristics, an overall thickness of at least 3mm should be maintained.

STOPGAP 1200 is self-smoothing, but should any imperfections remain they can be removed by rubbing with a carborundum stone when the compound will accept foot traffic – typically 60 minutes after application at 20°C. This time will be extended with reduced temperature i.e. approximately 2 hours at 10°C.

DRYING

Drying is dependent on the absorbency of the subfloor, ambient temperature and humidity.

On all surfaces, at a nominal 2 - 5mm thickness, the compound will be ready to receive most floorcoverings from 4 hours. At an applied thickness of 6 - 10mm, most floorcoverings can be installed after 24 hours. For thicknesses greater than 10mm and up to 30mm, the drying time will be extended up to 7 - 14 days.

When used to pre-smooth prior to the application of a STOPGAP waterproof surface membrane the underlayment should be left for a minimum of 24 hours before proceeding.

PRECAUTIONS

If applying to asphalt, ensure a minimum application of 3mm and a maximum application of 6mm is used and is applied uniformly. Not suitable for use over adhesive residues beneath surface damp proof membranes or over water softenable adhesive residues - these residues must be fully removed.

TOOLS

Suitable steel smoothing trowel, spiked roller, mixing bucket, electric drill and power whisk.

Wash tools with water immediately after use.

STORAGE

This product must be stored under cover, in unopened bags clear of the ground in cool dry conditions, protected from frost and excessive draught. Dampness will reduce the shelf life and may cause the powder to set in the sack.

SHELF LIFE

Powder: 6 months in unopened bags and stored under good conditions.

Liquid: 12 months in unopened bottles.

HEALTH & SAFETY ADVICE

This product is classified. Obtain the relevant Safety Data Sheet and follow the advice given. These can be found at www.f-ball.co.uk. Alternatively they can be obtained from the point of purchase or from F. Ball and Co. Ltd. at the address below.

Site conditions vary, to ensure this product is suitable and to confirm this data sheet is current, please contact our Technical Service Department.

For further information about F. Ball products or more detailed technical assistance, please contact:



Churnetside Business Park
Station Road, Cheddleton, Leek
Staffordshire ST13 7RS
United Kingdom

Tel: +44 (0) 1538 361633
Fax: +44 (0) 1538 361622
Tech Services Fax: +44 (0) 1538 361567
Email: mail@f-ball.co.uk

www.f-ball.co.uk





SAFETY DATA SHEET STOPGAP 1200 PRO

SECTION 1: Identification of the substance/mixture and of the company/undertaking

1.1. Product identifier

Product name STOPGAP 1200 PRO
UFI UFI: UN40-60WQ-W00W-4301

1.2. Relevant identified uses of the substance or mixture and uses advised against

Identified uses Cementitious flooring product.
Uses advised against None

1.3. Details of the supplier of the safety data sheet

Supplier F.Ball and Co. Ltd.
Churnetside Business Park,
Station Road,
Cheddleton,
Leek,
Staffordshire. ST13 7RS
Tel: 01538 361633 Mon-Fri 8.30am-5.00pm (Exc Bank Holidays)
E.mail: msds@f-ball.co.uk

1.4. Emergency telephone number

Emergency telephone 01538 361633 Mon-Fri 8.30am - 5.00pm (excluding Bank Holidays)
National emergency telephone number UK - National Poisons Information Service Call 111
Ireland - National Poisons Information Centre Call +353 1 809 2166

SECTION 2: Hazards identification

2.1. Classification of the substance or mixture

Classification (EC 1272/2008)

Physical hazards Not Classified
Health hazards Eye Irrit. 2 - H319 Skin Sens. 1 - H317
Environmental hazards Not Classified

Human health The product contains less than 0.0002% (2ppm) soluble Chromium VI as a percentage of the total dry weight of cement providing the product is stored correctly as indicated in section 7, and used within the recommended shelf life for the product. Persons with a known sensitivity to Chromium VI would be advised not to use this product. When mixed with water or gauging liquid splashes may cause serious eye damage.

Environmental The product may affect the acidity (pH-factor) in water with risk of harmful effects to aquatic organisms.

Physicochemical When handled correctly, undamaged units represent no danger.

2.2. Label elements

STOPGAP 1200 PRO

Hazard pictograms



Signal word

Warning

Hazard statements

H319 Causes serious eye irritation.
H317 May cause an allergic skin reaction.

Precautionary statements

P280 Wear protective gloves/ protective clothing/ eye protection/ face protection.
P302+P352 IF ON SKIN: Wash with plenty of water.
P305+P351+P338 IF IN EYES: Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing.
P313 Get medical advice/ attention.
P501 Dispose of contents/ container in accordance with national regulations.

Contains

CEMENT

2.3. Other hazards

This product does not contain any substances classified as PBT or vPvB.

SECTION 3: Composition/information on ingredients

3.2. Mixtures

CEMENT		1-5%
CAS number: 65997-15-1		EC number: 266-043-4
Classification Skin Irrit. 2 - H315 Eye Dam. 1 - H318 Skin Sens. 1 - H317 STOT SE 3 - H335		

The full text for all hazard statements is displayed in Section 16.

SECTION 4: First aid measures

4.1. Description of first aid measures

General information

Remove affected person from source of contamination.

Inhalation

Move affected person to fresh air at once. Get medical attention if any discomfort continues.

Ingestion

Rinse mouth thoroughly with water. Give plenty of water to drink. Do not induce vomiting. Get medical attention if any discomfort continues.

Skin contact

Remove contaminated clothing. Rinse immediately with plenty of water. Get medical attention if any discomfort continues.

Eye contact

Rinse immediately with plenty of water. Continue to rinse for at least 15 minutes and get medical attention.

4.2. Most important symptoms and effects, both acute and delayed

General information

The severity of the symptoms described will vary dependent on the concentration and the length of exposure.

Inhalation

Irritation of nose, throat and airway.

Ingestion

May cause discomfort if swallowed.

STOPGAP 1200 PRO

Skin contact Prolonged skin contact may cause redness and irritation. May cause an allergic skin reaction.

Eye contact May cause severe eye irritation.

4.3. Indication of any immediate medical attention and special treatment needed

Notes for the doctor Treat symptomatically.

SECTION 5: Firefighting measures

5.1. Extinguishing media

Suitable extinguishing media The product is non-combustible.

5.2. Special hazards arising from the substance or mixture

Specific hazards Dust may form explosive mixture with air. No unusual fire or explosion hazards noted.

Hazardous combustion products Does not decompose when used and stored as recommended.

5.3. Advice for firefighters

Protective actions during firefighting No specific firefighting precautions known.

Special protective equipment for firefighters Wear chemical protective suit.

SECTION 6: Accidental release measures

6.1. Personal precautions, protective equipment and emergency procedures

Personal precautions Avoid inhalation of dust. Avoid contact with skin and eyes.

6.2. Environmental precautions

Environmental precautions Do not discharge into drains or watercourses or onto the ground.

6.3. Methods and material for containment and cleaning up

Methods for cleaning up Avoid generation and spreading of dust. Preferably remove spillage with a vacuum cleaner. Collect spillage in containers, seal securely and dispose of as low hazard waste.

6.4. Reference to other sections

Reference to other sections For personal protection, see Section 8. See Section 11 for additional information on health hazards. For waste disposal, see section 13.

SECTION 7: Handling and storage

7.1. Precautions for safe handling

Usage precautions Avoid handling which leads to dust formation. Good personal hygiene procedures should be implemented. Do not eat, drink or smoke when using the product.

7.2. Conditions for safe storage, including any incompatibilities

Storage precautions Store in tightly-closed, original container. Keep separate from food, feedstuffs, fertilisers and other sensitive material. Store in a dry place.

Storage class Miscellaneous hazardous material storage.

7.3. Specific end use(s)

Specific end use(s) The identified uses for this product are detailed in Section 1.2.

SECTION 8: Exposure controls/Personal protection

STOPGAP 1200 PRO

8.1. Control parameters

Occupational exposure limits

CEMENT

Long-term exposure limit (8-hour TWA): WEL 10 total dust ; 4 respirable dust mg/m³

Short-term exposure limit (15-minute): WEL

Occupational Exposure Limit Value (8-hour reference period) 1 (R) mg/m³

WEL = Workplace Exposure Limit.

8.2. Exposure controls

Protective equipment



Appropriate engineering controls

Provide adequate ventilation. Avoid inhalation of dust. Observe any occupational exposure limits for the product or ingredients.

Personal protection

Always check applicability with your supplier of protective equipment.

Eye/face protection

If there is a risk of splashing, wear chemical resistant goggles or visor approved to BS EN166.

Hand protection

Chemical-resistant, impervious gloves complying with an approved standard should be worn if a risk assessment indicates skin contact is possible. Break through times can vary depending on thickness, use and source. Change gloves regularly.

Other skin and body protection

Wear appropriate clothing to prevent repeated or prolonged skin contact. Wear apron or protective clothing in case of contact.

Hygiene measures

Provide eyewash station. Promptly remove any clothing that becomes wet or contaminated. Wash promptly if skin becomes contaminated.

Respiratory protection

Respiratory protection must be used if the airborne contamination exceeds the recommended occupational exposure limit. A half mask dust respirator approved to EN 149 : 2001 FFP2 is recommended. Ensure that the mask fits tightly to ensure an efficient seal.

Environmental exposure controls

Residues and empty containers should be taken care of as hazardous waste according to local and national provisions.

SECTION 9: Physical and chemical properties

9.1. Information on basic physical and chemical properties

Appearance	Dusty powder.
Colour	Grey.
Odour	Slight.
Odour threshold	Not determined.
pH	pH (concentrated solution): High alkaline pH when mixed with water.
Melting point	Not determined.
Initial boiling point and range	Not applicable.
Flash point	Not applicable.
Evaporation rate	Not applicable.
Evaporation factor	Not applicable.
Flammability (solid, gas)	Not determined.

STOPGAP 1200 PRO

Upper/lower flammability or explosive limits	Not determined.
Other flammability	Not determined.
Vapour pressure	Not applicable.
Vapour density	Not applicable.
Relative density	Variable, depends on packing effects and temperature
Bulk density	Not determined.
Solubility(ies)	Slightly soluble in water.
Partition coefficient	Not applicable.
Auto-ignition temperature	Not determined.
Decomposition Temperature	Not determined.
Viscosity	Not determined.
Explosive properties	Not determined.
Explosive under the influence of a flame	Not considered to be explosive.
Oxidising properties	Not applicable.
Comments	Information given is applicable to the product in its ready-to-use form.

9.2. Other information

Other information	None.
Refractive index	Not determined.
Particle size	Not determined.
Molecular weight	Not determined.
Volatility	Not applicable.
Saturation concentration	Not determined.
Critical temperature	Not determined.
Volatile organic compound	Not applicable.

SECTION 10: Stability and reactivity

10.1. Reactivity

Reactivity	There are no known reactivity hazards associated with this product.
------------	---

10.2. Chemical stability

Stability	Stable at normal ambient temperatures and when used as recommended.
-----------	---

10.3. Possibility of hazardous reactions

Possibility of hazardous reactions	Under normal conditions of storage and use, hazardous reactions will not occur.
------------------------------------	---

10.4. Conditions to avoid

Conditions to avoid	There are no known conditions that are likely to result in a hazardous situation.
---------------------	---

10.5. Incompatible materials

STOPGAP 1200 PRO

Materials to avoid No specific material or group of materials is likely to react with the product to produce a hazardous situation.

10.6. Hazardous decomposition products

Hazardous decomposition products Does not decompose when used and stored as recommended.

SECTION 11: Toxicological information

11.1. Information on toxicological effects

Toxicological effects No information available.

Acute toxicity - oral

Notes (oral LD₅₀) No specific test data are available.

Acute toxicity - dermal

Notes (dermal LD₅₀) No specific test data are available.

Acute toxicity - inhalation

Notes (inhalation LC₅₀) No specific test data are available.

Skin corrosion/irritation

Skin corrosion/irritation No information available.

Animal data

No specific test data are available.

Human skin model test

No specific test data are available.

Extreme pH

No specific test data are available.

Serious eye damage/irritation

Serious eye damage/irritation Irritation of eyes is assumed.

Respiratory sensitisation

Respiratory sensitisation No specific test data are available.

Skin sensitisation

Skin sensitisation No specific test data are available.

Germ cell mutagenicity

Genotoxicity - in vitro Does not contain any substances known to be mutagenic.

Genotoxicity - in vivo Does not contain any substances known to be mutagenic.

Carcinogenicity

Carcinogenicity Does not contain any substances known to be carcinogenic.

IARC carcinogenicity

Not listed.

Reproductive toxicity

Reproductive toxicity - fertility Does not contain any substances known to be toxic to reproduction.

Reproductive toxicity - development Does not contain any substances known to be toxic to reproduction.

Specific target organ toxicity - single exposure

STOT - single exposure Not classified as a specific target organ toxicant after a single exposure.

Specific target organ toxicity - repeated exposure

STOT - repeated exposure Not classified as a specific target organ toxicant after repeated exposure.

STOPGAP 1200 PRO

Aspiration hazard

Aspiration hazard Not relevant.

General information

No specific health hazards known.

Inhalation

Dust in high concentrations may irritate the respiratory system. The product may contain a small percentage of respirable crystalline silica. Prolonged exposure to dust may result in long term irreversible effects

Ingestion

Ingestion of small amounts is unlikely to cause a significant reaction. Larger doses may result in irritation to the gastro intestinal tract.

Skin contact

Prolonged or repeated contact with the powder or mixtures with water may cause burns and/or irritant contact dermatitis

Eye contact

May cause irritation, soreness and reddening of the eyes

Acute and chronic health hazards

No specific health hazards known.

Route of exposure

Skin and/or eye contact

Target organs

Eyes Skin

Medical symptoms

Irritation of eyes and mucous membranes. Allergic rash.

Medical considerations

Pre-existing eye problems. Skin disorders and allergies.

SECTION 12: Ecological information

Ecotoxicity

The product may affect the acidity (pH) of water which may have hazardous effects on aquatic organisms.

12.1. Toxicity

Toxicity

Not available

Acute aquatic toxicity

Acute toxicity - fish

Not determined

Acute toxicity - aquatic invertebrates

Not determined.

Acute toxicity - aquatic plants

Not determined.

Acute toxicity - microorganisms

Not determined.

Acute toxicity - terrestrial

Not determined.

Chronic aquatic toxicity

Chronic toxicity - fish early life stage

Not determined.

Short term toxicity - embryo and sac fry stages

Not determined.

Chronic toxicity - aquatic invertebrates

Not determined.

12.2. Persistence and degradability

Persistence and degradability

There are no data on the degradability of this product.

STOPGAP 1200 PRO

Phototransformation	Not determined.
Stability (hydrolysis)	Not determined.
Biodegradation	Not determined.
Biological oxygen demand	No specific test data are available.
Chemical oxygen demand	No specific test data are available.

12.3. Bioaccumulative potential

Bioaccumulative potential	No data available on bioaccumulation.
Partition coefficient	Not applicable.

12.4. Mobility in soil

Mobility	The product is non-volatile.
Adsorption/desorption coefficient	Not determined.
Henry's law constant	Not determined.
Surface tension	Not determined.

12.5. Results of PBT and vPvB assessment

Results of PBT and vPvB assessment	This substance is not classified as PBT or vPvB according to current EU criteria.
---	---

12.6. Other adverse effects

Other adverse effects	Not known.
------------------------------	------------

SECTION 13: Disposal considerations

13.1. Waste treatment methods

Disposal methods	Small quantities may be mixed with water, allowed to cure fully and disposed of as low hazard waste. Larger quantities should be disposed of as hazardous waste via a licensed waste operator.
-------------------------	--

SECTION 14: Transport information

General	The product is not covered by international regulations on the transport of dangerous goods (IMDG, IATA, ADR/RID).
----------------	--

14.1. UN number

14.2. UN proper shipping name

14.3. Transport hazard class(es)

Transport labels	No transport warning sign required.
-------------------------	-------------------------------------

14.4. Packing group

14.5. Environmental hazards

Environmentally hazardous substance/marine pollutant	No.
---	-----

14.6. Special precautions for user

14.7. Transport in bulk according to Annex II of MARPOL and the IBC Code

STOPGAP 1200 PRO

SECTION 15: Regulatory information

15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

National regulations	Control of Substances Hazardous to Health Regulations 2002 (as amended).
Guidance	Workplace Exposure Limits EH40. Safety Data Sheets for Substances and Preparations.
Health and environmental listings	None of the ingredients are listed.
Authorisations (Annex XIV Regulation 1907/2006)	No specific authorisations are known for this product.
Restrictions (Annex XVII Regulation 1907/2006)	No specific restrictions on use are known for this product.

15.2. Chemical safety assessment

No chemical safety assessment has been carried out.

SECTION 16: Other information

General information	F.Ball and Company Ltd Technical Datasheet.
Key literature references and sources for data	Health and Safety Executive Guidance Note EH40 (amended annually). Workplace Exposure Limits.
Revision comments	Section 1 Update
Revision date	27/04/2022
Revision	7
Supersedes date	07/01/2021
SDS status	Approved.
Hazard statements in full	H315 Causes skin irritation. H317 May cause an allergic skin reaction. H318 Causes serious eye damage. H319 Causes serious eye irritation. H335 May cause respiratory irritation.

This information relates only to the specific material designated and may not be valid for such material used in combination with any other materials or in any process. Such information is, to the best of the company's knowledge and belief, accurate and reliable as of the date indicated. However, no warranty, guarantee or representation is made to its accuracy, reliability or completeness. It is the user's responsibility to satisfy himself as to the suitability of such information for his own particular use.

Control of Substances Hazardous to Health Assessment

COSHH Assessment

Substance Name	F.Ball Styccobond F3 Adhesive
Site Name	Waitrose Newport
Supplied by	F.Ball & Co. Ltd
Assessed By	Ampthill Flooring Limited

Location	Site Wide Carpet/matting works
Task	Floor Finishes Adhesive
Date	23/02/2026
Review date	23/02/2027

Quantity used		
1	less than 1kg	3
2	less than 10kg	
3	up to 50 kg	
4	up to 100 kg	
5	Over 100 kg	

Always follow the hierarchy of control measures	
1	Can the material/substance be eliminated?
2	Can you substitute the material/substance for something less hazardous?
3	Can engineered containment be applied?
4	Can the operator be isolated through control measures or engineering?
5	As a last resort use relevant personal protective equipment including RPE.

Exposure (time)		
1	Short Periods in Minutes or less than WEL	3
2	Up to 1 hour	
3	1-3 hours	
4	up to 5 hours	
5	All day or WEL exceeded for periods.	

Control Measures		
Score	Risk	Action
0-6	Low	No further action Needed follow basic hygiene measures. Review if change of use or Quantity
7-12	Low to Medium	Continue with existing control measures including hygiene.
13-18	Medium	Avoid prolonged exposure, do not swallow or ingest. Use rubber gloves when handling Use eye protection
19-24	Medium to High	Avoid prolonged exposure, Use rubber gloves when handling Use eye protection & consider RPE if dust or vapour Skin Contact - wash of with soap and water Eye contact - irrigate with water seek medical attention Inhalation - seek medical attention Ingestion - seek medical attention
25-30	High	Avoid prolonged exposure, do not swallow or ingest. Use rubber gloves and apron/chemical suit when handling Use eye protection - goggles or visor Use RPE Skin Contact - wash of with water seek medical attention Eye contact - irrigate with water seek medical attention Inhalation - seek medical attention Ingestion - seek medical attention
31-40	Avoid at All Costs	Evacuate area If exposed seek medical attention immediately Call emergency services

Physical properties		
1	Solid	3
2	Powder	
3	Liquid	
4	Vapour	
5	Gas	

Physio-Chemical properties		
1	Low	1
2	Flammable	
3	Oxidising or corrosive	
4	Highly Flammable	
5	Explosive	

Health Effects		
1	Low	1
5	Harmful	
10	Harmful Irritant/sensitising (toxic) - breathing/eyes	
15	Long term effects/ carcinogen/mutagen	
20	Very Toxic	

Total Score	Risk	11
--------------------	-------------	-----------

Follow guidance for a score of As shown above	11
--	-----------



STYCCOBOND F3

Flooring Adhesive



Scan to view the product demonstration video



PRODUCT DATA

INTRODUCTION

STYCCOBOND F3 is a water based rubber/resin flooring adhesive that has excellent wet grab with an early build up of strength. It is protected against bio-degradation and is suitable for use over normal underfloor heating installations.

STYCCOBOND F3 can be used for securing fibre bonded carpets, hessian, felt, secondary latex and rubber foam backed carpets and cork tiles up to 3.2mm thick.

See the F. Ball Recommended Adhesives Guide for details of specific floorcoverings.



STYCCOBOND F3 has been tested to the standards of the International Maritime Organisation and approved for use in marine floor installations.

STYCCOBOND F3 can be applied to STOPGAP smoothing underlayments, structurally sound, smooth, dry subfloors of concrete and sand/cement screed, plywood, flooring grade chipboard and hardboard.

STOPGAP waterproof surface membranes, sound flooring grade asphalt and some non-absorbent surfaces must be skimmed with a minimum of 3mm of the appropriate STOPGAP smoothing underlayment.

STYCCOBOND F3 can be applied directly to some non-absorbent subfloors such as Power Floated Concrete, Terrazzo and Granolithic, however, impervious backed floorcoverings should not be adhered directly to these subfloors and a suitable STOPGAP smoothing underlayment should be applied.

For details on other subfloors, contact our Technical Service Department.



FEATURES

- High strength
- Good wet grab
- Suitable for the installation of most carpets
- Approved for marine use

STANDARDS

All aspects of the installation of floorcoverings should be in accordance with the requirements of the relevant British Standard Code of Practice i.e. BS 5325 (Installation of textile floorcoverings) and supplementary specifications.

PACKAGES

15 litre bucket
5 litre bucket
2.5 litre bucket
1 litre pot

TECHNICAL INFORMATION

Colour	Cream / Yellow
Consistency	Viscous Liquid
Coverage Rate (Approx.)	3m ² per litre using a 2mm x 6mm trowel
Open Time	Up to 15 minutes depending on temperature, humidity and absorbency of the subfloor

HOW MUCH MATERIAL?

PACK SIZE	TROWEL SIZE	COVERAGE PER UNIT
15 litres	2mm x 6mm	45m ²
5 litres	2mm x 6mm	15m ²
2.5 litres	2mm x 6mm	7.5m ²
1 litre	2mm x 6mm	3m ²

Note: Coverage rates will depend on the condition and absorbency of the subfloor.

SURFACE PREPARATION

Proper subfloor preparation is essential for the correct installation of any floorcovering. Subfloors must be structurally sound, smooth, dry (<75% RH) and free from laitance and any contaminants which will affect adhesion. Use STYCCOCLEAN C140 for removing grease, oil, polish, soap etc. from non-absorbent substrates.

Concrete and sand/cement screeds must be fully cured and any laitance or surface treatments must be removed. The temperature of the floor must be maintained above 10°C throughout the application and drying of the adhesive. Underfloor heating must be off for at least 48 hours before, during and after application.

For detailed information, request the F. Ball Subfloor Preparation Guide.

DAMP SUBFLOORS

The Relative Humidity (RH) of the subfloor can be measured using the F. Ball Digital Hygrometer. Where the RH value is greater than 75% the appropriate STOPGAP Waterproof Surface Membrane should be applied.

SMOOTHING

To ensure a level surface on which to adhere to, uneven and irregular surfaces should be suitably prepared using the appropriate STOPGAP smoothing underlayments.

PRIMING

Highly absorbent subfloors such as sand/cement screeds and plywood etc. may cause rapid drying of the adhesive, thus reducing the open time. Use STOPGAP P131 diluted 4 parts of water and stir until thoroughly dispersed. This should be allowed to dry thoroughly before proceeding with the installation.

Dry and suitably prepared calcium sulphate screeds e.g. anhydrite must be primed with neat STOPGAP P121.

ADHESIVE APPLICATION

Holding the trowel at an angle of 60°, spread the adhesive evenly over an area of subfloor that can be covered whilst the adhesive remains receptive and gives good transfer.

Absorbent surfaces - lay the floorcovering immediately, except with cork tiles.

Installing cork tiles and onto surfaces with little or no absorbency - allow the adhesive to dry partially to a paste-like consistency before laying the floorcovering.

Deeply profiled or rough backed floorcoverings - it may be necessary to apply extra adhesive to ensure good contact. In such cases use a 3mm x 6mm 'V' notched trowel, this will reduce the coverage quoted. Some unitary backed carpets also require the large notched trowel.

Following the floorcovering manufacturer's laying instructions lay the floorcovering into the adhesive and press from the centre outwards to exclude air and ensure overall contact with the adhesive. Roll with the 68kg flooring roller, from end-to-end and side-to-side (on foam backed floorcoverings use the STYCCOBOND GLYDA) to ensure overall contact. 30 minutes later and when the floor has been completely covered roll or use the STYCCOBOND GLYDA as necessary to ensure overall contact is maintained.

PRECAUTIONS

Do not apply loads or move furniture on the floorcovering until the adhesive has fully set. Do not allow the floorcovering to be wet cleaned until three weeks after laying.

TOOLS

STYCCOBOND 2mm x 6mm or 3mm x 6mm 'V' notched trowel, F. Ball 68kg flooring roller, F. Ball STYCCOBOND GLYDA for foam backed carpets and Trimming knife.

Tools should be cleaned with warm soapy water while the adhesive is still wet.

STORAGE

Store between 5°C and 30°C. Protect from frost.

SHELF LIFE

12 months in unopened containers stored under good conditions.

HEALTH AND SAFETY ADVICE

This product is not classified. A Safety Data Sheet is available for the professional user on request.

These can be found at www.f-ball.co.uk alternatively these can be obtained from the point of purchase or from F. Ball and Co. Ltd. at the address below.

Site conditions vary, to ensure this product is suitable and to confirm this data sheet is current please contact our Technical Service Department.

For further information about F. Ball products or more detailed technical assistance, please contact:



Churnetside Business Park
Station Road, Cheddleton, Leek
Staffordshire ST13 7RS
United Kingdom

Tel: +44 (0) 1538 361633
Fax: +44 (0) 1538 361622
Tech Services Fax: +44 (0) 1538 361567
Email: mail@f-ball.co.uk

www.f-ball.co.uk





SAFETY DATA SHEET STYCCOBOND F3

SECTION 1: Identification of the substance/mixture and of the company/undertaking

1.1. Product identifier

Product name STYCCOBOND F3

1.2. Relevant identified uses of the substance or mixture and uses advised against

Identified uses Flooring Adhesive

Uses advised against No specific uses advised against are identified.

1.3. Details of the supplier of the safety data sheet

Supplier F.Ball and Co. Ltd.
Churnetside Business Park,
Station Road,
Cheddleton,
Leek,
Staffordshire. ST13 7RS
Tel: 01538 361633 Mon-Fri 8.30am-5.00pm (Exc Bank Holidays)
E.mail: msds@f-ball.co.uk

1.4. Emergency telephone number

Emergency telephone 01538 361633 Mon-Fri 8.30am - 5.00pm (excluding Bank Holidays)

SECTION 2: Hazards identification

2.1. Classification of the substance or mixture

Classification (EC 1272/2008)

Physical hazards Not Classified

Health hazards Not Classified

Environmental hazards Not Classified

2.2. Label elements

Hazard statements EUH208 Contains 1,2-BENZISOTHIAZOL-3(2H)-ONE. May produce an allergic reaction.

2.3. Other hazards

SECTION 3: Composition/information on ingredients

3.2. Mixtures

Composition comments No classified ingredients, or those having occupational exposure limits, present above the levels of disclosure.

SECTION 4: First aid measures

4.1. Description of first aid measures

General information Treat symptomatically.

Inhalation No specific recommendations.

STYCCOBOND F3

Ingestion	Rinse mouth thoroughly with water. Give plenty of water to drink. Do not induce vomiting. Get medical attention if any discomfort continues.
Skin contact	Wash skin thoroughly with soap and water. Remove contaminated clothing. Get medical attention if irritation persists after washing.
Eye contact	Rinse immediately with plenty of water. Continue to rinse for at least 15 minutes. Get medical attention if any discomfort continues.

4.2. Most important symptoms and effects, both acute and delayed

General information	The product is considered to be a low hazard under normal conditions of use.
Inhalation	No specific symptoms known.
Ingestion	No specific symptoms known.
Skin contact	May cause sensitisation or allergic reactions in sensitive individuals.
Eye contact	May cause temporary eye irritation.

4.3. Indication of any immediate medical attention and special treatment needed

Notes for the doctor	Treat symptomatically.
-----------------------------	------------------------

SECTION 5: Firefighting measures

5.1. Extinguishing media

Suitable extinguishing media	The product is not flammable. Use fire-extinguishing media suitable for the surrounding fire.
-------------------------------------	---

5.2. Special hazards arising from the substance or mixture

Specific hazards	None known.
Hazardous combustion products	Does not decompose when used and stored as recommended.

5.3. Advice for firefighters

Protective actions during firefighting	No specific firefighting precautions known.
Special protective equipment for firefighters	Wear chemical protective suit.

SECTION 6: Accidental release measures

6.1. Personal precautions, protective equipment and emergency procedures

Personal precautions	Wear protective gloves, eye and face protection.
-----------------------------	--

6.2. Environmental precautions

Environmental precautions	Do not discharge into drains or watercourses or onto the ground.
----------------------------------	--

6.3. Methods and material for containment and cleaning up

Methods for cleaning up	Contain and absorb spillage with sand, earth or other non-combustible material. Collect and place in suitable waste disposal containers and seal securely.
--------------------------------	--

6.4. Reference to other sections

Reference to other sections	For personal protection, see Section 8. See Section 11 for additional information on health hazards. Collect and dispose of spillage as indicated in Section 13.
------------------------------------	--

SECTION 7: Handling and storage

7.1. Precautions for safe handling

STYCCOBOND F3

Usage precautions Provide adequate ventilation. Good personal hygiene procedures should be implemented.

Advice on general occupational hygiene Wash at the end of each work shift and before eating, smoking and using the toilet.

7.2. Conditions for safe storage, including any incompatibilities

Storage precautions Protect from freezing and direct sunlight. Keep away from food, drink and animal feeding stuffs. Store in tightly-closed, original container.

7.3. Specific end use(s)

Specific end use(s) The identified uses for this product are detailed in Section 1.2.

SECTION 8: Exposure controls/Personal protection

8.1. Control parameters

8.2. Exposure controls

Protective equipment



Appropriate engineering controls Provide adequate ventilation.

Eye/face protection Eyewear complying with an approved standard should be worn if a risk assessment indicates eye contact is possible.

Hand protection Chemical-resistant, impervious gloves complying with an approved standard should be worn if a risk assessment indicates skin contact is possible.

Other skin and body protection No specific requirements are anticipated under normal conditions of use.

Hygiene measures Provide eyewash station. No specific hygiene procedures recommended but good personal hygiene practices should always be observed when working with chemical products.

Respiratory protection No specific recommendations.

SECTION 9: Physical and chemical properties

9.1. Information on basic physical and chemical properties

Appearance	Viscous liquid.
Colour	Cream.
Odour	Slight.
Odour threshold	Not determined.
pH	pH (concentrated solution): 8.5 - 9.5
Melting point	Not applicable.
Initial boiling point and range	Not determined.
Flash point	Not applicable.
Evaporation rate	Not determined.
Evaporation factor	Not determined.
Flammability (solid, gas)	Not applicable.

STYCCOBOND F3

Upper/lower flammability or explosive limits	Not applicable.
Other flammability	Not applicable.
Vapour pressure	Not determined.
Vapour density	Not determined.
Relative density	1.24 @ 20°C
Bulk density	Not determined.
Solubility(ies)	Soluble in water.
Partition coefficient	Not applicable.
Auto-ignition temperature	Not applicable.
Decomposition Temperature	Not determined.
Viscosity	600 - 800 P @ 20°C
Explosive properties	Not applicable.
Explosive under the influence of a flame	Not considered to be explosive.
Oxidising properties	Not applicable.
Comments	Information given is applicable to the product in its ready-to-use form.

9.2. Other information

Other information	None.
Refractive index	Not available.
Particle size	Not applicable.
Molecular weight	Not determined.
Volatility	Not determined.
Saturation concentration	Not determined.
Critical temperature	Not determined.
Volatile organic compound	Not determined.

SECTION 10: Stability and reactivity

10.1. Reactivity

Reactivity	There are no known reactivity hazards associated with this product.
------------	---

10.2. Chemical stability

Stability	Stable at normal ambient temperatures and when used as recommended.
-----------	---

10.3. Possibility of hazardous reactions

Possibility of hazardous reactions	No specific material or group of materials is likely to react with the product to produce a hazardous situation.
------------------------------------	--

10.4. Conditions to avoid

Conditions to avoid	Avoid freezing. Avoid exposure to high temperatures or direct sunlight.
---------------------	---

10.5. Incompatible materials

STYCCOBOND F3

Materials to avoid No specific material or group of materials is likely to react with the product to produce a hazardous situation.

10.6. Hazardous decomposition products

Hazardous decomposition products Does not decompose when used and stored as recommended.

SECTION 11: Toxicological information

11.1. Information on toxicological effects

Toxicological effects No information available.

Acute toxicity - oral

Notes (oral LD₅₀) No specific test data are available.

Acute toxicity - dermal

Notes (dermal LD₅₀) No specific test data are available.

Acute toxicity - inhalation

Notes (inhalation LC₅₀) No specific test data are available.

Skin corrosion/irritation

Skin corrosion/irritation No information available.

Animal data

No specific test data are available.

Human skin model test

No specific test data are available.

Extreme pH

No specific test data are available.

Serious eye damage/irritation

Serious eye damage/irritation No specific test data are available.

Respiratory sensitisation

Respiratory sensitisation No specific test data are available.

Skin sensitisation

Skin sensitisation No specific test data are available.

Germ cell mutagenicity

Genotoxicity - in vitro Not determined.

Genotoxicity - in vivo Not determined.

Carcinogenicity

Carcinogenicity Does not contain any substances known to be carcinogenic.

Target organ for carcinogenicity

Not relevant.

IARC carcinogenicity

Not listed.

Reproductive toxicity

Reproductive toxicity - fertility Does not contain any substances known to be toxic to reproduction.

Reproductive toxicity - development

Does not contain any substances known to be toxic to reproduction.

Specific target organ toxicity - single exposure

STOT - single exposure Not applicable.

STYCCOBOND F3

Target organs Not relevant.

Specific target organ toxicity - repeated exposure

STOT - repeated exposure Not applicable.

Target organs Not relevant.

Aspiration hazard

Aspiration hazard Not relevant.

General information No specific health hazards known.

Inhalation The product is considered to be a low hazard under normal conditions of use.

Ingestion No harmful effects expected from quantities likely to be ingested by accident.

Skin contact Skin irritation should not occur when used as recommended.

Eye contact May cause discomfort.

Acute and chronic health hazards No specific health hazards known.

Medical symptoms No specific symptoms known.

Medical considerations No information available.

SECTION 12: Ecological information

Ecotoxicity There are no data on the ecotoxicity of this product.

12.1. Toxicity

Toxicity Not considered toxic to fish.

Acute aquatic toxicity

Acute toxicity - fish No specific test data are available.

Acute toxicity - aquatic invertebrates Not determined.

Acute toxicity - aquatic plants Not determined.

Acute toxicity - microorganisms Not determined.

Acute toxicity - terrestrial Not determined.

Chronic aquatic toxicity

Chronic toxicity - fish early life stage Not determined.

Short term toxicity - embryo and sac fry stages Not determined.

Chronic toxicity - aquatic invertebrates Not determined.

12.2. Persistence and degradability

Persistence and degradability There are no data on the degradability of this product.

Phototransformation Not determined.

STYCCOBOND F3

Stability (hydrolysis)	Not determined.
Biodegradation	Not determined.
Biological oxygen demand	No specific test data are available.
Chemical oxygen demand	No specific test data are available.

12.3. Bioaccumulative potential

Bioaccumulative potential	No data available on bioaccumulation.
Partition coefficient	Not applicable.

12.4. Mobility in soil

Mobility	The product is non-volatile.
Adsorption/desorption coefficient	Not determined.
Henry's law constant	Not determined.
Surface tension	Not determined.

12.5. Results of PBT and vPvB assessment

Results of PBT and vPvB assessment	This substance is not classified as PBT or vPvB according to current EU criteria.
---	---

12.6. Other adverse effects

Other adverse effects	None known.
------------------------------	-------------

SECTION 13: Disposal considerations

13.1. Waste treatment methods

Disposal methods	Collect and place in suitable waste disposal containers and seal securely. Dispose of waste product or used containers in accordance with local regulations
-------------------------	---

SECTION 14: Transport information

General	The product is not covered by international regulations on the transport of dangerous goods (IMDG, IATA, ADR/RID).
----------------	--

14.1. UN number

Not applicable.

14.2. UN proper shipping name

Not applicable.

14.3. Transport hazard class(es)

No transport warning sign required.

14.4. Packing group

Not applicable.

14.5. Environmental hazards

Environmentally hazardous substance/marine pollutant	No.
---	-----

14.6. Special precautions for user

STYCCOBOND F3

Not applicable.

14.7. Transport in bulk according to Annex II of MARPOL and the IBC Code

Transport in bulk according to Not applicable.

Annex II of MARPOL 73/78
and the IBC Code

SECTION 15: Regulatory information

15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

National regulations The Control of Substances Hazardous to Health Regulations 2002 (SI 2002 No. 2677) (as amended).

Guidance Workplace Exposure Limits EH40.
Safety Data Sheets for Substances and Preparations.

Authorisations (Annex XIV Regulation 1907/2006) No specific authorisations are known for this product.

Restrictions (Annex XVII Regulation 1907/2006) No specific restrictions on use are known for this product.

15.2. Chemical safety assessment

No chemical safety assessment has been carried out.

SECTION 16: Other information

Abbreviations and acronyms used in the safety data sheet ATE: Acute Toxicity Estimate.
PBT: Persistent, Bioaccumulative and Toxic substance.
vPvB: Very Persistent and Very Bioaccumulative.

General information F.Ball and Company Ltd Technical Datasheet.

Revision comments Section 9: update.

Revision date 02/02/2022

Revision 20

Supersedes date 24/11/2020

SDS status Approved.

Hazard statements in full EUH208 Contains 1,2-BENZISOTHIAZOL-3(2H)-ONE. May produce an allergic reaction.

This information relates only to the specific material designated and may not be valid for such material used in combination with any other materials or in any process. Such information is, to the best of the company's knowledge and belief, accurate and reliable as of the date indicated. However, no warranty, guarantee or representation is made to its accuracy, reliability or completeness. It is the user's responsibility to satisfy himself as to the suitability of such information for his own particular use.

Control of Substances Hazardous to Health Assessment

COSHH Assessment

Substance Name	F.Ball F46 Acrylic Adhesive
Site Name	Waitrose Newport
Supplied by	F.Ball & Co. Ltd
Assessed By	Amphill Flooring Ltd

Location	Site Wide vinyl works
Task	Pressure Sensitive Vinyl Adhesive
Date	30/04/2026
Review date	30/04/2027

Quantity used		
1	less than 1kg	4
2	less than 10kg	
3	up to 50 kg	
4	up to 100 kg	
5	Over 100 kg	

Always follow the hierarchy of control measures	
1	Can the material/substance be eliminated?
2	Can you substitute the material/substance for something less hazardous?
3	Can engineered containment be applied?
4	Can the operator be isolated through control measures or engineering?
5	As a last resort use relevant personal protective equipment including RPE.

Exposure (time)		
1	Short Periods in Minutes or less than WEL	3
2	Up to 1 hour	
3	1-3 hours	
4	up to 5 hours	
5	All day or WEL exceeded for periods.	

Control Measures		
Score	Risk	Action
0-6	Low	No further action Needed follow basic hygiene measures. Review if change of use or Quantity
7-12	Low to Medium	Continue with existing control measures including hygiene.
13-18	Medium	Avoid prolonged exposure, do not swallow or ingest. Use rubber gloves when handling Use eye protection
19-24	Medium to High	Avoid prolonged exposure, Use rubber gloves when handling Use eye protection & consider RPE if dust or vapour Skin Contact - wash of with soap and water Eye contact - irrigate with water seek medical attention Inhalation - seek medical attention Ingestion - seek medical attention
25-30	High	Avoid prolonged exposure, do not swallow or ingest. Use rubber gloves and apron/chemical suit when handling Use eye protection - goggles or visor Use RPE Skin Contact - wash of with water seek medical attention Eye contact - irrigate with water seek medical attention Inhalation - seek medical attention Ingestion - seek medical attention
31-40	Avoid at All Costs	Evacuate area If exposed seek medical attention immediately Call emergency services

Physical properties		
1	Solid	3
2	Powder	
3	Liquid	
4	Vapour	
5	Gas	

Physio-Chemical properties		
1	Low	1
2	Flammable	
3	Oxidising or corrosive	
4	Highly Flammable	
5	Explosive	

Health Effects		
1	Low	10
5	Harmful	
10	Harmful Irritant/sensitising (toxic) - breathing/eyes	
15	Long term effects/ carcinogen/mutagen	
20	Very Toxic	

Total Score	Risk	21
--------------------	-------------	-----------

Follow guidance for a score of As shown above	21
--	-----------



SAFETY DATA SHEET STYCCOBOND F46

SECTION 1: Identification of the substance/mixture and of the company/undertaking

1.1. Product identifier

Product name STYCCOBOND F46

Internal identification SBF46/17

1.2. Relevant identified uses of the substance or mixture and uses advised against

Identified uses Flooring Adhesive

Uses advised against No specific uses advised against are identified.

1.3. Details of the supplier of the safety data sheet

Supplier F.Ball and Co. Ltd.
Churnetside Business Park,
Station Road,
Cheddleton,
Leek,
Staffordshire. ST13 7RS
Tel: 01538 361633 Mon-Fri 8.30am-5.00pm (Exc Bank Holidays)
E.mail: msds@f-ball.co.uk

1.4. Emergency telephone number

Emergency telephone 01538 361633 Mon-Fri 8.30am - 5.00pm (excluding Bank Holidays)

SECTION 2: Hazards identification

2.1. Classification of the substance or mixture

Classification (EC 1272/2008)

Physical hazards Not Classified

Health hazards Not Classified

Environmental hazards Not Classified

2.2. Label elements

Hazard statements EUH208 Contains 1,2-BENZISOTHIAZOL-3(2H)-ONE, 5-CHLORO-2-METHYL-2H-ISOTHIAZOL-3-ONE AND 2-METHYL-2H-ISOTHIAZOL-3-ONE. May produce an allergic reaction.

2.3. Other hazards

SECTION 3: Composition/information on ingredients

3.2. Mixtures

Composition comments No classified ingredients, or those having occupational exposure limits, present above the levels of disclosure.

SECTION 4: First aid measures

4.1. Description of first aid measures

STYCCOBOND F46

General information	Treat symptomatically.
Inhalation	No specific recommendations.
Ingestion	Rinse mouth thoroughly with water. Give plenty of water to drink. Do not induce vomiting. Get medical attention if any discomfort continues.
Skin contact	Wash skin thoroughly with soap and water. Remove contaminated clothing. Get medical attention if irritation persists after washing.
Eye contact	Rinse immediately with plenty of water. Continue to rinse for at least 15 minutes. Get medical attention if any discomfort continues.

4.2. Most important symptoms and effects, both acute and delayed

General information	The product is considered to be a low hazard under normal conditions of use.
Inhalation	No specific symptoms known.
Ingestion	No specific symptoms known.
Skin contact	May cause sensitisation or allergic reactions in sensitive individuals.
Eye contact	May cause temporary eye irritation.

4.3. Indication of any immediate medical attention and special treatment needed

Notes for the doctor	Treat symptomatically.
-----------------------------	------------------------

SECTION 5: Firefighting measures

5.1. Extinguishing media

Suitable extinguishing media	The product is not flammable. Use fire-extinguishing media suitable for the surrounding fire.
-------------------------------------	---

5.2. Special hazards arising from the substance or mixture

Specific hazards	None known.
Hazardous combustion products	Does not decompose when used and stored as recommended.

5.3. Advice for firefighters

Protective actions during firefighting	No specific firefighting precautions known.
---	---

Special protective equipment for firefighters	Wear chemical protective suit.
--	--------------------------------

SECTION 6: Accidental release measures

6.1. Personal precautions, protective equipment and emergency procedures

Personal precautions	Wear protective gloves, eye and face protection.
-----------------------------	--

6.2. Environmental precautions

Environmental precautions	Do not discharge into drains or watercourses or onto the ground.
----------------------------------	--

6.3. Methods and material for containment and cleaning up

Methods for cleaning up	Contain and absorb spillage with sand, earth or other non-combustible material. Collect and place in suitable waste disposal containers and seal securely.
--------------------------------	--

6.4. Reference to other sections

Reference to other sections	For personal protection, see Section 8. See Section 11 for additional information on health hazards. Collect and dispose of spillage as indicated in Section 13.
------------------------------------	--

STYCCOBOND F46

SECTION 7: Handling and storage

7.1. Precautions for safe handling

Usage precautions	Provide adequate ventilation. Good personal hygiene procedures should be implemented.
Advice on general occupational hygiene	Wash at the end of each work shift and before eating, smoking and using the toilet.

7.2. Conditions for safe storage, including any incompatibilities

Storage precautions	Protect from freezing and direct sunlight. Keep away from food, drink and animal feeding stuffs. Store in tightly-closed, original container.
----------------------------	---

7.3. Specific end use(s)

Specific end use(s)	The identified uses for this product are detailed in Section 1.2.
----------------------------	---

SECTION 8: Exposure controls/Personal protection

8.1. Control parameters

8.2. Exposure controls

Protective equipment



Appropriate engineering controls	Provide adequate ventilation.
Eye/face protection	Eyewear complying with an approved standard should be worn if a risk assessment indicates eye contact is possible.
Hand protection	Chemical-resistant, impervious gloves complying with an approved standard should be worn if a risk assessment indicates skin contact is possible.
Other skin and body protection	No specific requirements are anticipated under normal conditions of use.
Hygiene measures	Provide eyewash station. No specific hygiene procedures recommended but good personal hygiene practices should always be observed when working with chemical products.
Respiratory protection	No specific recommendations.

SECTION 9: Physical and chemical properties

9.1. Information on basic physical and chemical properties

Appearance	Viscous liquid. Emulsion.
Colour	White.
Odour	Characteristic.
Odour threshold	Not determined.
pH	pH (concentrated solution): 4-6 approx
Melting point	Not applicable.
Initial boiling point and range	Not determined.
Flash point	Not applicable.
Evaporation rate	Not determined.

STYCCOBOND F46

Evaporation factor	Not determined.
Flammability (solid, gas)	Not applicable.
Upper/lower flammability or explosive limits	Not applicable.
Other flammability	Not applicable.
Vapour pressure	Not determined.
Vapour density	Not determined.
Relative density	1.00 approx @ 20°C
Bulk density	Not determined.
Solubility(ies)	Soluble in water.
Partition coefficient	Not applicable.
Auto-ignition temperature	Not applicable.
Decomposition Temperature	Not determined.
Viscosity	30000-50000 cP @ 20°C
Explosive properties	Not applicable.
Explosive under the influence of a flame	Not considered to be explosive.
Oxidising properties	Not applicable.
Comments	Information given is applicable to the product in its ready-to-use form.

9.2. Other information

Other information	None.
Refractive index	Not available.
Particle size	Not applicable.
Molecular weight	Not determined.
Volatility	40% w/w approx (water)
Saturation concentration	Not determined.
Critical temperature	Not determined.
Volatile organic compound	Not applicable.

SECTION 10: Stability and reactivity

10.1. Reactivity

Reactivity	There are no known reactivity hazards associated with this product.
------------	---

10.2. Chemical stability

Stability	Stable at normal ambient temperatures and when used as recommended.
-----------	---

10.3. Possibility of hazardous reactions

Possibility of hazardous reactions	No specific material or group of materials is likely to react with the product to produce a hazardous situation.
------------------------------------	--

10.4. Conditions to avoid

STYCCOBOND F46

Conditions to avoid Avoid freezing. Avoid exposure to high temperatures or direct sunlight.

10.5. Incompatible materials

Materials to avoid No specific material or group of materials is likely to react with the product to produce a hazardous situation.

10.6. Hazardous decomposition products

Hazardous decomposition products Does not decompose when used and stored as recommended.

SECTION 11: Toxicological information

11.1. Information on toxicological effects

Toxicological effects No information available.

Acute toxicity - oral

Notes (oral LD₅₀) No specific test data are available.

Acute toxicity - dermal

Notes (dermal LD₅₀) No specific test data are available.

Acute toxicity - inhalation

Notes (inhalation LC₅₀) No specific test data are available.

Skin corrosion/irritation

Skin corrosion/irritation No information available.

Animal data No specific test data are available.

Human skin model test No specific test data are available.

Extreme pH No specific test data are available.

Serious eye damage/irritation

Serious eye damage/irritation No specific test data are available.

Respiratory sensitisation

Respiratory sensitisation No specific test data are available.

Skin sensitisation

Skin sensitisation No specific test data are available.

Germ cell mutagenicity

Genotoxicity - in vitro Not determined.

Genotoxicity - in vivo Not determined.

Carcinogenicity

Carcinogenicity Does not contain any substances known to be carcinogenic.

Target organ for carcinogenicity Not relevant.

IARC carcinogenicity Not listed.

Reproductive toxicity

Reproductive toxicity - fertility Does not contain any substances known to be toxic to reproduction.

Reproductive toxicity - development Does not contain any substances known to be toxic to reproduction.

STYCCOBOND F46

Specific target organ toxicity - single exposure

STOT - single exposure Not applicable.

Target organs Not relevant.

Specific target organ toxicity - repeated exposure

STOT - repeated exposure Not applicable.

Target organs Not relevant.

Aspiration hazard

Aspiration hazard Not relevant.

General information No specific health hazards known.

Inhalation The product is considered to be a low hazard under normal conditions of use.

Ingestion No harmful effects expected from quantities likely to be ingested by accident.

Skin contact Skin irritation should not occur when used as recommended.

Eye contact May cause discomfort.

Acute and chronic health hazards No specific health hazards known.

Medical symptoms No specific symptoms known.

Medical considerations No information available.

SECTION 12: Ecological information

Ecotoxicity There are no data on the ecotoxicity of this product.

12.1. Toxicity

Toxicity Not considered toxic to fish.

Acute aquatic toxicity

Acute toxicity - fish No specific test data are available.

Acute toxicity - aquatic invertebrates Not determined.

Acute toxicity - aquatic plants Not determined.

Acute toxicity - microorganisms Not determined.

Acute toxicity - terrestrial Not determined.

Chronic aquatic toxicity

Chronic toxicity - fish early life stage Not determined.

Short term toxicity - embryo and sac fry stages Not determined.

Chronic toxicity - aquatic invertebrates Not determined.

12.2. Persistence and degradability

Persistence and degradability There are no data on the degradability of this product.

STYCCOBOND F46

Phototransformation	Not determined.
Stability (hydrolysis)	Not determined.
Biodegradation	Not determined.
Biological oxygen demand	No specific test data are available.
Chemical oxygen demand	No specific test data are available.

12.3. Bioaccumulative potential

Bioaccumulative potential	No data available on bioaccumulation.
Partition coefficient	Not applicable.

12.4. Mobility in soil

Mobility	The product is non-volatile.
Adsorption/desorption coefficient	Not determined.
Henry's law constant	Not determined.
Surface tension	Not determined.

12.5. Results of PBT and vPvB assessment

Results of PBT and vPvB assessment	This substance is not classified as PBT or vPvB according to current EU criteria.
------------------------------------	---

12.6. Other adverse effects

Other adverse effects	None known.
-----------------------	-------------

SECTION 13: Disposal considerations

13.1. Waste treatment methods

Disposal methods	Collect and place in suitable waste disposal containers and seal securely. Dispose of waste product or used containers in accordance with local regulations
------------------	---

SECTION 14: Transport information

General	The product is not covered by international regulations on the transport of dangerous goods (IMDG, IATA, ADR/RID).
---------	--

14.1. UN number

Not applicable.

14.2. UN proper shipping name

Not applicable.

14.3. Transport hazard class(es)

No transport warning sign required.

14.4. Packing group

Not applicable.

14.5. Environmental hazards

Environmentally hazardous substance/marine pollutant	No.
--	-----

STYCCOBOND F46

14.6. Special precautions for user

Not applicable.

14.7. Transport in bulk according to Annex II of MARPOL and the IBC Code

Transport in bulk according to Not applicable.

Annex II of MARPOL 73/78
and the IBC Code

SECTION 15: Regulatory information

15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

National regulations	Control of Substances Hazardous to Health Regulations 2002 (as amended).
Guidance	Workplace Exposure Limits EH40. Safety Data Sheets for Substances and Preparations.
Authorisations (Annex XIV Regulation 1907/2006)	No specific authorisations are known for this product.
Restrictions (Annex XVII Regulation 1907/2006)	No specific restrictions on use are known for this product.

15.2. Chemical safety assessment

No chemical safety assessment has been carried out.

SECTION 16: Other information

Abbreviations and acronyms used in the safety data sheet	ATE: Acute Toxicity Estimate. PBT: Persistent, Bioaccumulative and Toxic substance. vPvB: Very Persistent and Very Bioaccumulative.
General information	F.Ball and Company Ltd Technical Datasheet.
Key literature references and sources for data	Type of Regulated Adhesive under the Air Pollution Control (Volatile Organic Compounds) Regulation of Hong Kong (VCT and Asphalt Tile Adhesive). VOC Content (ready to use) not exceeding 0g/litre.
Revision comments	Section 2: update.
Revision date	05/01/2021
Revision	17
Supersedes date	27/03/2019
SDS status	Approved.
Hazard statements in full	EUH208 Contains 1,2-BENZISOTHIAZOL-3(2H)-ONE, 5-CHLORO-2-METHYL-2H-ISOTHIAZOL-3-ONE AND 2-METHYL-2H-ISOTHIAZOL-3-ONE. May produce an allergic reaction.

This information relates only to the specific material designated and may not be valid for such material used in combination with any other materials or in any process. Such information is, to the best of the company's knowledge and belief, accurate and reliable as of the date indicated. However, no warranty, guarantee or representation is made to its accuracy, reliability or completeness. It is the user's responsibility to satisfy himself as to the suitability of such information for his own particular use.

Substance Name	Ultra Level It Super Liquid
Site Name	Waitrose Newport
Supplied by	Instarmac Group Plc
Assessed By	Ampthill Flooring Limited

Location	Site Wide Latex Works
Task	Latex Screed
Date	30/04/2026
Review date	30/04/2027

Quantity used		
1	less than 1kg	2
2	less than 10kg	
3	up to 50 kg	
4	up to 100 kg	
5	Over 100 kg	

Always follow the hierarchy of control measures	
1	Can the material/substance be eliminated?
2	Can you substitute the material/substance for something less hazardous?
3	Can engineered containment be applied?
4	Can the operator be isolated through control measures or engineering?
5	As a last resort use relevant personal protective equipment including RPE.

Exposure (time)		
1	Short Periods in Minutes or less than WEL	2
2	Up to 1 hour	
3	1-3 hours	
4	up to 5 hours	
5	All day or WEL exceeded for periods. Use if WEL exceeded at any time	

Control Measures		
Score	Risk	Action
0-6	Low	No further action Needed follow basic hygiene measures. Review if change of use or Quantity
7-12	Low to Medium	Continue with existing control measures including hygiene.
13-18	Medium	Avoid prolonged exposure, do not swallow or ingest. Use rubber gloves when handling Use eye protection
19-24	Medium to High	Avoid prolonged exposure, Use rubber gloves when handling Use eye protection & consider RPE if dust or vapour Skin Contact - wash of with soap and water Eye contact - irrigate with water seek medical attention Inhalation - seek medical attention Ingestion - seek medical attention
25-30	High	Avoid prolonged exposure, do not swallow or ingest. Use rubber gloves and apron/chemical suit when handling Use eye protection - goggles or visor Use RPE Skin Contact - wash of with water seek medical attention Eye contact - irrigate with water seek medical attention Inhalation - seek medical attention Ingestion - seek medical attention
31-40	Avoid at All Costs	Evacuate area If exposed seek medical attention immediately Call emergency services

Physical properties		
1	Solid	3
2	Powder	
3	Liquid	
4	Vapour	
5	Gas	

Physio-Chemical properties		
1	Low	1
2	Flammable	
3	Oxidising or corrosive	
4	Highly Flammable	
5	Explosive	

Health Effects		
1	Low	1
5	Harmful	
10	Harmful Irritant/sensitising (toxic) - breathing/eyes	
15	Long term effects/ carcinogen/mutagen	
20	Very Toxic	

Total Score	Risk	9
--------------------	-------------	----------

Follow guidance for a score of
As shown above

9

Substance Name	Ultra Floor Level It Super 30 Powder
Site Name	Waitrose Newport
Supplied by	Instarmac Group Plc
Assessed By	Ampthill Flooring Limited

Location	Site Wide Latex works
Task	Latex Screed
Date	30/04/2026
Review date	30/04/2027

Quantity used		
1	less than 1kg	3
2	less than 10kg	
3	up to 50 kg	
4	up to 100 kg	
5	Over 100 kg	

Always follow the hierarchy of control measures	
1	Can the material/substance be eliminated?
2	Can you substitute the material/substance for something less hazardous?
3	Can engineered containment be applied?
4	Can the operator be isolated through control measures or engineering?
5	As a last resort use relevant personal protective equipment including RPE.

Exposure (time)		
1	Short Periods in Minutes or less than WEL	2
2	Up to 1 hour	
3	1-3 hours	
4	up to 5 hours	
5	All day or WEL exceeded for periods. Use if WEL exceeded at any time	

Control Measures		
Score	Risk	Action
0-6	Low	No further action Needed follow basic hygiene measures. Review if change of use or Quantity
7-12	Low to Medium	Continue with existing control measures including hygiene.
13-18	Medium	Avoid prolonged exposure, do not swallow or ingest. Use rubber gloves when handling Use eye protection
19-24	Medium to High	Avoid prolonged exposure, Use rubber gloves when handling Use eye protection & consider RPE if dust or vapour Skin Contact - wash of with soap and water Eye contact - irrigate with water seek medical attention Inhalation - seek medical attention Ingestion - seek medical attention
25-30	High	Avoid prolonged exposure, do not swallow or ingest. Use rubber gloves and apron/chemical suit when handling Use eye protection - goggles or visor Use RPE Skin Contact - wash of with water seek medical attention Eye contact - irrigate with water seek medical attention Inhalation - seek medical attention Ingestion - seek medical attention
31-40	Avoid at All Costs	Evacuate area If exposed seek medical attention immediately Call emergency services

Physical properties		
1	Solid	2
2	Powder	
3	Liquid	
4	Vapour	
5	Gas	

Physio-Chemical properties		
1	Low	3
2	Flammable	
3	Oxidising or corrosive	
4	Highly Flammable	
5	Explosive	

Health Effects		
1	Low	1
5	Harmful	
10	Harmful Irritant/sensitising (toxic) - breathing/eyes	
15	Long term effects/ carcinogen/mutagen	
20	Very Toxic	

Total Score	Risk	11
--------------------	-------------	-----------

Follow guidance for a score of
As shown above

11

DECLARATION OF PERFORMANCE

in accordance with Annex 111 of Regulation (EU) No. 305/2011

(Construction Products Regulation)

1. Unique identification code of the product type:

ULTRA FLOOR LEVEL IT SUPER 30

2. Type, batch or serial number or other identifying mark to identify the construction product as set out in Article 11 (4):

Product formulation reference X3503

3. Intended use as foreseen by the manufacturer of the construction product in accordance with harmonised technical specification:

Cementitious screed material for use internally in buildings

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as set out in Article 11 (5):

**Instarmac Group plc
Birch Coppice Industrial Estate
Danny Morson Way, Dordon
Tamworth B78 1SE
United Kingdom**

5. When applicable, the name and contact address of the authorised representative who has received a mandate for the tasks set out in Article 12 (2):

Not relevant

6. System or systems for assessment and verification of constancy of performance of the construction product in accordance with Annex V:

System 4 + 4

7. In the case of a declaration of performance concerning a construction product that is covered by a harmonised standard:

The manufacturer has carried out initial type testing to System 4 + 4.

8. In the case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued.

Not relevant

9. Declared performance

<u>Essential characteristics</u>	<u>Performance</u>	<u>Harmonised technical specification</u>
Compressive Strength	C35	
Flexural strength	F7	
		BSEN 13813:2002
Reaction to Fire	Class F WFT	
Release of corrosive Substances	CT	

CLASSIFICATION - CT-C35-F7

10. The performance of the product identified in items 1 and 2 in conformity with the declared performance set out in item 9. The manufacturer as defined in number 4 is solely responsible for drawing up this declaration of performance.

Signed for on behalf of the manufacturer by:



Tamworth – 13.06.13

..... (Signature) (Place & Date Issued)

Chris Murphy - Technical Director

Revision Date 16/04/2015
Revision 15
Supersedes date 18/03/2015



SAFETY DATA SHEET ULTRA FLOOR LEVEL IT SUPER 30

SECTION 1: IDENTIFICATION OF THE SUBSTANCE/MIXTURE AND OF THE COMPANY/UNDERTAKING

1.1. Product identifier

Product name ULTRA FLOOR LEVEL IT SUPER 30

1.2. Relevant identified uses of the substance or mixture and uses advised against

1.3. Details of the supplier of the safety data sheet

Supplier	Instarmac Group plc Danny Morson Way Birch Coppice Business Park Dordon, Tamworth Staffordshire. B78 1SE United Kingdom Tel: +44 (0) 1827 872244 Fax: +44 (0) 1827 874466 email@instarmac.co.uk www.instarmac.co.uk
----------	--

1.4. Emergency telephone number

+44 (0)7971 217 347

SECTION 2: HAZARDS IDENTIFICATION

2.1. Classification of the substance or mixture

Classification (EC 1272/2008)

Physical and Chemical Hazards	Not classified.
Human health	Not classified.
Environment	Not classified.

Classification (1999/45/EEC)

Not classified.

The Full Text for all R-Phrases and Hazard Statements are Displayed in Section 16.

2.2. Label elements

Label In Accordance With (EC) No. 1272/2008

No pictogram required.

2.3. Other hazards

SECTION 3: COMPOSITION/INFORMATION ON INGREDIENTS

3.2. Mixtures

GROUND NATURAL CALCIUM CARBONATE		10-30%
CAS-No.: 1317-65-3	EC No.:	
Classification (EC 1272/2008) Not classified.	Classification (67/548/EEC) Not classified.	

ULTRA FLOOR LEVEL IT SUPER 30

SILICA SAND		30-60%
CAS-No.: 14808-60-7	EC No.: 238-878-4	
Classification (EC 1272/2008) Not classified.	Classification (67/548/EEC) Not classified.	

The Full Text for all R-Phrases and Hazard Statements are Displayed in Section 16.

SECTION 4: FIRST AID MEASURES

4.1. Description of first aid measures

General information

Risk of serious damage to eyes.

Inhalation

Move into fresh air and keep at rest. Get medical attention if any discomfort continues.

Ingestion

Do not induce vomiting. Immediately rinse mouth and drink plenty of water. Keep person under observation. If person becomes uncomfortable take to hospital along with these instructions.

Skin contact

Remove contaminated clothing immediately and wash skin with soap and water. Get medical attention if irritation persists after washing.

Eye contact

Immediately flush with plenty of water for up to 15 minutes. Remove any contact lenses and open eyes wide apart. Continue to rinse for at least 15 minutes and get medical attention.

4.2. Most important symptoms and effects, both acute and delayed4.3. Indication of any immediate medical attention and special treatment needed

SECTION 5: FIREFIGHTING MEASURES

5.1. Extinguishing media

Extinguishing media

Water. Foam.

5.2. Special hazards arising from the substance or mixture

Unusual Fire & Explosion Hazards

No unusual fire or explosion hazards noted.

5.3. Advice for firefighters

Special Fire Fighting Procedures

No specific fire fighting procedure given.

SECTION 6: ACCIDENTAL RELEASE MEASURES

6.1. Personal precautions, protective equipment and emergency procedures

Wear protective clothing as described in Section 8 of this safety data sheet.

6.2. Environmental precautions

Do not allow to enter drains, sewers or watercourses.

6.3. Methods and material for containment and cleaning up

Remove spillage with vacuum cleaner. If not possible, collect spillage with shovel, broom or the like. Avoid generation and spreading of dust.

6.4. Reference to other sections

SECTION 7: HANDLING AND STORAGE

7.1. Precautions for safe handling

Avoid spilling, skin and eye contact.

7.2. Conditions for safe storage, including any incompatibilities

ULTRA FLOOR LEVEL IT SUPER 30

Store in closed original container at temperatures between 5°C and 30°C. This product must be stored in unopened bags, clear of the ground in cool dry conditions and protected from excessive drafts. If stored correctly and used within 6 months of the date shown on the bag, the activity of the reducing agent will be maintained and this product will contain, when mixed with water, no more than 0.0002% (2 ppm) soluble Chromium (VI) of the total dry weight of the cement.

Shelf life in correct for sealed bags is 6 months. Please note: the use of this product after the end of the declared storage period may increase the risk of an allergic reaction.

7.3. Specific end use(s)

SECTION 8: EXPOSURE CONTROLS/PERSONAL PROTECTION

8.1. Control parameters

Name	STD	TWA - 8 Hrs		STEL - 15 Min		Notes
GROUND NATURAL CALCIUM CARBONATE			4 mg/m3 resp.dust			
SILICA SAND	WEL		0.1 mg/m3			

WEL = Workplace Exposure Limit.

8.2. Exposure controls

Protective equipment



Process conditions

Provide eyewash station.

Engineering measures

Provide sufficient ventilation for operations causing dust formation.

Respiratory equipment

If ventilation is insufficient, suitable respiratory protection must be provided. Dust mask/respirator.

Hand protection

Use suitable protective gloves if risk of skin contact.

Eye protection

Wear dust resistant safety goggles where there is danger of eye contact.

Other Protection

Wear appropriate clothing to prevent any possibility of skin contact.

Hygiene measures

Wash hands at the end of each work shift and before eating, smoking and using the toilet. Wash promptly if skin becomes contaminated.

When using do not eat, drink or smoke. Wash contaminated clothing before reuse.

SECTION 9: PHYSICAL AND CHEMICAL PROPERTIES

9.1. Information on basic physical and chemical properties

Appearance	Powder, dust
Relative density	1.6-2.0 @ 20°C

9.2. Other information

SECTION 10: STABILITY AND REACTIVITY

10.1. Reactivity

10.2. Chemical stability

Stable under normal temperature conditions and recommended use.

10.3. Possibility of hazardous reactions

10.4. Conditions to avoid

10.5. Incompatible materials

ULTRA FLOOR LEVEL IT SUPER 30

Materials To Avoid

Strong acids. Strong alkalis.

10.6. Hazardous decomposition products

SECTION 11: TOXICOLOGICAL INFORMATION

11.1. Information on toxicological effects

Inhalation

May cause damage to mucous membranes in nose, throat, lungs and bronchial system.

Ingestion

May cause discomfort if swallowed.

Skin contact

Prolonged contact with wet cement/mixture may cause burns.

Eye contact

Risk of serious damage to eyes.

SECTION 12: ECOLOGICAL INFORMATION

Ecotoxicity

The product components are not classified as environmentally hazardous. However, this does not exclude the possibility that large or frequent spills can have a harmful or damaging effect on the environment.

12.1. Toxicity12.2. Persistence and degradability12.3. Bioaccumulative potential12.4. Mobility in soil12.5. Results of PBT and vPvB assessment12.6. Other adverse effects

SECTION 13: DISPOSAL CONSIDERATIONS

General information

Dispose of waste and residues in accordance with local authority requirements.

13.1. Waste treatment methods

SECTION 14: TRANSPORT INFORMATION

General

The product is not covered by international regulation on the transport of dangerous goods (IMDG, IATA, ADR/RID).

14.1. UN number14.2. UN proper shipping name14.3. Transport hazard class(es)14.4. Packing group14.5. Environmental hazards14.6. Special precautions for user

ULTRA FLOOR LEVEL IT SUPER 30

14.7. Transport in bulk according to Annex II of MARPOL73/78 and the IBC Code

SECTION 15: REGULATORY INFORMATION

15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

Uk Regulatory References

Chemicals (Hazard Information & Packaging) Regulations.

Environmental Listing

Control of Pollution Act 1974.

Approved Code Of Practice

Safety Data Sheets for Substances and Preparations. Classification and Labelling of Substances and Preparations Dangerous for Supply.

Guidance Notes

Workplace Exposure Limits EH40.

EU Legislation

Dangerous Substance Directive 67/548/EEC. Dangerous Preparations Directive 1999/45/EC. Regulation (EC) No 1907/2006 of the European Parliament and of the Council of 18 December 2006 concerning the Registration, Evaluation, Authorisation and Restriction of Chemicals (REACH), establishing a European Chemicals Agency, amending Directive 1999/45/EC and repealing Council Regulation (EEC) No 793/93 and Commission Regulation (EC) No 1488/94 as well as Council Directive 76/769/EEC and Commission Directives 91/155/EEC, 93/67/EEC, 93/105/EC and 2000/21/EC, including amendments.

National Regulations

Workplace Exposure Limits 2005 (EH40) The Carriage of Dangerous Goods and Use of Transportable Pressure Equipment Regulations 2007 (CDG 2007).

15.2. Chemical Safety Assessment

SECTION 16: OTHER INFORMATION

General information

If further information on training is required contact Instarmac Group plc

Revision Date 16/04/2015

Revision 15

Supersedes date 18/03/2015

Risk Phrases In Full

NC Not classified.

Hazard Statements In Full

Disclaimer

The purpose of the above information is to describe the products only in terms of health and safety requirements. This information relates only to the specific material designated and may not be valid for such material used in combination with any other materials or in any process. It is the users obligation to evaluate and use this product safely and to comply with all applicable laws and regulations. Such information is, to the best of the company's knowledge and belief, accurate and reliable as of the date specified.

All goods are supplied in accordance with Instarmac Group plc's general conditions of sale, copies of which may be obtained by telephoning sales on 01827 872244

Revision Date 27/11/2013
 Revision 6
 Supersedes date 05/03/2013



SAFETY DATA SHEET ULTRA LEVEL IT SUPER LIQUID

SECTION 1: IDENTIFICATION OF THE SUBSTANCE/MIXTURE AND OF THE COMPANY/UNDERTAKING

1.1. Product identifier

Product name ULTRA LEVEL IT SUPER LIQUID

1.2. Relevant identified uses of the substance or mixture and uses advised against

1.3. Details of the supplier of the safety data sheet

Supplier Instarmac Group plc
 Danny Morson Way
 Birch Coppice Business Park
 Dordon, Tamworth
 Staffordshire. B78 1SE
 United Kingdom
 Tel: +44 (0) 1827 872244
 Fax: +44 (0) 1827 874466
 email@instarmac.co.uk www.instarmac.co.uk

1.4. Emergency telephone number

+44 (0)7971 217 347

SECTION 2: HAZARDS IDENTIFICATION

2.1. Classification of the substance or mixture

Classification (EC 1272/2008)

Physical and Chemical Hazards	Not classified.
Human health	Not classified.
Environment	Not classified.

Classification (1999/45/EEC)

Not classified.

The Full Text for all R-Phrases and Hazard Statements are Displayed in Section 16.

2.2. Label elements

Label In Accordance With (EC) No. 1272/2008

No pictogram required.

2.3. Other hazards

SECTION 3: COMPOSITION/INFORMATION ON INGREDIENTS

3.2. Mixtures

SECTION 4: FIRST AID MEASURES

4.1. Description of first aid measures

General information

Under ordinary workplace conditions no special measures required

Inhalation

Move into fresh air and keep at rest.

Ingestion

May cause nausea Do not induce vomiting. NEVER MAKE AN UNCONSCIOUS PERSON VOMIT OR DRINK FLUIDS!

Skin contact

Wash the skin immediately with soap and water.

ULTRA LEVEL IT SUPER LIQUID

Eye contact

Immediately flush with plenty of water for up to 15 minutes. Remove any contact lenses and open eyelids widely. If irritation persists: Continue flushing during transport to hospital. Bring these instructions.

4.2. Most important symptoms and effects, both acute and delayed

4.3. Indication of any immediate medical attention and special treatment needed

SECTION 5: FIREFIGHTING MEASURES

5.1. Extinguishing media

Extinguishing media

The product is non-combustible.

5.2. Special hazards arising from the substance or mixture

5.3. Advice for firefighters

SECTION 6: ACCIDENTAL RELEASE MEASURES

6.1. Personal precautions, protective equipment and emergency procedures

Wear protective clothing as described in Section 8 of this safety data sheet.

6.2. Environmental precautions

Do not discharge into drains, water courses or onto the ground.

6.3. Methods and material for containment and cleaning up

Large spillages should be contained and pumped into a receiving vessel. Absorb spillage with suitable absorbent material. For waste disposal, see section 13.

6.4. Reference to other sections

SECTION 7: HANDLING AND STORAGE

7.1. Precautions for safe handling

No specific usage precautions noted.

7.2. Conditions for safe storage, including any incompatibilities

Store between 5°C and 35°C protected from frost and direct sunlight

7.3. Specific end use(s)

SECTION 8: EXPOSURE CONTROLS/PERSONAL PROTECTION

8.1. Control parameters

Ingredient Comments

WEL = Workplace Exposure Limits

8.2. Exposure controls

Protective equipment



Process conditions

Provide eyewash station.

Hand protection

For prolonged or repeated skin contact use suitable protective gloves.

Eye protection

Wear splash-proof eye goggles to prevent any possibility of eye contact.

Hygiene measures

Wash hands at the end of each work shift and before eating, smoking and using the toilet.

Skin protection

Wash with soap and water after handling

ULTRA LEVEL IT SUPER LIQUID

SECTION 9: PHYSICAL AND CHEMICAL PROPERTIES

9.1. Information on basic physical and chemical properties

Appearance	Liquid
Colour	White.
Odour	Slight odour.

9.2. Other information

SECTION 10: STABILITY AND REACTIVITY

10.1. Reactivity

10.2. Chemical stability

Stable under normal temperature conditions and recommended use.

10.3. Possibility of hazardous reactions

10.4. Conditions to avoid

10.5. Incompatible materials

10.6. Hazardous decomposition products

SECTION 11: TOXICOLOGICAL INFORMATION

11.1. Information on toxicological effects

Toxicological information

No data recorded.

SECTION 12: ECOLOGICAL INFORMATION

Ecotoxicity

No data on possible environmental effects have been found.

12.1. Toxicity

12.2. Persistence and degradability

12.3. Bioaccumulative potential

12.4. Mobility in soil

12.5. Results of PBT and vPvB assessment

12.6. Other adverse effects

SECTION 13: DISPOSAL CONSIDERATIONS

13.1. Waste treatment methods

SECTION 14: TRANSPORT INFORMATION

General

The product is not covered by international regulation on the transport of dangerous goods (IMDG, IATA, ADR/RID).

14.1. UN number

14.2. UN proper shipping name

14.3. Transport hazard class(es)

ULTRA LEVEL IT SUPER LIQUID

14.4. Packing group

14.5. Environmental hazards

14.6. Special precautions for user

14.7. Transport in bulk according to Annex II of MARPOL73/78 and the IBC Code

SECTION 15: REGULATORY INFORMATION

15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

Uk Regulatory References

The Control of Substances Hazardous to Health (Amendment) Regulations 2004 Chemicals (Hazard Information & Packaging) Regulations.

Environmental Listing

Control of Pollution Act 1974.

Approved Code Of Practice

Safety Data Sheets for Substances and Preparations. Classification and Labelling of Substances and Preparations Dangerous for Supply.

EU Legislation

Dangerous Substance Directive 67/548/EEC. Dangerous Preparations Directive 1999/45/EC. Regulation (EC) No 1907/2006 of the European Parliament and of the Council of 18 December 2006 concerning the Registration, Evaluation, Authorisation and Restriction of Chemicals (REACH), establishing a European Chemicals Agency, amending Directive 1999/45/EC and repealing Council Regulation (EEC) No 793/93 and Commission Regulation (EC) No 1488/94 as well as Council Directive 76/769/EEC and Commission Directives 91/155/EEC, 93/67/EEC, 93/105/EC and 2000/21/EC, including amendments.

National Regulations

Workplace Exposure Limits 2005 (EH40) The Carriage of Dangerous Goods and Use of Transportable Pressure Equipment Regulations 2007 (CDG 2007).

15.2. Chemical Safety Assessment

SECTION 16: OTHER INFORMATION

General information

If further information on training is required contact Instarmac Group plc

Revision Date 27/11/2013

Revision 6

Supersedes date 05/03/2013

Risk Phrases In Full

NC Not classified.

Disclaimer

The purpose of the above information is to describe the products only in terms of health and safety requirements. This information relates only to the specific material designated and may not be valid for such material used in combination with any other materials or in any process. It is the users obligation to evaluate and use this product safely and to comply with all applicable laws and regulations. Such information is, to the best of the company's knowledge and belief, accurate and reliable as of the date specified.

All goods are supplied in accordance with Instarmac Group plc's general conditions of sale, copies of which may be obtained by telephoning sales on 01827 872244



Level IT Super30

High Strength, Rapid Drying and Curing Smoothing Underlayment
Screed Classification: CT-C35-F7



Healthcare



Transport



Leisure



Retail

INFORMATION

Ultra Floor Level IT SUPER30 is a high specification, high strength, rapid drying and curing two part cementitious smoothing underlayment. It consists of a powdered component incorporating a blend of high specifications cements, with graded fillers and additives and a pre-gauged polymer liquid.

USES

The two components are mixed to provide a rapid setting and curing, free flowing smoothing underlayment for smoothing strong, sound internal floors, prior to the application of decorative floor coverings. Its rapid set and curing profile enables decorative floor coverings to be loose laid in as little as 45 minutes (unbonded textiles) and fully bonded in just 3 hours after application. This makes it an ideal choice for use in areas where it is necessary to carry out installations in a short timeframe. This includes "Lay in a Day" projects and highly used areas such as corridors, atriums and lobby areas.

Its protein free formulation means it is ideal for use in biologically sensitive areas. It can be used on a variety of subfloors, and is suitable for use where warm water underfloor heating is incorporated.

Level IT SUPER30 can be applied between thicknesses of 2-15mm. Its initial set is approximately 15 minutes with a walk on time of 30 minutes. It is necessary to maintain a wet edge between mixes so working practices should be adjusted accordingly, to ensure this can be achieved within the products open time. Applications up to 5mm thick can normally receive floor coverings after approximately 3 hours (based on good ambient conditions).

SUBFLOOR PREPARATION: ASSESSMENT

All subfloors should be protected from moisture from the subground by use of a Damp Proof Membrane. (Please check older properties, which may not have a base DPM, and consult Ultra Floor for advice).

Assess moisture levels in accordance with BS 8203, to achieve a hygrometer reading of 75% RH or less. Where this is not attained, a surface Damp Proof Membrane should be used - the selection of which will be subject to the subfloor (seek advice from Ultra Floor).

Any surface laitance, adhesive residue, paints, weak smoothing underlayments and any other materials which will hinder Level IT SUPER30's bond with the subfloor, should be mechanically removed. The subfloor should be clean, dry and sound. The area should also be dust free prior to any primer application.

SUBFLOOR PREPARATION: PRIMING SUMMARY

NB: All ratios are water: primer

Subfloors should always be primed. The primer should be allowed to dry prior to the application of Level IT SUPER30. Drying times will be based on ambient conditions- bear in mind that cold or damp/humid conditions and poor airflow, can extend drying time (See Prime IT Multi-surface primer (MSP) datasheet for further information).

Porous Substrates: Ultra Floor Prime IT MSP should be diluted 3:1 with clean water. Normally a single coat is sufficient, however very porous floors may require a further coat. Allow primer to dry fully.

Non-Porous Substrates: Including very dense substrates/subfloors. Ultra Floor Prime IT MSP should be applied neat, in a thin uniform coating and allowed to dry fully.

RECOMMENDED USES

Specifically designed for fast turnaround projects. Use as an underlayment for most floor coverings inc. sheet vinyl, LVT, linoleum & rubber and breathable textiles.

FEATURES

- Rapid curing
- 30 minute walk on time
- Bonded floor coverings after 3 hours
- Extremely smooth finish
- Loose lay in 45 minutes (unbonded textiles)
- Protein free

2-15mm

Thickness



Open
Time up to
10 mins



Walk on
time
30 mins



Internal
Floors



Member of

continued....

SUBFLOOR PREPARATION: WHICH SUBSTRATE?

NB: All ratios are water:primer.

NOTE: Where UFH (Underfloor Heating) systems are incorporated, they must have been fully commissioned and brought up to their maximum temperature, and ideally switched off 48 hours before application. In the absence of other heat sources, the UFH may be set to 'cutback' position to achieve an air temperature of 15°C.

Any expansion or movement joints must be carried through to the floor covering surface.

Ultra Floor Surface DPM: Applications should be carried out within 36 hours of DPM application (see DPM IT datasheets). The DPM must then be primed with Ultra Floor Prime IT MSP neat in a thin uniform coating, allowing it to dry fully (usually 1-2 hours).

Concrete Subfloors: Power floated concrete should be treated as non-porous. Mechanically abrade (shotblast or scarify) to remove surface hardeners to expose the cement/aggregate. Apply Prime IT MSP neat, in a thin uniform coating, allowing it to dry fully (usually 1-2 hours).

Tamped or pan floated concrete should be treated as porous, and any laitance or weak material should be mechanically removed to ensure a sound, dry and dust-free surface. Apply Prime IT MSP diluted 3:1 with clean water and allow to dry fully (usually 1-2 hours).

Sand/Cement Screeds: These should be strong enough for an application of Super 30. Weak, friable or damaged screed should be uplifted and repaired. Apply Prime IT MSP diluted 3:1 with clean water and allow to dry fully (usually 1-2 hours). A two-coat application may be required for very absorbent screeds.

Terrazzo/Granolithic Ceramic Tiles: These must be securely bonded, and any surface treatment should be mechanically removed. A good mechanical key should be ensured by abrading the surface using a Surface Texturing & Grinding (STG) machine (a diamond disc is recommended). These subfloors can be treated as low porosity and primed using Prime IT MSP neat.

Calcium Sulphate/Anhydrite/Hemihydrate Screeds: See relevant technical datasheet. A barrier primer application is required. If moisture is above 75%RH we **do not** recommend using a surface DPM. These screeds often incorporate warm water underfloor heating systems which can be used, along with dehumidifiers, to speed up the drying process. Screed manufacturer's normally suggest this can be conducted after 7 days minimum curing.

Mechanically remove any laitance or weak material to leave a clean, dry and dust-free surface. We recommend an STG machine with a suitable mesh grinding disc of 60-100 grade grit. Apply Prime IT MSP diluted 3:1 with clean water and allow to fully dry overnight. Apply a second coat diluted 1:1 with clean water allowing it to dry to a clear film (usually 1-2 hours).

For any other scenarios please call Ultra Floor Technical Services for advice on 01827 871871

SUPER30 APPLICATION

Shake the bottle of Level IT SUPER30 liquid and pour into an oversized bucket (20+ Ltrs). Gradually add the powder whilst mixing continually with an electric drill with power whisk. When all powder is added mix for a further 2 mins, keeping the whisk below the surface (to minimise air entrapment), until a lump free creamy material is attained.

The product should be mixed as close to the application area as possible and poured onto the subfloor as quickly as possible after mixing. This will ensure maximum working time.

Regularly clean out the bucket or use a new bucket to ensure cured product does not collect in the mixing vessel.

Any spiked roller application should be carried out before the onset of the initial set, typically 10 minutes after mixing.

CURING AND DRYING

All times are based on a 3mm application and good site conditions (ie. air temperature of 20°C, air humidity of 65% and good ventilation). Cold, humid or damp sites, or those with poor airflow, will prolong curing and drying times. Avoid strong drafts and direct sunlight during curing which can 'force dry' the product and result in excess tension and cracking. Level IT SUPER30 is ready to receive light foot traffic after 30 minutes and floor coverings after as little as 45 minutes (unbonded textiles) and 3 hours (bonded).

TECHNICAL DATA

Specification	
BS EN 13813:2002 Screed Classification	CT-C35-F7
Application thickness:	2-15mm
Working time @ 20°C	10 mins
Walk on hardness time @ 20°C	30 mins
Ready to received floor coverings (based on 3mm application)	45 mins (unbonded) 3 hours (bonded) (depending on substrate porosity and nature of flooring)
Compressive Strength (N/mm ²): (to BS EN 13892-2)	1 Day: 20.0 7 Days: 29.0 28 Days: 35.0
Flexural Strength (N/mm ²): (to BS EN 13892-2)	1 Day: 3.0 7 Days: 4.0 28 Days: 7
Packaging:	20kg bags/4 litre bottle

All figures above are based on tests carried out under quality controlled environments. Actual results attained will be subject to site conditions and allowances should be made accordingly.

BS EN13813:2002

References to BS EN13813:2002 confirms the minimum compressive and flexural strengths that the product will attain when tested to the standard.

How much material?

Applied Thickness	Coverage Per Unit (approx)	Consumption Per 100m ² Area
3mm	5.0m ²	20 bags
5mm	3.1m ²	33 bags
10mm	1.5m ²	64 bags

Coverage is for guidance only based on a smooth, non absorbent subfloor. Substrate texture and absorbercy can affect consumption variations.

As with all raw materials, colour variation may occur. Please note that this does not affect the consistency or characteristics of the product.

CLEANING

Tools should be cleaned in water immediately after use to remove excess materials.

STORAGE

Powder: store in a dry place between 5-30°C.

Shelf life is 6 months in correctly sealed bags.

Liquid: store out of direct sunlight and maintain frost free conditions throughout storage and transportation. Shelf life is a minimum 12 months from the date of manufacture under good storage conditions

continued....

QUALITY ASSURANCE

All products are manufactured in a plant, the quality management system of which is certified/registered as conforming with BS EN ISO 9001, ISO 14001 and OHSAS 18001. Ultra Floor products are guaranteed against defective materials and manufacture and will be replaced or money refunded if the goods do not comply with our claims. We cannot, however, accept responsibility arising from the application or use of our products because we have no direct or continuous control over where and how our products are used. All Ultra Floor products are sold subject to our Terms & Conditions of Sale which are available from ultra-floor.co.uk.

HEALTH AND SAFETY

Please ensure that appropriate PPE is used when preparing, mixing and applying products. Always wash hands before consuming food and make sure that materials are kept out of the reach of children and animals. Please dispose of packaging and waste appropriately. A full MSDS for all our products is available from ultra-floor.co.uk.

The information contained within this product technical datasheet is given in good faith, based on our knowledge and experience and is offered to help select and use the most appropriate product. However, Ultra Floor cannot control site conditions or workmanship and cannot accept liability due to inappropriate use. If there are any concerns we advise that a trial area be carried out to ensure the performance of the materials under specific circumstances.

It is the responsibility of both the supplier and the end user to ensure the products are safely stored in a suitable environment to prevent damage and deterioration, including during transportation and placement on site.



Instarmac Group plc, Birch Coppice Business Park, Danny Morson Way, Dordon, Tamworth, Staffordshire, B78 1SE, United Kingdom

Tel: +44 (0) 1827 872244 Fax: +44 (0) 1827 874466

Email: email@instarmac.co.uk Order: orders@instarmac.co.uk Website: www.instarmac.co.uk

Ultra Floor products are guaranteed against defective materials and manufacture, and will be replaced or money refunded if the goods do not comply with our promotional literature. All products are sold subject to our conditions of sale, copies of which may be obtained on request.

An **INSTARMAC** Brand



SAFETY DATA SHEET ULTRA FLOOR LEVEL IT SUPER 30

SECTION 1: Identification of the substance/mixture and of the company/undertaking

1.1. Product identifier

Product name ULTRA FLOOR LEVEL IT SUPER 30

1.2. Relevant identified uses of the substance or mixture and uses advised against

Uses advised against No specific uses advised against are identified.

1.3. Details of the supplier of the safety data sheet

Supplier Instarmac Group plc
Danny Morson Way
Birch Coppice Business Park
Dordon, Tamworth
Staffordshire. B78 1SE
United Kingdom
Tel: +44 (0) 1827 872244
Fax: +44 (0) 1827 874466
email@instarmac.co.uk www.instarmac.co.uk

1.4. Emergency telephone number

Emergency telephone +44(0)1827 254433 +44 (0)7971 217 347

SECTION 2: Hazards identification

2.1. Classification of the substance or mixture

Classification (EC 1272/2008)

Physical hazards Not Classified

Health hazards Not Classified

Environmental hazards Not Classified

Human health See Section 11 for additional information on health hazards.

Environmental The product is not expected to be hazardous to the environment.

2.2. Label elements

Hazard statements NC Not Classified

2.3. Other hazards

This substance is not classified as PBT or vPvB according to current EU criteria.

SECTION 3: Composition/information on ingredients

3.2. Mixtures

ULTRA FLOOR LEVEL IT SUPER 30

SILICA SAND	30-60%
CAS number: 14808-60-7	EC number: 238-878-4
Classification Not Classified	

GROUND NATURAL CALCIUM CARBONATE	10-30%
CAS number: 1317-65-3	
Classification Not Classified	

The full text for all hazard statements is displayed in Section 16.

SECTION 4: First aid measures

4.1. Description of first aid measures

General information	Remove affected person from source of contamination. Get medical attention if any discomfort continues.
Inhalation	Move affected person to fresh air and keep warm and at rest in a position comfortable for breathing. Get medical attention if any discomfort continues.
Ingestion	Rinse mouth thoroughly with water. Give plenty of water to drink. Keep affected person under observation. Get medical attention if any discomfort continues. Show this Safety Data Sheet to the medical personnel. Never give anything by mouth to an unconscious person.
Skin contact	Rinse immediately with plenty of water. Remove contaminated clothing. Get medical attention if any discomfort continues.
Eye contact	Rinse immediately with plenty of water. Remove any contact lenses and open eyelids wide apart. Continue to rinse for at least 15 minutes. Get medical attention if any discomfort continues.

4.2. Most important symptoms and effects, both acute and delayed

General information	The severity of the symptoms described will vary dependent on the concentration and the length of exposure.
----------------------------	---

4.3. Indication of any immediate medical attention and special treatment needed

Notes for the doctor	No specific recommendations.
-----------------------------	------------------------------

SECTION 5: Firefighting measures

5.1. Extinguishing media

Suitable extinguishing media	Use fire-extinguishing media suitable for the surrounding fire.
-------------------------------------	---

5.2. Special hazards arising from the substance or mixture

Specific hazards	Not known. No unusual fire or explosion hazards noted.
Hazardous combustion products	Does not decompose when used and stored as recommended.

5.3. Advice for firefighters

Protective actions during firefighting	No specific firefighting precautions known.
---	---

ULTRA FLOOR LEVEL IT SUPER 30

Special protective equipment for firefighters Use protective equipment appropriate for surrounding materials.

SECTION 6: Accidental release measures

6.1. Personal precautions, protective equipment and emergency procedures

Personal precautions Wear protective clothing as described in Section 8 of this safety data sheet.

6.2. Environmental precautions

Environmental precautions Avoid release to the environment.

6.3. Methods and material for containment and cleaning up

Methods for cleaning up GENERAL. For waste disposal, see Section 13.

6.4. Reference to other sections

Reference to other sections For personal protection, see Section 8. Collect and dispose of spillage as indicated in Section 13. See Section 11 for additional information on health hazards.

SECTION 7: Handling and storage

7.1. Precautions for safe handling

Usage precautions No specific recommendations.

7.2. Conditions for safe storage, including any incompatibilities

Storage precautions Store at moderate temperatures in dry, well ventilated area.

Storage class Unspecified storage.

7.3. Specific end use(s)

Specific end use(s) The identified uses for this product are detailed in Section 1.2.

SECTION 8: Exposure Controls/personal protection

8.1. Control parameters

Occupational exposure limits

SILICA SAND

Long-term exposure limit (8-hour TWA): WEL 0.1 mg/m³

GROUND NATURAL CALCIUM CARBONATE

Long-term exposure limit (8-hour TWA): 4 mg/m³ resp.dust

WEL = Workplace Exposure Limit

Ingredient comments No exposure limits known for ingredient(s).

8.2. Exposure controls

Protective equipment



Appropriate engineering controls

Not relevant.

Eye/face protection

The following protection should be worn: Chemical splash goggles.

Hand protection

Chemical-resistant, impervious gloves complying with an approved standard should be worn if a risk assessment indicates skin contact is possible.

ULTRA FLOOR LEVEL IT SUPER 30

Other skin and body protection	Wear appropriate clothing to prevent any possibility of skin contact.
Hygiene measures	Wash at the end of each work shift and before eating, smoking and using the toilet. No specific hygiene procedures recommended but good personal hygiene practices should always be observed when working with chemical products.
Respiratory protection	No specific recommendations. Respiratory protection may be required if excessive airborne contamination occurs.

SECTION 9: Physical and Chemical Properties

9.1. Information on basic physical and chemical properties

Appearance Dusty powder.

9.2. Other information

Other information Not available.

SECTION 10: Stability and reactivity

10.1. Reactivity

Reactivity There are no known reactivity hazards associated with this product.

10.2. Chemical stability

Stability No particular stability concerns.

10.3. Possibility of hazardous reactions

Possibility of hazardous reactions Not applicable. No potentially hazardous reactions known.

10.4. Conditions to avoid

Conditions to avoid There are no known conditions that are likely to result in a hazardous situation.

10.5. Incompatible materials

Materials to avoid No specific material or group of materials is likely to react with the product to produce a hazardous situation.

10.6. Hazardous decomposition products

Hazardous decomposition products Does not decompose when used and stored as recommended.

SECTION 11: Toxicological information

11.1. Information on toxicological effects

Toxicological effects No information available.

General information No specific health hazards known.

Inhalation No specific health hazards known.

Ingestion May cause irritation. Symptoms following overexposure may include the following: Stomach pain. Nausea, vomiting. Diarrhoea.

Skin contact Irritating to skin.

Eye contact Irritating to eyes.

ULTRA FLOOR LEVEL IT SUPER 30

Acute and chronic health hazards This product may cause skin and eye irritation.

SECTION 12: Ecological Information

Ecotoxicity There are no data on the ecotoxicity of this product.

12.1. Toxicity

Toxicity No information available

12.2. Persistence and degradability

Persistence and degradability No information available There are no data on the degradability of this product.

12.3. Bioaccumulative potential

Bioaccumulative potential No data available on bioaccumulation.

12.4. Mobility in soil

Mobility The product is non-volatile.

12.5. Results of PBT and vPvB assessment

Results of PBT and vPvB assessment This substance is not classified as PBT or vPvB according to current EU criteria.

12.6. Other adverse effects

Other adverse effects Not available.

SECTION 13: Disposal considerations

13.1. Waste treatment methods

General information When handling waste, the safety precautions applying to handling of the product should be considered.

Disposal methods Dispose of waste to licensed waste disposal site in accordance with the requirements of the local Waste Disposal Authority.

SECTION 14: Transport information

General The product is not covered by international regulations on the transport of dangerous goods (IMDG, IATA, ADR/RID).

14.1. UN number

Not applicable.

14.2. UN proper shipping name

Not applicable.

14.3. Transport hazard class(es)

Not applicable.

14.4. Packing group

Not applicable.

14.5. Environmental hazards

Environmentally hazardous substance/marine pollutant

No.

ULTRA FLOOR LEVEL IT SUPER 30

14.6. Special precautions for user

Not applicable.

14.7. Transport in bulk according to Annex II of MARPOL and the IBC Code

Transport in bulk according to Not applicable.

Annex II of MARPOL 73/78
and the IBC Code

SECTION 15: Regulatory information

15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

National regulations Health and Safety at Work etc. Act 1974 (as amended).
Control of Substances Hazardous to Health Regulations 2002 (as amended).

Guidance Safety Data Sheets for Substances and Preparations.

15.2. Chemical safety assessment

No chemical safety assessment has been carried out.

SECTION 16: Other information

General information Only trained personnel should use this material.

Issued by HS&E Manager.

Revision date 17/05/2017

SDS status Approved.



SAFETY DATA SHEET

Ultra Floor Level It Super 30 Liquid

SECTION 1: Identification of the substance/mixture and of the company/undertaking

1.1. Product identifier

Product name Ultra Floor Level It Super 30 Liquid

1.2. Relevant identified uses of the substance or mixture and uses advised against

Uses advised against No specific uses advised against are identified.

1.3. Details of the supplier of the safety data sheet

Supplier Instarmac Group plc
Danny Morson Way
Birch Coppice Business Park
Dordon, Tamworth
Staffordshire. B78 1SE
United Kingdom
Tel: +44 (0) 1827 872244
Fax: +44 (0) 1827 874466
email@instarmac.co.uk www.instarmac.co.uk

1.4. Emergency telephone number

Emergency telephone +44(0)1827 254433 +44 (0)7971 217 347

SECTION 2: Hazards identification

2.1. Classification of the substance or mixture

Classification (EC 1272/2008)

Physical hazards Not Classified

Health hazards Not Classified

Environmental hazards Not Classified

Human health See Section 11 for additional information on health hazards.

Environmental The product is not expected to be hazardous to the environment.

2.2. Label elements

Hazard statements NC Not Classified

2.3. Other hazards

This substance is not classified as PBT or vPvB according to current EU criteria.

SECTION 3: Composition/information on ingredients

3.2. Mixtures

Composition comments None of the ingredients are required to be listed.

SECTION 4: First aid measures

4.1. Description of first aid measures

Ultra Floor Level It Super 30 Liquid

General information	Remove affected person from source of contamination. Get medical attention if any discomfort continues.
Inhalation	Move affected person to fresh air and keep warm and at rest in a position comfortable for breathing. Get medical attention if any discomfort continues.
Ingestion	Rinse mouth thoroughly with water. Give plenty of water to drink. Keep affected person under observation. Get medical attention if any discomfort continues. Show this Safety Data Sheet to the medical personnel. Never give anything by mouth to an unconscious person.
Skin contact	Rinse immediately with plenty of water. Remove contaminated clothing. Get medical attention if any discomfort continues.
Eye contact	Rinse immediately with plenty of water. Remove any contact lenses and open eyelids wide apart. Continue to rinse for at least 15 minutes. Get medical attention if any discomfort continues.

4.2. Most important symptoms and effects, both acute and delayed

General information	The severity of the symptoms described will vary dependent on the concentration and the length of exposure.
----------------------------	---

4.3. Indication of any immediate medical attention and special treatment needed

Notes for the doctor	No specific recommendations.
-----------------------------	------------------------------

SECTION 5: Firefighting measures

5.1. Extinguishing media

Suitable extinguishing media	Use fire-extinguishing media suitable for the surrounding fire.
-------------------------------------	---

5.2. Special hazards arising from the substance or mixture

Specific hazards	Not known. No unusual fire or explosion hazards noted.
Hazardous combustion products	Does not decompose when used and stored as recommended.

5.3. Advice for firefighters

Protective actions during firefighting	No specific firefighting precautions known.
Special protective equipment for firefighters	Use protective equipment appropriate for surrounding materials.

SECTION 6: Accidental release measures

6.1. Personal precautions, protective equipment and emergency procedures

Personal precautions	Wear protective clothing as described in Section 8 of this safety data sheet.
-----------------------------	---

6.2. Environmental precautions

Environmental precautions	Avoid release to the environment.
----------------------------------	-----------------------------------

6.3. Methods and material for containment and cleaning up

Methods for cleaning up	GENERAL. Wear suitable protective equipment, including gloves, goggles/face shield, respirator, boots, clothing or apron, as appropriate.
--------------------------------	---

6.4. Reference to other sections

Reference to other sections	For personal protection, see Section 8. Collect and dispose of spillage as indicated in Section 13. See Section 11 for additional information on health hazards.
------------------------------------	--

Ultra Floor Level It Super 30 Liquid

SECTION 7: Handling and storage

7.1. Precautions for safe handling

Usage precautions Read and follow manufacturer's recommendations.

7.2. Conditions for safe storage, including any incompatibilities

Storage precautions Store at moderate temperatures in dry, well ventilated area.

Storage class Unspecified storage.

7.3. Specific end use(s)

Specific end use(s) The identified uses for this product are detailed in Section 1.2.

SECTION 8: Exposure Controls/personal protection

8.1. Control parameters

Occupational exposure limits

METHYL-2H or METHYL-4 (3:1) Mixture of EC NO 220-239-6

Long-term exposure limit (8-hour TWA): WEL 0.20 mg/m³

WEL = Workplace Exposure Limit

Ingredient comments No exposure limits known for ingredient(s).

FOAM CONTROL AGENT (CAS: 64742-65-0)

Ingredient comments WEL = Workplace Exposure Limits

8.2. Exposure controls

Protective equipment



Appropriate engineering controls Not relevant.

Eye/face protection The following protection should be worn: Chemical splash goggles.

Hand protection Chemical-resistant, impervious gloves complying with an approved standard should be worn if a risk assessment indicates skin contact is possible.

Other skin and body protection Wear appropriate clothing to prevent any possibility of skin contact.

Hygiene measures Wash at the end of each work shift and before eating, smoking and using the toilet. No specific hygiene procedures recommended but good personal hygiene practices should always be observed when working with chemical products.

Respiratory protection No specific recommendations.

SECTION 9: Physical and Chemical Properties

9.1. Information on basic physical and chemical properties

Appearance Liquid.

9.2. Other information

Other information Not available.

Ultra Floor Level It Super 30 Liquid

SECTION 10: Stability and reactivity

10.1. Reactivity

Reactivity There are no known reactivity hazards associated with this product.

10.2. Chemical stability

Stability No particular stability concerns.

10.3. Possibility of hazardous reactions

Possibility of hazardous reactions Not applicable. No potentially hazardous reactions known.

10.4. Conditions to avoid

Conditions to avoid There are no known conditions that are likely to result in a hazardous situation.

10.5. Incompatible materials

Materials to avoid No specific material or group of materials is likely to react with the product to produce a hazardous situation.

10.6. Hazardous decomposition products

Hazardous decomposition products Does not decompose when used and stored as recommended.

SECTION 11: Toxicological information

11.1. Information on toxicological effects

Toxicological effects No information available.

General information No specific health hazards known.

Inhalation No specific health hazards known.

Ingestion May cause irritation. Symptoms following overexposure may include the following: Stomach pain. Nausea, vomiting. Diarrhoea.

Skin contact Irritating to skin.

Eye contact Irritating to eyes.

Acute and chronic health hazards This product may cause skin and eye irritation.

SECTION 12: Ecological Information

Ecotoxicity There are no data on the ecotoxicity of this product.

12.1. Toxicity

Toxicity No information available

12.2. Persistence and degradability

Persistence and degradability No information available There are no data on the degradability of this product.

12.3. Bioaccumulative potential

Bioaccumulative potential No data available on bioaccumulation.

12.4. Mobility in soil

Mobility The product is non-volatile.

Ultra Floor Level It Super 30 Liquid

12.5. Results of PBT and vPvB assessment

Results of PBT and vPvB assessment This substance is not classified as PBT or vPvB according to current EU criteria.

12.6. Other adverse effects

Other adverse effects Not available.

SECTION 13: Disposal considerations

13.1. Waste treatment methods

General information When handling waste, the safety precautions applying to handling of the product should be considered.

Disposal methods Dispose of waste to licensed waste disposal site in accordance with the requirements of the local Waste Disposal Authority.

SECTION 14: Transport information

General The product is not covered by international regulations on the transport of dangerous goods (IMDG, IATA, ADR/RID).

14.1. UN number

Not applicable.

14.2. UN proper shipping name

Not applicable.

14.3. Transport hazard class(es)

Not applicable.

14.4. Packing group

Not applicable.

14.5. Environmental hazards

Environmentally hazardous substance/marine pollutant
No.

14.6. Special precautions for user

Not applicable.

14.7. Transport in bulk according to Annex II of MARPOL and the IBC Code

Transport in bulk according to Annex II of MARPOL 73/78 and the IBC Code Not applicable.

SECTION 15: Regulatory information

15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

National regulations Health and Safety at Work etc. Act 1974 (as amended).
Control of Substances Hazardous to Health Regulations 2002 (as amended).

Guidance Safety Data Sheets for Substances and Preparations.

15.2. Chemical safety assessment

No chemical safety assessment has been carried out.

Ultra Floor Level It Super 30 Liquid

SECTION 16: Other information

General information	Only trained personnel should use this material.
Issued by	HS&E Manager.
Revision date	14/06/2017
SDS number	20329
SDS status	Approved.