

Document Reference: UHSF20.1	RAMS REVIEW FORM	 CONSTRUCTING CHANGE
--	-------------------------	---

METHOD STATEMENT / RISK ASSESSMENT DETAILS

Name of company:	Dy-rect Services Ltd	Account:	Waitrose
Site	Newport - 81978	Submitted by:	Mike James
Title:	Installation and strip-out of ductwork, fans and grilles		
Date submitted to Uplands for review:	19.08.2026		

UPLANDS REVIEW

Uplands Review Details			
Name:	M. Singlehurst	Position:	Project Manager
Signed:		Date:	27.08.2026
A	No Comments, Satisfactory		
B	Minor Comments. Satisfactory Subject to Incorporation of Comments Below		
C	Unsatisfactory, please revise and Re submit to include comments below:		✓
Date sent for amendments to be added:		Date received back with amendment added:	
General Comments:	Do not accept as final without revision. The document is marked For Approval, accepted-by is blank, time scale is incomplete, contact details are incomplete, COSHH attachments are not evidenced, and MC-controlled crane/roof works need clearer interface controls.		

All Hazards identified MUST have the appropriate CONTROLS MEASURES identified and explained in the RAMs.

Demolition	Yes ☐ No ☒	Licensed Asbestos Removal	Yes ☐ No ☒
Hot Works	Yes ☒ No ☐	Non-Licensed Asbestos Removal	Yes ☐ No ☒
Steel Erection	Yes ☐ No ☒	Dust	Yes ☒ No ☐
Work At Height	Yes ☒ No ☐	Noise	Yes ☒ No ☐
Roof Work / Work Near Fragile Materials	Yes ☒ No ☐	Vibration	Yes ☒ No ☐
Temporary Works including Scaffolding	Yes ☒ No ☐	Manual Handling	Yes ☒ No ☐
Breaking Ground / Digging	Yes ☐ No ☒	Epoxy Resins	Yes ☐ No ☒
Working in Excavations	Yes ☐ No ☒	Methyl methacrylate (MMA)	Yes ☐ No ☒
Confined Space Work	Yes ☐ No ☒	UV (Solar) Radiation	Yes ☐ No ☒
Lifting Operations	Yes ☒ No ☐	Leptospirosis	Yes ☐ No ☒
Overhead Services	Yes ☒ No ☐	Psittacosis	Yes ☐ No ☒
Electrical Work	Yes ☒ No ☐	Needle Stick Injury	Yes ☐ No ☒
Use of Plant and Equipment	Yes ☒ No ☐	Hazardous Substances	Yes ☒ No ☐
PAT Testing	Yes ☒ No ☐	Falls of materials	Yes ☒ No ☐
Restricted Access and Egress	Yes ☒ No ☐	Working on / adjacent to water	Yes ☐ No ☒
Vehicle / Plant Movements	Yes ☒ No ☐	Adverse weather	Yes ☐ No ☒
Segregation	Yes ☒ No ☐	Other Hazards: Please Specify:	
Fire / Explosion	Yes ☒ No ☐	COVID-19	Yes ☐ No ☒
Sharp Objects	Yes ☒ No ☐		
Poor Ground Conditions	Yes ☒ No ☐		
Non English Speaking Operatives	Yes ☐ No ☒		
Flying Particles	Yes ☒ No ☐		

Document Reference: UHSF20.1	Title: RAMS REVIEW FORM	 CONSTRUCTING CHANGE
--	-----------------------------------	---

Pressure Systems	Yes ☒	No ☐	
QUESTION	YES	NO	COMMENTS
1. Are appropriate controls contained in the RAMs to mitigate the risks arising from the hazards identified overleaf?	☒	☐	Controls are included for access/egress, mobile towers, ladders, abrasive wheels, portable electrical tools, hot works, manual handling, plant, PPE and waste.
2. Do they cover all the likely significant hazards that will be encountered in the work?	☐	☒	Major hazards are partly covered, but crane lifting of roof ductwork, COSHH attachments, exact roof controls and accepted final status are not complete enough.
2. Are Uplands Permits to Work required? If so state which ones in the comments section.	☒	☐	Permits required for hot works, roof works, WAH/mobile tower use, any ladder use, isolations and crane/lifting interfaces controlled by MC/Uplands.
3. Is the area of work and scope of works clearly defined?	☐	☒	Scope is described, but location is only store construction zones and the time scale is incomplete.
4. Are supervisory and communications arrangements clearly defined? State the name of the Contractors Supervisor in the comments section.	☐	☒	Named operatives are listed, but contact numbers are blank and document acceptance/sign-off is incomplete.
5. Has the responsibility for monitoring the operations, to which the method statement relates, been clearly defined?	☒	☐	Monitoring is assigned to Dy-rect supervisors, ICH supervision and MC recorded information, subject to the missing acceptance details being resolved.
6. Does the document identify the training requirements for personnel engaged on the work?	☒	☐	Certification is listed for PASMA, IPAF, abrasive wheels, asbestos awareness and skills cards.
7. HAS EITHER OF THE FOLLOWING BEEN CARRIED OUT IN RELATION TO NON ENGLISH SPEAKING OPERATIVES: A. A Bi-lingual Supervisor has translated the RAMs to the Non English speaking Operatives in the presence of an Uplands Manager B. RAMs have been provided in the Non English speaking operative's native language.	☐	☒	No non-English speaking operatives are identified and no translation arrangements are stated.
8. Has the impact of the work on other contractors, visitors, and public areas been assessed? & if so have controls been proposed to protect them?	☒	☐	Interfaces with other trades, barriers, signage, access routes and site traffic arrangements are included.
9. Are arrangements for emergencies adequately addressed?	☒	☐	Emergency and first aid arrangements are covered via ICH/MC procedures and named first aiders, though telephone details should be completed.
10. Has the appropriate personal protective equipment been identified?	☒	☐	PPE includes hi-vis, gloves, hard hat, safety boots, hearing protection, FFP3 and safety glasses/goggles.
11. Are environmental aspects such as waste disposal, contaminated spoil, water pollution etc., adequately addressed?	☐	☒	Waste/housekeeping is addressed, but COSHH assessments are stated as required attachments and are not evidenced in the extracted document.
12. Is there anything else that the RAMs needs to address?	☒	☐	Revise/resubmit with accepted status, complete timescale and contact details, attach COSHH/MSDS, and add specific crane/roof interface controls.

Note: By accepting this method statement Uplands do not assume responsibility for any errors or omissions by the author. The contractor is not relieved of statutory obligation to provide, monitor and revise their safe system of work during progress with the activity. All revisions to the document or the system of work must be agreed with Uplands prior to execution of the work.