

Document Reference: UHSF20.1	RAMS REVIEW FORM	 CONSTRUCTING CHANGE
--	-------------------------	---

METHOD STATEMENT / RISK ASSESSMENT DETAILS

Name of company:	ICH Projects Ltd	Account:	Waitrose
Site	Newport - 81978	Submitted by:	Daniel Boden
Title:	L4L scheme: AC, plumbing and gas works		
Date submitted to Uplands for review:	August 2026		

UPLANDS REVIEW

Uplands Review Details			
Name:	M. Singlehurst	Position:	Project Manager
Signed:		Date:	27.08.2026
A	No Comments, Satisfactory		
B	Minor Comments. Satisfactory Subject to Incorporation of Comments Below		✓
C	Unsatisfactory, please revise and Re submit to include comments below:		
Date sent for amendments to be added:		Date received back with amendment added:	
General Comments:	Broad controls are included, but the document needs site-specific tightening: version is N/A, site supervisor details are blank, scope is generic, and the address/hospital details should be checked before works start.		

All Hazards identified MUST have the appropriate CONTROLS MEASURES identified and explained in the RAMs.

Demolition	Yes ☐ No ☒	Licensed Asbestos Removal	Yes ☐ No ☒
Hot Works	Yes ☐ No ☒	Non-Licensed Asbestos Removal	Yes ☐ No ☒
Steel Erection	Yes ☐ No ☒	Dust	Yes ☒ No ☐
Work At Height	Yes ☒ No ☐	Noise	Yes ☒ No ☐
Roof Work / Work Near Fragile Materials	Yes ☐ No ☒	Vibration	Yes ☒ No ☐
Temporary Works including Scaffolding	Yes ☒ No ☐	Manual Handling	Yes ☒ No ☐
Breaking Ground / Digging	Yes ☐ No ☒	Epoxy Resins	Yes ☐ No ☒
Working in Excavations	Yes ☐ No ☒	Methyl methacrylate (MMA)	Yes ☐ No ☒
Confined Space Work	Yes ☒ No ☐	UV (Solar) Radiation	Yes ☒ No ☐
Lifting Operations	Yes ☒ No ☐	Leptospirosis	Yes ☐ No ☒
Overhead Services	Yes ☒ No ☐	Psittacosis	Yes ☐ No ☒
Electrical Work	Yes ☒ No ☐	Needle Stick Injury	Yes ☐ No ☒
Use of Plant and Equipment	Yes ☒ No ☐	Hazardous Substances	Yes ☒ No ☐
PAT Testing	Yes ☒ No ☐	Falls of materials	Yes ☒ No ☐
Restricted Access and Egress	Yes ☒ No ☐	Working on / adjacent to water	Yes ☐ No ☒
Vehicle / Plant Movements	Yes ☒ No ☐	Adverse weather	Yes ☒ No ☐
Segregation	Yes ☒ No ☐	Other Hazards: Please Specify:	
Fire / Explosion	Yes ☒ No ☐	COVID-19	Yes ☐ No ☒
Sharp Objects	Yes ☒ No ☐		
Poor Ground Conditions	Yes ☒ No ☐		
Non English Speaking Operatives	Yes ☐ No ☒		
Flying Particles	Yes ☒ No ☐		

Document Reference: UHSF20.1	Title: RAMS REVIEW FORM	 CONSTRUCTING CHANGE
--	-----------------------------------	---

Pressure Systems	Yes ☒	No ☐	
QUESTION	YES	NO	COMMENTS
1. Are appropriate controls contained in the RAMs to mitigate the risks arising from the hazards identified overleaf?	☒	☐	Controls are included for AC installation, gas works, pipework, WAH/MEWP, manual handling, COSHH, electrical isolation, waste, PPE and emergency arrangements.
2. Do they cover all the likely significant hazards that will be encountered in the work?	☒	☐	Likely significant hazards are covered, but several sections are generic and should be checked against the final Waitrose Newport workforce.
2. Are Uplands Permits to Work required? If so state which ones in the comments section.	☒	☐	Permits may be required for WAH/MEWP, gas works, electrical isolation/live services, confined-space work if applicable, and any client-specific permit-to-work process.
3. Is the area of work and scope of works clearly defined?	☒	☐	Project is Waitrose Newport L4L scheme, but the task description is broad. Confirm exact work areas and whether the nearest hospital/address details are correct.
4. Are supervisory and communications arrangements clearly defined? State the name of the Contractors Supervisor in the comments section.	☐	☒	Site manager is named as Gary Bathurst, but site supervisor details are blank. Add contractor/site supervision and communication lines.
5. Has the responsibility for monitoring the operations, to which the method statement relates, been clearly defined?	☒	☐	Monitoring is covered through site induction, PDA site-specific risk assessment, stopping/reassessing changed work, and permit sign-off.
6. Does the document identify the training requirements for personnel engaged on the work?	☒	☐	Training is referenced through relevant work-at-height, IPAF, PASMA, asbestos awareness, electrical and task competency controls.
7. HAS EITHER OF THE FOLLOWING BEEN CARRIED OUT IN RELATION TO NON ENGLISH SPEAKING OPERATIVES: A. A Bi-lingual Supervisor has translated the RAMs to the Non English speaking Operatives in the presence of an Uplands Manager B. RAMs have been provided in the Non English speaking operative's native language.	☐	☒	No non-English speaking operatives are identified and no translation arrangements are stated.
8. Has the impact of the work on other contractors, visitors, and public areas been assessed? & if so have controls been proposed to protect them?	☒	☐	Contractors, visitors, public and other affected groups are included, with barriers, signage and controlled access/egress.
9. Are arrangements for emergencies adequately addressed?	☒	☐	Emergency, first aid and evacuation arrangements are included, but site-specific first aid contacts should be completed.
10. Has the appropriate personal protective equipment been identified?	☒	☐	PPE includes head, eye, hearing, hand, foot, hi-vis, mask and site-specific requirements.
11. Are environmental aspects such as waste disposal, contaminated spoil, water pollution etc., adequately addressed?	☒	☐	Waste handling, COSHH, spill response and environmental controls are referenced.
12. Is there anything else that the RAMs needs to address?	☒	☐	Amend before final acceptance: complete supervisor fields, confirm exact scope/work areas, remove ambiguity in versioning, and verify hospital/site address details.

Note: By accepting this method statement Uplands do not assume responsibility for any errors or omissions by the author. The contractor is not relieved of statutory obligation to provide, monitor and revise their safe system of work during progress with the activity. All revisions to the document or the system of work must be agreed with Uplands prior to execution of the work.

Date Reviewed: 30-06-2025 Rev3	Document Type: FORM	Document Created By: HSEQ DEPT	Status: APPROVED	PAGE 2 of 2
-----------------------------------	------------------------	-----------------------------------	---------------------	-------------