

Inspection Report IR-22 — Hydrostatic pressure test

Plant: Shakti Petrochem Unit-2 | **Asset:** V-301 | **Date:** 2024-05-12 | **Result:** PASS | **Next Due:** 2026-05-12

Findings

Vessel hydrostatically tested to 1.5x MAWP. Passed. Certificate issued, valid per statutory interval.

Result

PASS