

Inspection Report IR-30 — Baseline vibration

Plant: Shakti Petrochem Unit-2 | **Asset:** P-204A | **Date:** 2026-02-10 | **Result:** PASS | **Next Due:** 2026-05-10

Findings

Baseline vibration 3.1 mm/s RMS, within limits.

Result

PASS