

Work Order WO-133 — Rising outlet temperature

Plant: Shakti Petrochem Unit-2 | **Asset:** HX-102 | **Date:** 2026-06-05 | **Status:** open

Description

Process reported HX-102 outlet temperature rising above baseline at constant duty.

Findings

Suspected tube-side fouling. Outlet temp 9 degC above baseline.

Action Taken

Scheduled chemical cleaning of tube bundle.

Post-Repair Test

n/a