

Compliance Checklist CMP-02

Plant: Shakti Petrochem Unit-2 | **Asset:** C-110 | **Standard:** OISD-STD-106 | **Status:** OK

Requirement

Relief-valve pop test within interval

Evidence Status

OK

Note

Relief valve tested within statutory interval.