

Compliance Checklist CMP-03

Plant: Shakti Petrochem Unit-2 | **Asset:** P-204A | **Standard:** Internal QMS / SOP-17 | **Status:** GAP

Requirement

Post-maintenance verification recorded on closeout

Evidence Status

GAP

Note

WO-141 closed without a recorded post-repair vibration reading.