

SOP-30 — Heat Exchanger Cleaning

Plant: Shakti Petrochem Unit-2 | **Applies To:** Heat Exchanger | **Revision:** Rev 3 | **Last Reviewed:** 2025-06-15

Procedure Steps

1. Trend outlet temperature; clean when it rises 8 degC above baseline or every 6 months.
2. Isolate, drain, and gas-free before opening the channel.