

Work Order WO-108 — Coupling inspection

Plant: Shakti Petrochem Unit-2 | **Asset:** P-204A | **Date:** 2026-03-15 | **Status:** closed

Description

Routine coupling inspection on P-204A.

Findings

Coupling element showing early wear.

Action Taken

Noted for next overhaul.

Post-Repair Test

n/a