Coolfix Home Services (demo)

Service job card. Air conditioners. Pune.

Job no.
CF-7417

Date
25 May 2026

Customer
S. Fernandes

Area
Baner

Unit model
Coolwave CS-18F

Serial no.
A93-14438

Complaint
Outdoor unit noisy

Suction (psi)
130

Compressor (A)
7.1

Supply air (C)
14

Work done
Outdoor fan bearing noisy, lubricated

Parts used
None

Remarks
Fan motor to be replaced if noise returns

Next service
Nov 2026

Technician
Anil

☐ Filters cleaned ☐ Gas topped up ☑ Customer informed

Customer signature
Fernandes